

TECHNICAL EVALUATION REPORT

**REVIEW OF LICENSEES' RESOLUTION OF OUTSTANDING ISSUES
FROM NRC EQUIPMENT ENVIRONMENTAL QUALIFICATION
SAFETY EVALUATION REPORTS (F-11 and B-60)**

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT 1

VOL. 2 OF 2

NRC DOCKET NO. 50-280

FRC PROJECT C5257

NRC TAC NO. 42468

FRC ASSIGNMENT 13

NRC CONTRACT NO. NRC-03-79-118

FRC TASK 482

Prepared by

Franklin Research Center
20th and Race Streets
Philadelphia, PA 19103

FRC Group Leader: G. J. Toman

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

December

This report was prepared as an account of work performed for the United States Government. Neither the United States Government, nor any of its employees, makes any warranty, expressed or implied, or assumes any legal responsibility for any third party's use, or the results of its use, of the information, data, or conclusions contained herein. The views and opinions of individuals do not necessarily represent those of the United States Government. This report is intended to be distributed in its entirety and its use is unlimited. Reproduction and distribution of this report is unlimited. This report and the information contained herein are not to be used for advertising or promotional purposes, for creating new publicity for a product, or for promoting a service. This report and the information contained herein are not to be used for advertising or promotional purposes, for creating new publicity for a product, or for promoting a service. This report and the information contained herein are not to be used for advertising or promotional purposes, for creating new publicity for a product, or for promoting a service.

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

REGULATORY DOCKET FILE COPY

DEADLINE RETURN DATE _____

RECORDS FACILITY BRANCH

TECHNICAL EVALUATION REPORT

REVIEW OF LICENSEES' RESOLUTION OF OUTSTANDING ISSUES FROM NRC EQUIPMENT ENVIRONMENTAL QUALIFICATION SAFETY EVALUATION REPORTS (F-11 and B-60)

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT 1

VOL. 2 OF 2

NRC DOCKET NO. 50-280

FRC PROJECT C5257

NRC TAC NO. 42468

FRC ASSIGNMENT 13

NRC CONTRACT NO. NRC-03-79-118

FRC TASK 482

Prepared by

Franklin Research Center
20th and Race Streets
Philadelphia, PA 19103

FRC Group Leader: G. J. Toman

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

Lead NRC Engineer: P. Shemanski

December 21, 1982

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Reviewed by:


Group Leader

Approved by:


Project Manager


Department Director



Franklin Research Center

A Division of The Franklin Institute

The Benjamin Franklin Parkway, Phila., Pa. 19103 (215) 448-1000



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 58

EQUIPMENT ITEM NO. 58
 ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 GENERAL ELECTRIC, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 58
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CHARGING PUMP COOLING (1-CC-P-2A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-61, -62

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), (T), (QT), RT, (P), (H), CS, (A), S, (R), M, I, QM, (RPN), EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 5

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (~~has~~/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action to begin" last quarter of '82.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 58

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 58

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 58

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.7 General Electric Corporation (Charging Pump Component Cooling Water Pumps)

PLANT ID NO. WORKSHEET PAGE NO.

1-CC-P-2A	6-61
1-CC-P-2B	6-62

7.2.7.1 Modification/Replacement Status

We will replace the charging pump component cooling water pump motors with qualified replacement units.

7.2.7.2 Modification/Replacement Schedule

Based on current projections for purchase order placement, material delivery and our present outage schedule, replacement is scheduled to start during the last quarter of 1982.

7.2.7.3 Justification For Continued Operation

The charging pump component cooling water pumps provide seal and cooling water for the mechanical seals of the charging pumps during their operation. In the event of a cooling water pump failure, the manufacturer has determined that the water reservoir surrounding the charging pump mechanical seals should provide a sufficient buffer to extend the operation of the pumps for approximately one (1) hour. Further, since during the use of the charging pumps in its safety injection mode, it is handling cold water from the refueling water storage tank, which will minimize the heat load for the charging cooling system.

On the basis of the above, it is concluded that the component cooling water pumps will perform their intended safety function, and will have no impact on plant safety



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 402

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 59

EQUIPMENT ITEM NO. 59
 ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 59
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP MOTOR (1-CV-P-1B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-79, -78

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), T, (QT), RT, P, H, CS, (A), S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 59

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | <u>III.a</u> Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 5

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 59

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- X (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 5

LICENSEE RESPONSE TO NRC SER (Continued)

7.3.7 Containment Vacuum Pump Motors

1-CV-P-1A

1-CV-P-1B

These pumps are not required to function after a containment isolation signal is received. By design the containment pressure will return to sub-atmospheric conditions within an hour after an LOCA and remain sub-atmospheric for 30 days without mechanical removal of air during that time.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 59

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/~~non-concurrence~~ with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)

Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIb)

Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

Reason for Non-Concurrence

Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.

Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.

Backup (equipment/system) is subject to a potentially disabling single active failure.

Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.

Failure of the primary equipment can result in erroneous indication which could mislead an operator.

Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila.. Pa 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

EQUIPMENT ITEM NO. 60
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
 (AB-2B)
 LIMITORQUE MODEL SMBO WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 60
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): BORIC ACID INJECTION TANK OUTLET VALVE (MOV-1842)
 LICENSEE SUBMITTAL: SCEW(S): 6-200

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3e, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| <u>I.a</u> Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW

Criteria: DOR Guidelines X; NUREG-0588, Cat. I ; NUREG-0588, Cat. II .

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
--------------------------------------------------------------------	-----------------------	--------------------------------	----------------------------------

EQUIPMENT DESCRIPTION

Equipment Type	MVA	Motorized Valve Actuator	
Manufacturer's Name (5.2.2/-/-)	LIMITORQUE	Limatorque	
Model Number (5.2.2/-/-)	SMB; Various Sizes	SMB-0	
Serial Number	NOTE 1	195004	NOTE 1
Features/Mounting (5.2.6/-/-)	See Pg. 1a and NOTE 2	Reliance AC Motor Class B Insulation also Electric Apparatus Motor with Class B Insulation	NOTE 2,7 NOTE 3
Connections/Interfaces (5.2.6/-/-)	NOTE 3	Not Stated	
Location/Elevation	See Pg. 1a	Not Applicable	
Equipment ID No.	See Pg. 1a	Not Applicable	

QUALIFICATION REPORT

(8.0/5.0/5.0)			
Report ID Number	—	B0003	
Report Date	—	June 1976	
Issued by	—	Limatorque Corporation	
Prepared for	—	Limatorque	
Referenced Reports	—	Not Stated	
Qualification Method (5.1, 5.3/2.1, 2.4/2.1, 2.4)	—	Sequential Test	

QUALIFICATION TEST PROGRAM

Functional Test Description (5.2.5/2.2.9/2.2.9)	—	Cycling/Insulation Resistance	
Operating Conditions (-/2.2.10/2.2.10) Load/Cycles/Voltage/ Current/Freq.	NOTE 4	Not Applicable	NOTE 4



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Acceptance Criteria (5.2.5/2.2.1/2.2.1)	—	Not Stated	
Accuracy (5.2.5/-/-)	—	Not Applicable	
Number of Specimens	—	1 Actuator + 2 Motors	
Test Instruments Calibrated	—	Yes	
Safety Function (Active/ Passive) (-/2.1.3/2.1.3)	ACTIVE	Not Applicable	
Test Duration (5.2.1/-/-)	—	16 Days	} NOTE 5
Accident Duration (Envir. Above Normal) (5.2.1/-/-)	1 hour	Not Applicable	
Required Function Time	See Pg. 1a	Not Applicable	
Test Sequence (General) (5.2.3/2.3.1/2.3.1)	—	Thermal Aging Mechanical Cycling Radiation Exposure Seismic Aging LOCA Simulation	
Test Sequence (NUREG-0588, Cat. I) (-/2.3.1/-)	—		
1. Representative Sample 2. Baseline Data 3. Performance Extremes 4. Thermal Aging 5. Radiation Aging 6. Wear Aging 7. Vibration/Seismic 8. DBE Exposure 9. Post-DBE Exposure 10. Inspection	—	Not Applicable	
Aging (5.2.4, 7.0/4.0/4.0) Thermal Aging/Basis	120°F for 40 years (Design)	(B0058 provides data on epoxy life) 199.8 hrs @ 165°F/100%RH	} NOTE 6
Material Aging Evaluation (7.0/-/-)	NOTE 6	Not Applicable	
Materials Susceptible (Thermal) (5.2.4, 7.0/-/-)	—	Not Stated	
Radiation Aging, Type	GAMMA	Gamma	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Radiation Aging, Dose (rd)	2.5E06 rd (max.) see SCEM for exact value	See Accident Dose	
Radiation Aging, Dose Rate		See Accident Dose	
Radiation Aging, Method	—	Test	
Materials Susceptible (Radiation) (5.2.4, 7.0/-/-)	—	Not Stated	
Operational Aging (-/4.2/-)	—	2000 cycles at rated Load	
Other Age Conditioning (-/4.2/-)	—	Seismic	
Qualified Life Claimed/ Established (5.2.4/4.10/-)	40 years/ 40 years	40 Years outside containment	NOTE 6
Normal Ambient Temperature	120°F.	Not Applicable	
Normal Ambient Radiation**	7.1 rd/hr	Not Applicable	
Normal Ambient Humidity *	20-90%	Not Applicable	
On-Going Surveillance and Preventive Maintenance (7.0/-/-)	yes	Not Applicable	
On-Going Analysis of Failures and Degradation (7.0/-/-)	yes	Not Applicable	
Margin (General) (6.0/3.0/3.0)	—	Not Stated	
Margin (NUREG-0588, Cat. I) (-/3.2/-)	—	Not Applicable	
1. Temperature (+15°F)			
2. Pressure (+10%, 10 psig max)			
3. Radiation (not required)			
4. Time (+10%, +1 hour + function time minimum)			

* ASSUMED BY FRC

** $(2.5E06 \text{ RD} / (40 \text{ y}) \times \frac{365 \text{ d}}{\text{y}} \times \frac{24 \text{ h}}{\text{d}}) = 7.1 \text{ R/hr}$



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 5d

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>ACCIDENT CONDITIONS</u>			
LOCA/MSLB/HELB/Uncontrolled (4.1, 4.2, 4.3.1, 4.3.3/ 1.1, 1.2, 1.5/1.1, 1.2, 1.5)	MSLB	LOCA/HELB outside Containment	
Radiation Type	GAMMA	Gamma	
Radiation Dose (rd) (4.1.2/1.4/1.4)	8.0E06rd (max.) See SCEW for exact value	2x10 ⁷ (Complete Actuator) 2.04x10 ⁸ (2 Motors)	
Radiation Dose Rate (rd/hr)	—	1 Mrd/hr	
Radiation Qual. Method (5.3.1/-/-)	—	test	
Proximity to Concentrated Radiation (4.1.2/1.4.6/1.4.6)	—	Not Applicable	
Equipment Susceptible to Beta Radiation (4.1.2/-/-)	NO	No	
Radiation Dose (Normal + Accident) (4.1.2/-/-)	1.08E07rd (max.) see SCEW for exact value	Not Applicable	
Plateout Dose Considered (-/1.48/1.48)	—	Not Applicable	
Gamma + Beta Dose (rd) (4.1.2/1.4.7/1.4.7)	—	Not Applicable	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE No.)
<u>ENVIRONMENTAL PROFILE</u> *, * <u>OF ACCIDENT CONDITIONS</u>			
Rate of Temp./Press. Increase	2.8°F/sec 0.5 psig/min	13°F, 2.5psi/sec	
Peak: °F/psig/RH/Time	205/15.2/100 1000 sec	250/25/100/24 hrs	
Increase To: °F/psig/RH/Time	160/14.9/100 14 min	200/10/100/15 days	
Decrease To: °F/psig/RH/Time	120/14.9/100		
Decrease To: °F/psig/RH/Time	1 hour		
Equipment Surface Tempera- ture (MSLB) (-/1.2.5.C, 2.2.6/1.2.5.C, 2.2.6)	—	Not Applicable	
Spray Qualification Method (5.3.2/1.3, 2.2.8/1.3, 2.2.8)	N/A	Not Applicable Outside Containment application	
Spray Composition (4.1.4/1.3, 2.2.8/ 1.3, 2.2.8)	↓	Not Applicable	
Spray Density (gpm/ft ²)	↓	Not Applicable	
Spray Duration	↓	Not Applicable	
Submergence Duration (4.1.3/2.2.5/2.2.5)	NOT REQUIRED	Not Applicable	
In-Leakage Considered (5.2.6, 5.3.2/-/-)	↓	Not Stated but none apparent in photographs	
Time to Submergence	↓	Not Applicable	
Dust Environment (-/2.2.11/2.2.11)	—	Not Applicable	

* enveloping profile for comparison
* maximum outside containment values



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NOTES:

1. Serial numbers are provided in PSR # 27 on the "walk-down" sheets
2. For most motorized valve actuators (MVAs) The motor manufacturer, class of insulation and whether or not the MVA has a motor-brake assembly has been identified in PSR #27 and on the SCEW(s)
3. The component interfaces (i.e. motor leads, splices) are not considered part of the MVA by the licensee, but will be addressed separately.
4. The nameplate operating conditions for the MVA (and brakes where applicable) are provided in PSR #27 on the "walk-down" sheets.
5. For the equipment located outside containment, a required operating time of 120 days is specified. The test lasted only 16 days. PSR # 27 has attempted to extrapolate the qualified duration by using the Arrhenius technique and the elevated, saturated steam conditions reported in PGR #662 (B0003). The following



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NOTES:

is noted with respect to this application of the Arrhenius technique.

The thermal aging analyses presented for this facility have attempted to extrapolate test data obtained from saturated steam tests using the Arrhenius technique to extend qualified duration or calculate qualified life estimates. The assumption used in justifying this procedure is that the thermal degradation during the environmental test is greater than that accumulated during the postulated accident conditions. What the analyses have failed to recognize is the fact that the Arrhenius methodology is a theoretical relationship which attempts to predict how reaction rates vary with respect to increases in temperature. This technique is based on the premise that all organic materials degrade to some extent--primarily by oxidation--when exposed to elevated temperatures in the presence of air. The saturated steam tests, as a matter of procedure, purge the air from the test chamber prior to the onset of the environmental test. Therefore, the use of saturated steam, or superheated steam for that matter, in conjunction with the Arrhenius technique is not technically justified as an aging procedure. In addition, the Arrhenius technique does not take into account variations in the reaction rates due to changes in pressure (as would be experienced in a LOCA/MSLB/HELB test), nor does it account for possible anomalies due to the presence of moisture in the chamber atmosphere. The application of the Arrhenius methodology is limited to data obtained from air-oven thermal aging tests (minimum of three tests at different times and temperatures) where the only parameter affecting the reaction rate is temperature. Any application of this technique to thermodynamically different systems must be technically justified with valid analytical procedures.

Though the licensee has not provided this technical basis, it is noted that the MVA tested showed no indication that exposure to continued post-accident conditions would result in a failure of



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

NOTES:

The device. As such, This MVA is considered qualified for the specified operating time.

6. Thermal aging has been addressed in the BOP58 report for the motor insulation and is acceptable. The licensee has also addressed seals, gaskets (Not required for absolute sealing), & lubricants. The limit and torque switches are generally made of a phenolic material and would generally not experience significant thermal degradation. The licensee has also stated that the interfaces will be address as separate items. The licensee should be aware that Teflon is used in many motor leads as insulation and is susceptible to thermal and radiation degradation. The licensee has also addressed terminal strips (Blocks) and connectors in their review. All information reviewed is acceptable.

7. The difference in motor manufacturers has been adequately addressed.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

EQUIPMENT ITEM NO. 61

MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)

LIMITORQUE MODEL SMB WITH CLASS B INSULATION; SIZES 00, 000 WITH MOTOR-BRAKE ASSEMBLY

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 61

LICENSEE REFERENCE(S): 662, 659, 27

FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM REFUELING WATER STORAGE TANK (MOV-1115D)

LICENSEE SUBMITTAL: SCEW(S): 6-15

FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM VOLUME CONTROL TANK (MOV-1115B)

LICENSEE SUBMITTAL: SCEW(S): 6-13

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (REPLACE BRAKE/MODIFY MVA)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 821231 (last quarter 1982).)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b Modification</u> | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	_____
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	<u> X </u>
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u> X </u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- X (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2 Motor Operators With Brakes

WORKSHEET PAGE NO.

MOV-1890A	6-215
MOV-1890B	6-216
MOV-1890C	6-217
MOV-1115B	6-13
MOV-1115D	6-15
MOV-1863A	6-205
MOV-1863B	6-206
MOV-1864A	6-228
MOV-1864B	6-229

7.2.8.2.1 Modification/Replacement Status

The valves listed above are addressed by Franklin Institute Research Laboratories Report F-C3271, which does not include radiation data. If the brakes are removed, the vendor has informed us that the valves will be qualified by their Qualification Report B0003. Therefore, the brakes will be removed from the motor operated valves.

7.2.8.2.2 Modification Replacement Schedule

VEPCO is currently reviewing two methods of qualification. One requires modification to the existing valve and the other requires complete actuator replacement. Our current projections indicate that if complete replacement is required, material availability will allow replacement to start during the last quarter of 1982.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 61

LICENSEE RESPONSE TO NRC SER. (Continued)

7.2.8.2.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by test and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB. Also no failures of any significance were experienced during these tests to indicate a potential for common mode failures. In these tests, the valve actuators included motor brakes that are similar in construction to those used in the Surry design. These tests included multicycle open/close operation prior to, during, and after entire DBA test sequence. The motor brakes performed satisfactorily in each of the eleven operational cycles throughout the program's six days of test duration. These tests, however, did not include irradiation. Since these actuators are located outside the containment, the normal operating radiation dose to these actuators is minimal. These actuators are accessible for frequent inspections, tests, and maintenance. Further, even during post DBA/HELB conditions, these valves can be operated using manual handwheels independent of the brakes.

On the basis of the above it is concluded that continued plant operation in the interim with these equipment lacking substantiation of their environmental qualification will have little or no impact on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

EQUIPMENT ITEM NO. 62
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMB1 WITH MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 62
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION DISCHARGE VALVE (MOV-1864B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-229, -228

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, (QI) RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is ~~qualified and/or~~ will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (REPLACE BRAKE / MODIFY MVA)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 021231 (last quarter 1982).)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| <u>I.a</u> Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied X _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2 Motor Operators With Brakes

WORKSHEET PAGE NO.

MOV-1890A	6-215
MOV-1890B	6-216
MOV-1890C	6-217
MOV-1115B	6-13
MOV-1115D	6-15
MOV-1863A	6-205
MOV-1863B	6-206
MOV-1864A	6-228
MOV-1864B	6-229

7.2.8.2.1 Modification/Replacement Status

The valves listed above are addressed by Franklin Institute Research Laboratories Report F-C3271, which does not include radiation data. If the brakes are removed, the vendor has informed us that the valves will be qualified by their Qualification Report B0003. Therefore, the brakes will be removed from the motor operated valves.

7.2.8.2.2 Modification Replacement Schedule

VEPCO is currently reviewing two methods of qualification. One requires modification to the existing valve and the other requires complete actuator replacement. Our current projections indicate that if complete replacement is required, material availability will allow replacement to start during the last quarter of 1982.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 62

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by test and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB. Also no failures of any significance were experienced during these tests to indicate a potential for common mode failures. In these tests, the valve actuators included motor brakes that are similar in construction to those used in the Surry design. These tests included multicycle open/close operation prior to, during, and after entire DBA test sequence. The motor brakes performed satisfactorily in each of the eleven operational cycles throughout the program's six days of test duration. These tests, however, did not include irradiation. Since these actuators are located outside the containment, the normal operating radiation dose to these actuators is minimal. These actuators are accessible for frequent inspections, tests, and maintenance. Further, even during post DBA/HELB conditions, these valves can be operated using manual handwheels independent of the brakes.

On the basis of the above it is concluded that continued plant operation in the interim with these equipment lacking substantiation of their environmental qualification will have little or no impact on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

EQUIPMENT ITEM NO. 63
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMB2 WITH CLASS B INSULATION; MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 63
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION STOP VALVE (MOV-1890A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-215 TO -217

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is ~~qualified and/or~~ will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (Replace Brake/Modify MVA)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 021231 (last quarter 1982).)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------------------------|---------------------------------------------------------|
| <input checked="" type="checkbox"/> I.a Qualified | <input type="checkbox"/> II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | <input type="checkbox"/> III.a Exempt |
| <input type="checkbox"/> II.a Qualification Not Established | <input type="checkbox"/> III.b Not in Scope |
| <input type="checkbox"/> II.b Not Qualified | <input type="checkbox"/> IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

Documented Evidence of Qualification Adequate	_____
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	<u> X </u>
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u> X </u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2 Motor Operators With Brakes

WORKSHEET PAGE NO.

MOV-1890A	6-215
MOV-1890B	6-216
MOV-1890C	6-217
MOV-1115B	6-13
MOV-1115D	6-15
MOV-1863A	6-205
MOV-1863B	6-206
MOV-1864A	6-228
MOV-1864B	6-229

7.2.8.2.1 Modification/Replacement Status

The valves listed above are addressed by Franklin Institute Research Laboratories Report F-C3271, which does not include radiation data. If the brakes are removed, the vendor has informed us that the valves will be qualified by their Qualification Report B0003. Therefore, the brakes will be removed from the motor operated valves.

7.2.8.2.2 Modification Replacement Schedule

VEPCO is currently reviewing two methods of qualification. One requires modification to the existing valve and the other requires complete actuator replacement. Our current projections indicate that if complete replacement is required, material availability will allow replacement to start during the last quarter of 1982.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 63

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by test and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB. Also no failures of any significance were experienced during these tests to indicate a potential for common mode failures. In these tests, the valve actuators included motor brakes that are similar in construction to those used in the Surry design. These tests included multicycle open/close operation prior to, during, and after entire DBA test sequence. The motor brakes performed satisfactorily in each of the eleven operational cycles throughout the program's six days of test duration. These tests, however, did not include irradiation. Since these actuators are located outside the containment, the normal operating radiation dose to these actuators is minimal. These actuators are accessible for frequent inspections, tests, and maintenance. Further, even during post DBA/HELB conditions, these valves can be operated using manual handwheels independent of the brakes.

On the basis of the above it is concluded that continued plant operation in the interim with these equipment lacking substantiation of their environmental qualification will have little or no impact on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 64

EQUIPMENT ITEM NO. 64
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP
 CUBICLE (AB-2C)
 LIMITORQUE MODEL WITH PEERLESS MOTOR CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 64
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE
 TANK (MOV-1275A)
 LICENSEE SUBMITTAL: SCEW(S): 6-2

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 64

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| <input checked="" type="checkbox"/> I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 60

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 64

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

EQUIPMENT ITEM NO. 65
 MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL,
 SUBMERGED (RC-3A)
 LIMITORQUE, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 65
 LICENSEE REFERENCE(S): 43
 FUNCTION (PLANT ID): ACCUMULATOR ISOLATION (MOV-1865A TO 1865C)
 LICENSEE SUBMITTAL: SCEW(S): 6-207 TO -209

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, (QT), RT, (P), H, (CS), (A), S, (R), M, I, QM, RPN, EXN, SEN, (QI), RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3e, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____ **X**
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

Refer to pages 4a & b for evaluation



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482/483

Page
3b

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

LICENSEE RESPONSE TO NRC SER (Continued)

7.3.9 Motor Operated Valves (Safety Injection)

MOV-1865A
MOV-1865B
MOV-1865C

These valves serve to isolate the safety injection accumulator tanks during refueling. They are administratively locked open for critical operations by locking out the breakers that supply power to these valves. Thus, the valves will remain in their required open position to mitigate an LOCA or MSLB.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/~~non-concurrence~~ with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

- Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)
- Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIb)
- Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

Reason for Non-Concurrence

- Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.
- Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.
- Backup (equipment/system) is subject to a potentially disabling single active failure.
- Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.
- Failure of the primary equipment can result in erroneous indication which could mislead an operator.
- Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 65

Reason for Concurrence

The equipment's accident mitigating function is completed prior to the onset of the hostile environment. No subsequent functions are necessary. See note (1) below. (NRC Qualification Evaluation Category IIIb)

Other (see page)

Resultant NRC Qualification Evaluation Category (IIIa/~~IIIb~~)

Note 1: The Licensee (has/has not) stated that failure of the primary equipment will not affect other safety-related equipment or cause an operator to be misled. (See page)

Reason for Non-Concurrence

Although backup equipment is available, it is not technically sound to relinquish defense-in-depth for this function.

Backup (equipment/system) is not safety-related.

This equipment is necessary for the operator to ensure an ESF system is performing its intended safety function.

The rationale presented by the Licensee is not supported by objective technical evidence.

Other (see page)

LICENSEE STATEMENT

^b
 See page 3~~7~~ of this checksheet.

EVALUATION OF LICENSEE STATEMENT

These valves are locked in their required accident mitigating position with the power removed (breaker locked open). These valves are exempt from qualification



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 66

EQUIPMENT ITEM NO. 66
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SM800 WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 66
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION SUCTION (MOV-1862B)
 LICENSEE SUBMITTAL: SCEW(S): 6-204
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION SUCTION FROM REFUELING WATER STORAGE TANK (MOV-1862A)
 LICENSEE SUBMITTAL: SCEW(S): 6-203
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION PUMP RECIRCULATION (MOV-1885A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-230C, B, A
 FUNCTION (PLANT ID): RECIRCULATION SPRAY PUMP SUCTION (MOV-RS-156A, B; -155A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-158 TO -161

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

MOV-1885A,B,C only

(R), T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, (QI) RPS, None,

Not stated, Not applicable

Not for MOV-RS-156 A,B

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 9

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 66

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
(If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 6

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 67

EQUIPMENT ITEM NO. 67
MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
(AB-2B)
LIMITORQUE MODEL SMBOO
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 67
LICENSEE REFERENCE(S): 662, 659, 27
FUNCTION (PLANT ID): BORON INJECTION TANK BYPASS (MOV-1869B)
LICENSEE SUBMITTAL: SCEW(S): 6-230
FUNCTION (PLANT ID): SAFETY INJECTION TO REACTOR HOT LEG ISOLATION (MOV-1869A)
LICENSEE SUBMITTAL: SCEW(S): 6-214
FUNCTION (PLANT ID): BORON INJECTION TANK OUTLET ISOLATION (MOV-1867D)
LICENSEE SUBMITTAL: SCEW(S): 6-213
FUNCTION (PLANT ID): BORIC ACID INJECTION TANK OUTLET VALVE (MOV-1867C)
LICENSEE SUBMITTAL: SCEW(S): 6-212
FUNCTION (PLANT ID): BORIC ACID INJECTION TANK VALVE (MOV-1867A)
LICENSEE SUBMITTAL: SCEW(S): 6-210
FUNCTION (PLANT ID): CHARGING TO REGENERATIVE HEAT EXCHANGER STOP VALVE
(MOV-1289A)
LICENSEE SUBMITTAL: SCEW(S): 6-17
FUNCTION (PLANT ID): CHARGING HEADER PENETRATION AREA (MOV-1289B)
LICENSEE SUBMITTAL: SCEW(S): 6-18
FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE
TANK HEADER ISOLATION (MOV-1373)
LICENSEE SUBMITTAL: SCEW(S): 6-5

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
(See Section 3 of this TER for Legend)

(R)⁺ (T)^{*} (QT)¹ RT, (P)^{*} (H)^{*} CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, (QI)⁺ RPS, None,

Not stated, Not applicable

+ MOV-1867A, -1869B, and -1373 only

LISTING OF APPLICABLE CHECKSHEETS:

* MOV-1373 only

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 67

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 67

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	_____
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	<u>X</u>
I.b	Equipment Qualification Pending Modification	_____
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 6

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

EQUIPMENT ITEM NO. 68
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 LIMITORQUE MODEL SM800 WITH CLASS B INSULATION; MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 68
 LICENSEE REFERENCE(S): 662; 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION DISCHARGE (MOV-1863A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-205, -206

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is ~~qualified and/or~~ will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (Replace Brake/Modify MVA)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 821231 (last quarter 1982).)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

Documented Evidence of Qualification Adequate	_____
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____ X
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	_____ X
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2 Motor Operators With Brakes

WORKSHEET PAGE NO.

MOV-1890A	6-215
MOV-1890B	6-216
MOV-1890C	6-217
MOV-1115B	6-13
MOV-1115D	6-15
MOV-1863A	6-205
MOV-1863B	6-206
MOV-1864A	6-228
MOV-1864B	6-229

7.2.8.2.1 Modification/Replacement Status

The valves listed above are addressed by Franklin Institute Research Laboratories Report F-C3271, which does not include radiation data. If the brakes are removed, the vendor has informed us that the valves will be qualified by their Qualification Report B0003. Therefore, the brakes will be removed from the motor operated valves.

7.2.8.2.2 Modification Replacement Schedule

VEPCO is currently reviewing two methods of qualification. One requires modification to the existing valve and the other requires complete actuator replacement. Our current projections indicate that if complete replacement is required, material availability will allow replacement to start during the last quarter of 1982.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 68

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.2.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by test and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB. Also no failures of any significance were experienced during these tests to indicate a potential for common mode failures. In these tests, the valve actuators included motor brakes that are similar in construction to those used in the Surry design. These tests included multicycle open/close operation prior to, during, and after entire DBA test sequence. The motor brakes performed satisfactorily in each of the eleven operational cycles throughout the program's six days of test duration. These tests, however, did not include irradiation. Since these actuators are located outside the containment, the normal operating radiation dose to these actuators is minimal. These actuators are accessible for frequent inspections, tests, and maintenance. Further, even during post DBA/HELB conditions, these valves can be operated using manual handwheels independent of the brakes.

On the basis of the above it is concluded that continued plant operation in the interim with these equipment lacking substantiation of their environmental qualification will have little or no impact on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

EQUIPMENT ITEM NO. 69
 MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
 LIMITORQUE MODEL SMB000
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 69
 LICENSEE REFERENCE(S): 659, 706, 43
 FUNCTION (PLANT ID): PRESSURIZER RELIEF BLOCK VALVE (MOV-1535, -1536)
 LICENSEE SUBMITTAL: SCEW(S): 6-196, -197

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (QT) RT, (P), (H), (CS) (A) S, (R), M, I, QM, RPN, EXN, SEN, (QI) RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 821231 (last quarter of 1982).)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established
- Aging Degradation Evaluated Adequately
- Qualified Life or Replacement Schedule Established (If Required)
- Program Established to Identify Aging Degradation
- Criteria Regarding Aging Simulation Satisfied (If Required)
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate
 - o Peak Pressure Adequate
 - o Duration Adequate
 - o Required Profile Enveloped Adequately
 - o Steam Exposure (If Required) Adequate
- Criteria Regarding Spray Satisfied
- Criteria Regarding Submergence Satisfied
- Criteria Regarding Radiation Satisfied
- Criteria Regarding Test Sequence Satisfied
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied
- Criteria Regarding Functional Testing Satisfied
- Criteria Regarding Instrument Accuracy Satisfied
- Test Duration Margin (1 hour + Function Time) Satisfied
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established
- II.b Equipment Not Qualified
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified
- III.a Equipment Exempt From Qualification
- III.b Equipment Not in the Scope of the Qualification Review
- IV Documentation Not Made Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8 Limitorque (Motor Operated Valve Actuators)

7.2.8.1 Motor Operators Without Brakes

PLANT ID NO.	WORKSHEET PAGE NO.
MOV-FW151A	6-96
MOV-FW151B	6-97
MOV-FW151C	6-98
MOV-FW151D	6-99
MOV-FW151E	6-100
MOV-FW151F	6-101
MOV-1535	6-196
MOV-1536	6-197

7.2.8.1.1 Modification/Replacement Status

Additional vendor qualification documentation comprised of a listing of the special operator features (e.g., actuator motor, limit switch and torque switches, insulating and housing materials, splices, etc., used in the various vendor qualification tests was received. For each MOV with incomplete qualification data, we conducted a field inspection to determine the existence of any unqualified components. We will replace all unqualified parts with qualified

7.2.8.1.2 Modification/Replacement Schedule

ones.
 Based on current projections for purchase order placement, material delivery and our present outage schedule, these modifications are scheduled to start during the last quarter of 1982.



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
3c

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8.1.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by testing and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB.

Also, no failure of any significance were experienced during these tests to indicate a potential for common mode failures. On this basis, it is concluded that continued operation of Surry Units in the interim with this equipment, albeit incomplete in qualification documentation, will have little or no effect on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW

Criteria: DOR Guidelines X; NUREG-0588, Cat. I ; NUREG-0588, Cat. II .

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>EQUIPMENT DESCRIPTION</u>			
Equipment Type	MVA	MOTORIZED VALVE ACTUATOR	
Manufacturer's Name (5.2.2/-/-)	Limitorque	LIMITORQUE	
Model Number (5.2.2/-/-)	SMB; Various sizes	SMB-0	
Serial Number	NOTE 1	189835(O/N 600456-A)	NOTE 1
Features/Mounting (5.2.6/-/-)	NOTE 2	RELIANCE CLASS RH INSUL. MOTOR, ID# 2Y267074A1EZ, TYPE P	NOTE 2, 7
Connections/Interfaces (5.2.6/-/-)	NOTE 3	CONTROL & POWER LEADS THRU FLEXIBLE, PRESSURE- TIGHT CONDUIT	NOTE 3
Location/Elevation	See Pg. 1a	AUTOCLAVE	
Equipment ID No.	See Pg. 1a	—	
<u>QUALIFICATION REPORT</u> (8.0/5.0/5.0)			
Report ID Number	—	600456 (with B-0058)	
Report Date	—	751201	
Issued by	—	LIMITORQUE	
Prepared for	—	LIMITORQUE	
Referenced Reports	—	LOCKHEED 352J-4811	
Qualification Method (5.1, 5.3/2.1, 2.4/2.1, 2.4)	—	SIMULTANEOUS AND SEQUENTIAL TEST	
<u>QUALIFICATION TEST PROGRAM</u>			
Functional Test Description (5.2.5/2.2.9/2.2.9)	—	VALVE ACTUATION AND IR MEASUREMENTS	
Operating Conditions (-/2.2.10/2.2.10) Load/Cycles/Voltage/ Current/Freq.	NOTE 4	40 ft-#/460 Volts/60 Hz	NOTE 4



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 6

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Acceptance Criteria (5.2.5/2.2.1/2.2.1)	—	SUCCESSFUL OPERATION OF THE MVA	
Accuracy (5.2.5/-/-)	—	—	
Number of Specimens	—	1 COMPLETE MVA AND 1 ADDITIONAL MOTOR	
Test Instruments Calibrated	—	YES	
Safety Function (Active/ Passive) (-/2.1.3/2.1.3)	ACTIVE	—	
Test Duration (5.2.1/-/-)	—	30 DAYS	} NOTE 5
Accident Duration (Envir. Above Normal) (5.2.1/-/-)	48 hrs.	—	
Required Function Time	120 Days	—	
Test Sequence (General) (5.2.3/2.3.1/2.3.1)	—	—	
Test Sequence (NUREG-0588, Cat. I) (-/2.3.1/-)	—	—	
1. Representative Sample	/	—	
2. Baseline Data		—	
3. Performance Extremes		—	
4. Thermal Aging		YES	
5. Radiation Aging		YES	
6. Wear Aging		YES	
7. Vibration/Seismic		YES	
8. DBE Exposure		YES	
9. Post-DBE Exposure		YES	
10. Inspection		YES	
Aging (5.2.4, 7.0/4.0/4.0) Thermal Aging/Basis	120°F for 40 years	100 HOURS @ 180 C FOR THE MOTOR STATORS <u>ONLY</u>	NOTE 6
Material Aging Evaluation (7.0/-/-)	NOTE 6	NO	
Materials Susceptible (Thermal) (5.2.4, 7.0/-/-)	—	NOT STATED	
Radiation Aging, Type	GAMMA	GAMMA	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Radiation Aging, Dose (rd)	1.3E07 rd	4 Mrd (COMPLETE UNIT)	
Radiation Aging, Dose Rate	—	1 Mrd/Hr	
Radiation Aging, Method	—	TEST (SEQUENTIAL)	
Materials Susceptible (Radiation) (5.2.4, 7.0/-/-)	—	NOT STATED	
Operational Aging (-/4.2/-)	—	1208 OPEN/CLOSE CYCLES+ 803 (LOCA+POST-LOCA) CYCLES + 2184 CYCLES OF MVA WITH BASE TEST MOTOR INSTALLED	
Other Age Conditioning (-/4.2/-)	—	SEISMIC/VIBRATIONAL	
Qualified Life Claimed/ Established (5.2.4/4.10/-)	40 years/ None	NONE	
Normal Ambient Temperature	120° F	—	
Normal Ambient Radiation*	37.1 R/hr	—	
Normal Ambient Humidity**	20-90%	—	
On-Going Surveillance and Preventive Maintenance (7.0/-/-)	yes	—	
On-Going Analysis of Failures and Degradation (7.0/-/-)	yes	—	
Margin (General) (6.0/3.0/3.0)	—	—	
Margin (NUREG-0588, Cat. I) (-/3.2/-)	/	NOT STATED, EXCEPT FOR	
1. Temperature (+15°F)		THE POST-LOCA ADDITIONAL	
2. Pressure (+10%, 10 psig max)		MVA CYCLING	
3. Radiation (not required)		—	
4. Time (+10%, +1 hour + function time minimum)		—	

* $(1.3E07 \text{ rd}) \left(\frac{1 \text{ yr}}{8760 \text{ hr}} \right) = 37.1 \text{ R/HR}$

** assumed by FRC



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 5d

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 6

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>ACCIDENT CONDITIONS</u>			
LOCA/MSLB/HELB/Uncontrolled (4.1, 4.2, 4.3.1, 4.3.3/ 1.1, 1.2, 1.5/1.1, 1.2, 1.5)	LOCA	LOCA	
Radiation Type	GAMMA	GAMMA	
Radiation Dose (rd) (4.1.2/1.4/1.4)	2.4E07rd	200 Mrd	
Radiation Dose Rate (rd/hr) Radiation Qual. Method (5.3.1/-/-)	—	1 Mrd/Hr TEST	
Proximity to Concentrated Radiation (4.1.2/1.4.6/1.4.6)	NOT STATED	—	
Equipment Susceptible to Beta Radiation (4.1.2/-/-)	No	—	
Radiation Dose (Normal + Accident) (4.1.2/-/-)	3.7E07rd	204 Mrd TOTAL DOSE	
Plateout Dose Considered (-/1.48/1.48)	—	—	
Gamma + Beta Dose (rd) (4.1.2/1.4.7/1.4.7)	3.7E07rd	—	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE No.)
<u>ENVIRONMENTAL PROFILE OF ACCIDENT CONDITIONS</u>			
Rate of Temp./Press. Increase	26.7 °F/sec; 7.5 psig/sec	10F/SEC., 2.5 psig/SEC.	
Peak: °F/psig/RH/Time	280/45/100/ 30 min	310/78/100/30 min.	2 PEAKS
Drop Decrease To: °F/psig/RH/Time	280 → 150/45 → 0/ 100/30 → 1 hr.	255/30/100/91 hours	
Drop Decrease To: °F/psig/RH/Time	150 → 120/0/100/ 1 hr → 48 hrs	195/10/100/623 hours	
Decrease To: °F/psig/RH/Time	120/0/100/ > 48 hrs	COOL TO AMBIENT	
Equipment Surface Tempera- ture (MSLB) (-/1.2.5.C, 2.6/1.2.5.C, 2.2.6)	—	—	
Spray Qualification Method (5.3.2/1.3, 2.2.8/1.3, 2.2.8)	—	TEST PER IEEE-323-1974	
Spray Composition (4.1.4/1.3, 2.2.8/ 1.3, 2.2.8)	H ₃ BO ₃ (2000 - 2200 ppm B), NaOH, 8.5-11 pH	3000 PPM BORON(0.28 molar H ₃ BO ₃), 0.064 molar Na ₂ S ₂ O ₃ NaOH to pH of 10.5 @ 77F	
Spray Density (gpm/ft ²)	NOT STATED	1.2 gpm	
Spray Duration	0-4 hrs	24 hours (ASSUMED).	
Submergence Duration (4.1.3/2.2.5/2.2.5)	NONE	—	
In-Leakage Considered (5.2.6, 5.3.2/-/-)	↓	—	
Time to Submergence	↓	—	
Dust Environment (-/2.2.11/2.2.11)	—	—	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NOTES:

1. The serial numbers are provided in PSR # 43 on the "walk down" sheets
2. For most motorized valve actuators (MVA's) The motor manufacturer, class of insulation and whether or not the MVA contains a motor-brake assembly has been identified in PSR #43 and on the SCEWs
3. The component interfaces (i.e. motor leads, splices) are not considered part of the MVA by the licensee and will be addressed separately.
4. The nameplate operating conditions for the MVA are provided in PSR #43 on the "walk-down" sheets
5. For the equipment located inside containment, a required operating time of 120 days is specified. The referenced test lasted 30 days. PSR #43 has attempted to extrapolate the saturated steam test data to extend the qualified duration. The following facts should be noted in considering this methodology:



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NOTES:

- a. The installed motor is Class B
- b. The replacement motor is Class RH
- c. The extrapolation and thermal aging analyses use data from BOP 58.
- d. Class RH data is used to extend the test duration
- e. Class B data is used in evaluating thermal aging and relative humidity.
- f. The 165°F / 100% RH / 200hr. exposure cited in BOP 58 for Class B motors was performed in BOP 3 and simulates only a small fraction of the installed life.
- g. The thermal aging (log-life) data in BOP 58 (for both Class B and RH) did not consider RH. These were air-oven aging tests.

The following is noted with respect to this application of the Arrhenius Methodology:

The thermal aging analyses presented for this facility have attempted to extrapolate test data obtained from saturated steam tests using the Arrhenius technique to extend qualified duration or calculate qualified life estimates. The assumption used in justifying this procedure is that the thermal degradation during the environmental test is greater than that accumulated during the postulated accident conditions. What the analyses have failed to recognize is the fact



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NOTES:

that the Arrhenius methodology is a theoretical relationship which attempts to predict how reaction rates vary with respect to increases in temperature. This technique is based on the premise that all organic materials degrade to some extent--primarily by oxidation--when exposed to elevated temperatures in the presence of air. The saturated steam tests, as a matter of procedure, purge the air from the test chamber prior to the onset of the environmental test. Therefore, the use of saturated steam, or superheated steam for that matter, in conjunction with the Arrhenius technique is not technically justified as an aging procedure. In addition, the Arrhenius technique does not take into account variations in the reaction rates due to changes in pressure (as would be experienced in a LOCA/MSLB/HELB test), nor does it account for possible anomalies due to the presence of moisture in the chamber atmosphere. The application of the Arrhenius methodology is limited to data obtained from air-oven thermal aging tests (minimum of three tests at different times and temperatures) where the only parameter affecting the reaction rate is temperature. Any application of this technique to thermodynamically different systems must be technically justified with valid analytical procedures.

Though the licensee has not provided the technical basis for extending the test duration by using Arrhenius, the licensee did state the following with respect to thermal aging, (PSR #430)

"Question #13

Report B0058, Section 3.2.1.3 (Thermal Aging) addresses that 100% relative humidity was maintained during the thermal aging procedure. Because there is no known method to contemplate the effects of humidity aging it is sufficient to assume that this meets the condition by keeping 100% RH during thermal aging of the equipment."



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NOTES:

This statement has not been related to the test duration extension and pressure effects were also not addressed. However, there was no indication during the test that continued exposure to the post-LOCA conditions would result in a failure of the device, and, as such, this device is considered qualified for the specified duration.

6. Thermal aging has been addressed in B0058 for the motor insulation system. The licensee has also addressed the qualification of the seals, gaskets and the lubricants. The limit and torque switches are to be replaced along with the motor and thermal aging of these devices has been addressed in B0058. These devices are composed of plastics and metals which are not significantly affected by thermal aging degradation. Terminal strips (blocks) and connectors have been addressed also. The licensee



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 69

NOTES:

has stated that the equipment interfaces will be addressed as separate items.

The licensee should be aware that Teflon is used in many motor leads and is susceptible to thermal aging and radiation effects.

7. The difference in motor manufacturers has been adequately addressed

General Note:

Since the licensee has committed to replace the motor, limit switches, torque switch, install "T" drains on limit switch compartments and use grease relief valves on the main gear box; the licensee should provide documented evidence that the modified MVA and the listed are similar because the changes are very extensive. This request is meant as a precaution to assure qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 70

EQUIPMENT ITEM NO. 70
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)
 LIMITORQUE MODEL SMB WITH CLASS B INSULATION; SIZES 00, 000
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 70
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM VOLUME CONTROL TANK (MOV-1115C, E)
 LICENSEE SUBMITTAL: SCEW(S): 6-14, -16
 FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE TANK (MOV-1275B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-3, -4

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 7

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 70

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
(If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ **X**
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 70

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 71

EQUIPMENT ITEM NO. 71
 MOTORIZED VALVE ACTUATOR LOCATED IN THE CONTAINMENT SPRAY PUMP HOUSE (CSPH-11)
 BELOW ELEV. 27'6"
 LIMITORQUE MODEL SM800 WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 71
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHEMICAL ADDITION TANK ISOLATION (MOV-CS-102B)
 LICENSEE SUBMITTAL: SCEW(S): 6-77
 FUNCTION (PLANT ID): CHEMICAL ADDITION (MOV-CS-102A)
 LICENSEE SUBMITTAL: SCEW(S): 6-76
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (MOV-CS-101D)
 LICENSEE SUBMITTAL: SCEW(S): 6-75
 FUNCTION (PLANT ID): SPRAY PUMP DISCHARGE ISOLATION (MOV-CS-101C, B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-74, -73, -72

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. _____

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 71

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 7

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 72

EQUIPMENT ITEM NO. 72
 MOTORIZED VALVE ACTUATOR LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-11)
 LIMITORQUE MODEL SMB00 WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 72
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER (MOV-SW-105D, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-249, -248
 FUNCTION (PLANT ID): SERVICE WATER OUTLET RECIRCULATION SPRAY HEAT EXCHANGER
 (MOV-SW-105B)
 LICENSEE SUBMITTAL: SCEW(S): 6-247
 FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER SERVICE WATER RETURN
 (MOV-SW-105A, -104D)
 LICENSEE SUBMITTAL: SCEW(S): 6-246, -245
 FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER SERVICE WATER SUPPLY
 (MOV-SW-104C, B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-244, -243, -242

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 7

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 72

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 73

EQUIPMENT ITEM NO. 73
 MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-47B)
 LIMITORQUE MODEL SMB00
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 73
 LICENSEE REFERENCE(S): 659, 706, 43
 FUNCTION (PLANT ID): AUXILIARY FEEDWATER/HELB MITIGATION (MOV-FW-151A TO F)
 LICENSEE SUBMITTAL: SCEW(S): 6-96 TO -101

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), (T), (QT), RT, (P), (H), (CS), (A), S, (R), M, I, QM, RPN, EXN, SEN, (QI) RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action 821231 (last quarter of 1982).)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------------------------|---------------------------------------------------------|
| <input type="checkbox"/> I.a Qualified | <input type="checkbox"/> II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | <input type="checkbox"/> III.a Exempt |
| <input type="checkbox"/> II.a Qualification Not Established | <input type="checkbox"/> III.b Not in Scope |
| <input type="checkbox"/> II.b Not Qualified | <input type="checkbox"/> IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 73

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

Refer to equipment item # 69 for detailed evaluation of the referenced reports previously reviewed for similar equipment.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 70

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 73

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.8 Limitorque (Motor Operated Valve Actuators)

7.2.8.1 Motor Operators Without Brakes

PLANT ID NO.	WORKSHEET PAGE NO.
MOV-FW151A	6-96
MOV-FW151B	6-97
MOV-FW151C	6-98
MOV-FW151D	6-99
MOV-FW151E	6-100
MOV-FW151F	6-101
MOV-1535	6-196
MOV-1536	6-197

7.2.8.1.1 Modification/Replacement Status

Additional vendor qualification documentation comprised of a listing of the special operator features (e.g., actuator motor, limit switch and torque switches, insulating and housing materials, splices, etc., used in the various vendor qualification tests was received. For each MOV with incomplete qualification data, we conducted a field inspection to determine the existence of any unqualified components. We will replace all unqualified parts with qualified ones.

7.2.8.1.2 Modification/Replacement Schedule

Based on current projections for purchase order placement, material delivery and our present outage schedule, these modifications are scheduled to start during the last quarter of 1982.

7.2.8.1.3 Justification For Continued Operation

Review of the available qualification documents, some dating back to the time at which Surry was built, indicates that valve actuators with parts similar to those slated for replacement were demonstrated by testing and analysis, to be capable of functioning in the harsh environments more severe than that expected in Surry following DBA/HELB.

Also, no failure of any significance were experienced during these tests to indicate a potential for common mode failures. On this basis, it is concluded that continued operation of Surry Units in the interim with this equipment, albeit incomplete in qualification documentation, will have little or no effect on safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 74

EQUIPMENT ITEM NO. 74
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
 (AB-29)
 LIMITORQUE MODEL SMB000 WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 74
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): BORIC ACID INJECTION TANK INLET VALVE (MOV-1867B)
 LICENSEE SUBMITTAL: SCEW(S): 6-211
 FUNCTION (PLANT ID): REACTOR COOLING PUMP SEAL WATER RETURN (MOV-1381)
 LICENSEE SUBMITTAL: SCEW(S): 6-6

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 74

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

I.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 74

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 14

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 75

EQUIPMENT ITEM NO. 75
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMB000 WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 75
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION RECIRCULATION VALVE (MOV-1860A)
 LICENSEE SUBMITTAL: SCEW(S): 6-201
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION PUMP RECIRCULATION (MOV-1885D)
 LICENSEE SUBMITTAL: SCEW(S): 6-230D
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION RECIRCULATION WATER (MOV-1860B)
 LICENSEE SUBMITTAL: SCEW(S): 6-202

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 MOV-1885D only
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 75

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| <u>I.a Qualified</u> | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 75

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____ X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

REFER TO EQUIPMENT ITEM #60 FOR DETAILED EVALUATION OF
 THE REFERENCED REPORTS PREVIOUSLY REVIEWED FOR SIMILAR
 EQUIPMENT.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 75

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 76

EQUIPMENT ITEM NO. 76
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL LB831654E
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 76
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): BORON INJECTION TANK RECIRCULATION (SOV-1884C, B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-227, -226, -225

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 76

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW

- CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| (I.b) Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 74

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 76

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 76

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of $10E6$ rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

EQUIPMENT ITEM NO. 77
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 ASCO MODEL LB831654
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 77
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRESSURIZER AUXILIARY SPRAY ISOLATION/MINIMUM BORATION
 (SOV-1311)
 LICENSEE SUBMITTAL: SCEW(S): 6-12

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), (T), (QT) RT, (P) (H) (CS) (A) S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 7

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | <u>III.a</u> Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification X _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- X (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482/483

Page
3b

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

LICENSEE RESPONSE TO NRC SER (Continued)

7.3.14 Solenoid Operated Valves (Chemical and Volume Control)

SOV-1311

This valve will not be required during a LOCA because pressure and boration control are not necessary. During an Auxiliary Building HELB, this valve will not be affected, since it is inside containment.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/~~non-concurrence~~ with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

Reason for Non-Concurrence

- Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)
- Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIb)
- Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

- Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.
- Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.
- Backup (equipment/system) is subject to a potentially disabling single active failure.
- Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.
- Failure of the primary equipment can result in erroneous indication which could mislead an operator.
- Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 77

Reason for Concurrence

___ The equipment's accident mitigating function is completed prior to the onset of the hostile environment. No subsequent functions are necessary. See note (1) below. (NRC Qualification Evaluation Category IIIIb)

___ Other (see page ___)

___ Resultant NRC Qualification Evaluation Category (IIIIa/IIIIb)

Note 1: The Licensee (~~has~~/has not) stated that failure of the primary equipment will not affect other safety-related equipment or cause an operator to be misled. (See page 36)

Reason for Non-Concurrence

___ Although backup equipment is available, it is not technically sound to relinquish defense-in-depth for this function.

___ Backup (equipment/system) is not safety-related.

___ This equipment is necessary for the operator to ensure an ESF system is performing its intended safety function.

___ The rationale presented by the Licensee is not supported by objective technical evidence.

___ Other (see page ___)

LICENSEE STATEMENT

See page 3a of this checksheet.

EVALUATION OF LICENSEE STATEMENT



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 78

EQUIPMENT ITEM NO. 78
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL HBX8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 78
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150C, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-82, -80
 FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100C)
 LICENSEE SUBMITTAL: SCEW(S): 6-169
 FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER TANK VENT (SOV-VG-109A)
 LICENSEE SUBMITTAL: SCEW(S): 6-166
 FUNCTION (PLANT ID): NITROGEN SUPPLY LINE (SOV-DG-108A)
 LICENSEE SUBMITTAL: SCEW(S): 6-164

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), T, (QT) RT, P, H, CS, A, S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 78

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 78

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 78

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 78

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specifically installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 79

EQUIPMENT ITEM NO. 79
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL HBX8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 79
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR CONTAINMENT SUMP PUMP DISCHARGE (SOV-DA-100B)
 LICENSEE SUBMITTAL: SCEW(S): 6-163
 FUNCTION (PLANT ID): COMPONENT COOLING RETURN FROM CONTAINMENT COOLERS
 ISOLATION (SOV-CC-110A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-69 TO -71

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (QT) RT, (P) (H) CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 7

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 79

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established
- Aging Degradation Evaluated Adequately
- Qualified Life or Replacement Schedule Established (If Required)
- Program Established to Identify Aging Degradation
- Criteria Regarding Aging Simulation Satisfied (If Required)
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate
 - o Peak Pressure Adequate
 - o Duration Adequate
 - o Required Profile Enveloped Adequately
 - o Steam Exposure (If Required) Adequate
- Criteria Regarding Spray Satisfied
- Criteria Regarding Submergence Satisfied
- Criteria Regarding Radiation Satisfied
- Criteria Regarding Test Sequence Satisfied
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied
- Criteria Regarding Functional Testing Satisfied
- Criteria Regarding Instrument Accuracy Satisfied
- Test Duration Margin (1 hour + Function Time) Satisfied
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established
- II.b Equipment Not Qualified
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified
- III.a Equipment Exempt From Qualification
- III.b Equipment Not in the Scope of the Qualification Review
- IV Documentation Not Made Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 70

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 79

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 80

EQUIPMENT ITEM NO. 80
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL HBX832081RF
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 80
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLING HOT LEG SAMPLE (SOV-SS-106A)
 LICENSEE SUBMITTAL: SCEW(S): 6-240
 FUNCTION (PLANT ID): PRESSURE RELIEF TANK SAMPLE (SOV-SS-104A)
 LICENSEE SUBMITTAL: SCEW(S): 6-238

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (QT) RT, (P) (H) (CS) (A) S, (R), M, I, QM, (RPN), EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 80

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 80

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 80

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 81

EQUIPMENT ITEM NO. 81
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
 LAWRENCE MODEL 330OWA742DC
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 81
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRESSURIZER POWER OPERATED RELIEF VALVE ACTUATION/LOCA
 AND MSLB MITIGATION (SOV-1456-3, SOV-1455C-3)
 LICENSEE SUBMITTAL: SCEW(S): 6-195, -192

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), (T), (Q), RT, (P), (H), (CS), (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 8

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 81

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 81

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION.
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 81

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 82

EQUIPMENT ITEM NO. 82
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL HT8316C47E
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 82
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): MAIN STEAM TRIP VALVE (SOV-MS-101AA, AB, BA, BB, CA, CB)
 LICENSEE SUBMITTAL: SCEW(S): 6-148 TO -153

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 82

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 82

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 8

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 83

EQUIPMENT ITEM NO. 83
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)
 ASCO, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 83
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REFUELING WATER STORAGE TANK CROSS CONNECT
 (SOV-SI-102B2, A2)
 LICENSEE SUBMITTAL: SCEW(S): 6-224, -222

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (OT) RT, (P) (H) CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 5

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 83

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review X _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 82

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 83

LICENSEE RESPONSE TO NRC SER (Continued)

7.3.15 Solenoid Operated Valves (Safety Injection)

- SOV-SI-102A1
- SOV-SI-102A2
- SOV-SI-102B1
- SOV-SI-102B2

These valves serve to cross-connect the LHSI suction line from the Refueling Water Storage Tank (RWST) in Unit 2, to supply the LHSI pump suction for Unit 1. If an HELB occurs in the MSVH for Unit 1 (Location of LHSI line from the RWST of (Unit 1), these valves can be operated to put the RWST of Unit 2 on service. Due to the location of these valves, these valves will not see the effects of an HELB in Unit one's main steam valve house. Thus, these valves have been deleted.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/non-concurrence with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

Reason for Non-Concurrence

— Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)

— Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.

Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIb)

— Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.

— Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

— Backup (equipment/system) is subject to a potentially disabling single active failure.

— Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.

— Failure of the primary equipment can result in erroneous indication which could mislead an operator.

— Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 83

Reason for Concurrence

The equipment's accident mitigating function is completed prior to the onset of the hostile environment. No subsequent functions are necessary. See note (1) below. (NRC Qualification Evaluation Category IIIb)

Other (see page)

Resultant NRC Qualification Evaluation Category (IIIa/IIIb)

Note 1: The Licensee (~~has~~/ has not) stated that failure of the primary equipment will not affect other safety-related equipment or cause an operator to be misled. (See page 36)

Reason for Non-Concurrence

Although backup equipment is available, it is not technically sound to relinquish defense-in-depth for this function.

Backup (equipment/system) is not safety-related.

This equipment is necessary for the operator to ensure an ESF system is performing its intended safety function.

The rationale presented by the Licensee is not supported by objective technical evidence.

Other (see page)

LICENSEE STATEMENT

See page 3a of this checksheet.

EVALUATION OF LICENSEE STATEMENT



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 84

EQUIPMENT ITEM NO. 84
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 84
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100A)
 LICENSEE SUBMITTAL: SCEW(S): 6-170
 FUNCTION (PLANT ID): PRIMARY GRADE WATER TO PRESSURIZER RELIEF TANK
 (SOV-1519A)
 LICENSEE SUBMITTAL: SCEW(S): 6-189

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (QT) RT, (P) (H) CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 84

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 84

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 84

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 85

EQUIPMENT ITEM NO. 85
 SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-11)
 ASCO, MODEL NOT STATED
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 85
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): MAIN STEAM LINE DRAINS TO CONDENSER (SOV-MS-110)
 LICENSEE SUBMITTAL: SCEW(S): 6-155

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 8

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 85

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established
- Aging Degradation Evaluated Adequately
- Qualified Life or Replacement Schedule Established (If Required)
- Program Established to Identify Aging Degradation
- Criteria Regarding Aging Simulation Satisfied (If Required)
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate
 - o Peak Pressure Adequate
 - o Duration Adequate
 - o Required Profile Enveloped Adequately
 - o Steam Exposure (If Required) Adequate
- Criteria Regarding Spray Satisfied
- Criteria Regarding Submergence Satisfied
- Criteria Regarding Radiation Satisfied
- Criteria Regarding Test Sequence Satisfied
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied
- Criteria Regarding Functional Testing Satisfied
- Criteria Regarding Instrument Accuracy Satisfied
- Test Duration Margin (1 hour + Function Time) Satisfied
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established
- II.b Equipment Not Qualified
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified
- III.a Equipment Exempt From Qualification
- III.b Equipment Not in the Scope of the Qualification Review
- IV Documentation Not Made Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 85

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 85

LICENSEE RESPONSE TO NRC SER

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 86

EQUIPMENT ITEM NO. 86
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
 ASCO MODEL NP831654E
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 86
 LICENSEE REFERENCE(S): 2850
 FUNCTION (PLANT ID): CHEMICAL VOLUME CONTROL SYSTEM ISOLATION VALVE FOR
 LETDOWN (SOV-1200A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-20, -21, -22
 FUNCTION (PLANT ID): PRESSURIZER POWER OPERATED RELIEF (SOV-1456-2, -1;
 -1455C-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): 6-190 TO -194

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (OT) RT, (P) (H) (CS) (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 86

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|---------------------------------------|
| I.a Qualified | <u>II.c</u> Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 80

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) X
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified X
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 86

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
5

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 86

Checksheets 5a thru 5f have been removed due to the
proprietary nature of information contained therein.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

EQUIPMENT ITEM NO. 87
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 830281RF
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 87
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER PUMP/CONTAINMENT ISOLATION VALVE OPERATOR (SOV-DG-108B)
 LICENSEE SUBMITTAL: SCEW(S): 6-165
 FUNCTION (PLANT ID): PRIMARY COOLANT HOT LEG SAMPLE (SOV-SS-106B)
 LICENSEE SUBMITTAL: SCEW(S): 6-241
 FUNCTION (PLANT ID): PRESSURE RELIEF TANK SAMPLE (SOV-SS-104B)
 LICENSEE SUBMITTAL: SCEW(S): 6-239
 FUNCTION (PLANT ID): RESIDUAL HEAT REMOVAL SAMPLE (SOV-SS-103)
 LICENSEE SUBMITTAL: SCEW(S): 6-237
 FUNCTION (PLANT ID): PRESSURE VAPOR SPACE (SOV-SS-101B1)
 LICENSEE SUBMITTAL: SCEW(S): 6-234
 FUNCTION (PLANT ID): PRESSURE LIQUID SPACE SAMPLE (SOV-SS-100B1)
 LICENSEE SUBMITTAL: SCEW(S): 6-232

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT), RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- X (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 87

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 88

EQUIPMENT ITEM NO. 88
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL 8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 88
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR CONTAINMENT PUMP DISCHARGE (SOV-DA-100A)
 LICENSEE SUBMITTAL: SCEW(S): 6-162

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) (T) (QT) RT, (P) (H) (CS) (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 88

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (~~has~~/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 88

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 88

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

EQUIPMENT ITEM NO. 89
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 ASCO MODEL 8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 89
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-101B)
 LICENSEE SUBMITTAL: SCEW(S): 6-129

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (RT) RT, P, H, CS, (A) S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW

- CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- X (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 89

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 90

EQUIPMENT ITEM NO. 90
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 90
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): NITROGEN RELIEF (SOV-SI-101B)
 LICENSEE SUBMITTAL: SCEW(S): 6-220
 FUNCTION (PLANT ID): NITROGEN SUPPLY (SOV-SI-100)
 LICENSEE SUBMITTAL: SCEW(S): 6-218
 FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100B)
 LICENSEE SUBMITTAL: SCEW(S): 6-168
 FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER TANK VENT (SOV-VG-109B)
 LICENSEE SUBMITTAL: SCEW(S): 6-167
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150D)
 LICENSEE SUBMITTAL: SCEW(S): 6-83
 FUNCTION (PLANT ID): REACTOR CONTAINMENT PUMP COOLANT WATER ISOLATION
 (SOV-CC-105A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-63 TO -65

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), T, (QT), RT, P, H, CS, (A), S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheets Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 90

EQUIPMENT ITEM NO. 90 (CONTINUED)

FUNCTION (PLANT ID): REACTOR COOLANT PUMP THERMAL BARRIER ISOLATION
 (SOV-CC-107)

LICENSEE SUBMITTAL: SCEW(S): 6-66

FUNCTION (PLANT ID): COOLING WATER RETURN FROM RESIDUAL HEAT EXCHANGER
 ISOLATION (SOV-CC-109A, B)

LICENSEE SUBMITTAL: SCEW(S): 6-67, -68

FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150B)

LICENSEE SUBMITTAL: SCEW(S): 6-81

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S; (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 90

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 90

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 90

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 91

EQUIPMENT ITEM NO. 91
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL NP8320A173B
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 91
 LICENSEE REFERENCE(S): 2850
 FUNCTION (PLANT ID): CONTAINMENT INSTRUMENTATION AIR COMPRESSOR SUCTION
 (SOV-BD-100E)
 LICENSEE SUBMITTAL: SCEW(S): 6-258
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100C)
 LICENSEE SUBMITTAL: SCEW(S): 6-256
 FUNCTION (PLANT ID): OUTSIDE BLOWDOWN TRIP VALVE (SOV-BD-100A)
 LICENSEE SUBMITTAL: SCEW(S): 6-254

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3e, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 91

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|---------------------------------------|
| I.a Qualified | <u>II.c</u> Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 91

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) X _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified X _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

See review of equipment item no. 86 for evaluation.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 91

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 92

EQUIPMENT ITEM NO. 92
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)
 ASCO MODEL 830282G
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 92
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG (SOV-SI-102B1, A1)
 LICENSEE SUBMITTAL: SCEW(S): 6-223, -221

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 92

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/~~non-concurrence~~ with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

Reason for Non-Concurrence

___ Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)

___ Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.

X Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIb)

___ Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.

___ Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

___ Backup (equipment/system) is subject to a potentially disabling single active failure.

___ Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.

___ Failure of the primary equipment can result in erroneous indication which could mislead an operator.

___ Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 92

Reason for Concurrence

___ The equipment's accident mitigating function is completed prior to the onset of the hostile environment. No subsequent functions are necessary. See note (1) below. (NRC Qualification Evaluation Category IIIb)

___ Other (see page ___)

___ Resultant NRC Qualification Evaluation Category (IIIa/IIIb)

Note 1: The Licensee (~~has~~/ has not) stated that failure of the primary equipment will not affect other safety-related equipment or cause an operator to be misled. (See page 36)

Reason for Non-Concurrence

___ Although backup equipment is available, it is not technically sound to relinquish defense-in-depth for this function.

___ Backup (equipment/system) is not safety-related.

___ This equipment is necessary for the operator to ensure an ESF system is performing its intended safety function.

___ The rationale presented by the Licensee is not supported by objective technical evidence.

___ Other (see page ___)

LICENSEE STATEMENT

See page 3a of this checksheet.

EVALUATION OF LICENSEE STATEMENT



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 93

EQUIPMENT ITEM NO. 93
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 8320A102
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 93
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100D, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-257, -255

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, (RPN), EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 93

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 93

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 94

EQUIPMENT ITEM NO. 94
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 ASCO MODEL 8320A102
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 94
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-100A TO G)
 LICENSEE SUBMITTAL: SCEW(S): 6-120 TO -126
 FUNCTION (PLANT ID): CONTAINMENT PRESSURE (SOV-LM-100H)
 LICENSEE SUBMITTAL: SCEW(S): 6-127
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-101A)
 LICENSEE SUBMITTAL: SCEW(S): 6-128
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100F)
 LICENSEE SUBMITTAL: SCEW(S): 6-259

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 94

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 94

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 94

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 94

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 95

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW

- CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 95

EQUIPMENT ITEM NO. 95
 SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-27)
 ASCO MODEL 80174
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 95
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): MAIN STEAM LINE DRAINS TO CONDENSER (SOV-MS-109)
 LICENSEE SUBMITTAL: SCEW(S): 6-154

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3e, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b,
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 95

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 95

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 95

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila.. Pa 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 96

EQUIPMENT ITEM NO. 96
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL NP8320175E
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 96
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): NITROGEN RELIEF (SOV-SI-101A)
 LICENSEE SUBMITTAL: SCEW(S): 6-219

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 96

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|---------------------------------------|
| I.a Qualified | <u>II.c</u> Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 96

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) X
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified X
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

See equipment item no. 86 for evaluation



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 96

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

EQUIPMENT ITEM NO. 97
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 831654
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 97
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): LETDOWN INLET NON-REGENERATIVE HEAT EXCHANGER (SOV-1204)
 LICENSEE SUBMITTAL: SCEW(S): 6-19

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R), T, (QT), RT, P, H, CS, (A), S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 98

EQUIPMENT ITEM NO. 98
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 830281R
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 98
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLE (SOV-SS-102B1)
 LICENSEE SUBMITTAL: SCEW(S): 6-236

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT RT, P, H, CS, A S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|---------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="radio"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 98

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 98

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 98

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila. Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 99

EQUIPMENT ITEM NO. 99
 SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-27)
 ASCO MODEL HBX8320A26
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 99
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): AIR REMOVAL TO CONTAINMENT (SOV-SV-102)
 LICENSEE SUBMITTAL: SCEW(S): 6-1

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 99

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW

- CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 99

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	_____
Aging Degradation Evaluated Adequately	_____
Qualified Life or Replacement Schedule Established (If Required)	_____
Program Established to Identify Aging Degradation	_____
Criteria Regarding Aging Simulation Satisfied (If Required)	_____
Criteria Regarding Temperature/Pressure Exposure:	
o Peak Temperature Adequate	_____
o Peak Pressure Adequate	_____
o Duration Adequate	_____
o Required Profile Enveloped Adequately	_____
o Steam Exposure (If Required) Adequate	_____
Criteria Regarding Spray Satisfied	_____
Criteria Regarding Submergence Satisfied	_____
Criteria Regarding Radiation Satisfied	_____
Criteria Regarding Test Sequence Satisfied	_____
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	_____
Criteria Regarding Functional Testing Satisfied	_____
Criteria Regarding Instrument Accuracy Satisfied	_____
Test Duration Margin (1 hour + Function Time) Satisfied	_____
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	_____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	_____
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	_____
II.b	Equipment Not Qualified	_____
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	_____
III.a	Equipment Exempt From Qualification	_____
III.b	Equipment Not in the Scope of the Qualification Review	_____
IV	Documentation Not Made Available	_____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 99

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 99

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 100

EQUIPMENT ITEM NO. 100
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT (RC-3B)
 ASCO MODEL HBX8320A26
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 100
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR SUCTION
 (SOV-IA-101A)
 LICENSEE SUBMITTAL: SCEW(S): 6-114

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

Equipment replacement with qualified equipment

Equipment modification

Equipment relocation above submergence level

Relocate or shield equipment from radiation source

Verify qualification by additional (testing/analysis)

Equipment relocation to a mild environment

Qualification testing of equipment in progress

Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

I.a Qualified

I.b Modification

II.a Qualification Not Established

II.b Not Qualified

II.c Qualified Life Deficiency

III.a Exempt

III.b Not in Scope

IV Documentation Not Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 100

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

Documented Evidence of Qualification Adequate	<u>X</u>
Adequate Similarity Between Equipment and Test Specimen Established	<u> </u>
Aging Degradation Evaluated Adequately	<u> </u>
Qualified Life or Replacement Schedule Established (If Required)	<u> </u>
Program Established to Identify Aging Degradation	<u> </u>
Criteria Regarding Aging Simulation Satisfied (If Required)	<u> </u>
Criteria Regarding Temperature/Pressure Exposure:	<u> </u>
o Peak Temperature Adequate	<u> </u>
o Peak Pressure Adequate	<u> </u>
o Duration Adequate	<u> </u>
o Required Profile Enveloped Adequately	<u> </u>
o Steam Exposure (If Required) Adequate	<u> </u>
Criteria Regarding Spray Satisfied	<u> </u>
Criteria Regarding Submergence Satisfied	<u> </u>
Criteria Regarding Radiation Satisfied	<u> </u>
Criteria Regarding Test Sequence Satisfied	<u> </u>
Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied	<u> </u>
Criteria Regarding Functional Testing Satisfied	<u> </u>
Criteria Regarding Instrument Accuracy Satisfied	<u> </u>
Test Duration Margin (1 hour + Function Time) Satisfied	<u> </u>
Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)	<u> </u>

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

I.a	Equipment Qualified	<u> </u>
I.b	Equipment Qualification Pending Modification	<u>X</u>
II.a	Equipment Qualification Not Established	<u> </u>
II.b	Equipment Not Qualified	<u> </u>
II.c	Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified	<u> </u>
III.a	Equipment Exempt From Qualification	<u> </u>
III.b	Equipment Not in the Scope of the Qualification Review	<u> </u>
IV	Documentation Not Made Available	<u> </u>



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 100

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 101

EQUIPMENT ITEM NO. 101
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL 830281R
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 101
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLE (SOV-SS-102A1)
 LICENSEE SUBMITTAL: SCEW(S): 6-235
 FUNCTION (PLANT ID): PRESSURE LIQUID SPACE SAMPLE (SOV-SS-101A1, -100A1)
 LICENSEE SUBMITTAL: SCEW(S): 6-233, -231

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 101

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW
 - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| (I.b) Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 101

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 101

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 101

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 102

EQUIPMENT ITEM NO. 102
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL HBX8320A26
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 102
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR SUCTION
 (SOV-IA-101B)
 LICENSEE SUBMITTAL: SCEW(S): 6-115
 FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR DISCHARGE
 (SOV-IA-100)
 LICENSEE SUBMITTAL: SCEW(S): 6-113

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

(R) T, (QT) RT, P, H, CS, (A) S, (R), M, I, QM, (RPN) EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO.

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

The Licensee (has/~~has not~~) provided a response to the SER concerns.

The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.

The Licensee has presented information which shows there are no outstanding qualification deficiencies.

The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.

Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.

Corrective action specified by the Licensee:

- Equipment replacement with qualified equipment
- Equipment modification
- Equipment relocation above submergence level
- Relocate or shield equipment from radiation source
- Verify qualification by additional (testing/analysis)
- Equipment relocation to a mild environment
- Qualification testing of equipment in progress
- Other (_____)

The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.

The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action during first quarter of 1982.)

The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10Z

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 102

LICENSEE RESPONSE TO NRC SER (Continued)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are of NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and severe external environments. They are heat resistant. They are Underwriter's Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e. insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 103

EQUIPMENT ITEM NO. 103
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 103
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CHARGING FLOW CONTROL/MINIMUM BORATION (FCV-1122)
 LICENSEE SUBMITTAL: SCEW(S): 6-10

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 103

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | <u>III.b</u> Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review X _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 103

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

SYSTEM CONSIDERATION REVIEW

The Licensee has stated that this equipment item does not require environmental qualification and/or should be exempted from qualification. The Licensee's rationale has been evaluated and the reasons for concurrence/~~non concurrence~~ with the technical basis of the Licensee's position are presented below.

Reason for Concurrence

- ___ Equipment does not provide a safety function or mitigate the consequences of a design basis accident. Equipment Environmental Qualification is not required by the DOR Guidelines. (NRC Qualification Evaluation Category IIIa)
- Equipment is not exposed to a harsh environment by the accident it is intended to mitigate. ~~See note (1) on page 4b.~~ (NRC Qualification Evaluation Category IIIb)
- ___ Backup (equipment/system) is available which completely performs the safety function. The backup (equipment/system) is environmentally qualified and appears to meet single active failure criterion. See note (1) on page 4b. (NRC Qualification Evaluation Category IIIa)

Reason for Non-Concurrence

- ___ Backup (equipment/system) is not fully capable of performing the intended safety function or accident mitigating function.
- ___ Backup (equipment/system) is not environmentally qualified and can be exposed to a hostile environment simultaneously with the primary equipment.
- ___ Backup (equipment/system) is subject to a potentially disabling single active failure.
- ___ Failure of the primary equipment can compromise the ability of other safety-related equipment to perform its specified safety function.
- ___ Failure of the primary equipment can result in erroneous indication which could mislead an operator.
- ___ Requirement for continued functioning throughout the post-accident period necessitates environmental qualification.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 104

EQUIPMENT ITEM NO. 104
 PRESSURE TRANSMITTER LOCATED IN THE AUXILIARY BUILDING
 ROSEMOUNT MODEL 1152AP7A22PB
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 104
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT PRESSURE POST-ACCIDENT MONITORING
 (PT-LM-101A, -101B)
 LICENSEE SUBMITTAL: SCEW(S): T-1, T-2 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *new item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 104

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

NA new item

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| <u>II.a</u> Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 104

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 104

LICENSEE RESPONSE TO NRC SER

5. Rosemount Inc. - Pressure Transmitters

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
PT-LM-101A	1152AP7A22PB	10.3-1
PT-LM-101B	1152AP7A22PB	10.3-2

Transmitters test documentation is presently being upgraded from IEEE 323-1971 to IEEE 323-1974.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 105

EQUIPMENT ITEM NO. 105
 SOLENOID VALVE LOCATED IN THE SAFEGUARDS AREA
 ASCO MODEL NP831654E
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 105
 LICENSEE REFERENCE(S): 649
 FUNCTION (PLANT ID): CONTAINMENT ISOLATION (SOV-DA-103A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-3, T-4 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable
new item

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 105

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|---------------------------------------|
| I.a Qualified | <u>II.c</u> Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 105

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) X
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified X
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

See Item 86 for evaluation



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. ¹³
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 106

EQUIPMENT ITEM NO. 106
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 GEMS MODELS XM-54854 AND XM-54853
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 106
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR COOLANT WATER LEVEL (WIDE RANGE) (LT-RS-151A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-30, T-31 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 106

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

NA new item

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-----------------------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| <input checked="" type="checkbox"/> I.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
3a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 106

LICENSEE RESPONSE TO NRC SER

1. GEMS - Level Transmitters

<u>Plant ID Nos.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
LT-RS-151A	XM-54854 & XM-54853	10.3-30
LT-RS-151B	XM-54854 & XM-54853	10.3-31.
LT-DA-110A	XM-54854	10.3-5
LT-DA-110B	XM-54854	10.3-6

Components are presently being qualified to IEEE 323-1974.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

EQUIPMENT ITEM NO. 107
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 GEMS MODEL XM-54854
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 107
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR COOLANT SUMP WATER LEVEL, NARROW RANGE
 (LT-DA-110A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-5, T-6 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

NA new item

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| I.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
3a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 107

LICENSEE RESPONSE TO NRC SER

1. GEMS - Level Transmitters

<u>Plant ID Nos.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
LT-RS-151A	XM-54854 & XM-54853	10.3-30
LT-RS-151B	XM-54854 & XM-54853	10.3-31.
LT-DA-110A	XM-54854	10.3-5
LT-DA-110B	XM-54854	10.3-6

Components are presently being qualified to IEEE 323-1974.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

EQUIPMENT ITEM NO. 108
 LIMIT SWITCH LOCATED IN THE SAFEGUARDS AREA
 NAMCO MODEL EA180-31302
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 108
 LICENSEE REFERENCE(S): 4447
 FUNCTION (PLANT ID): CONTAINMENT ISOLATION AUXILIARY BUILDING SUMP
 (ZS-DA-103A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-7, T-8 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

NA New Item

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|---------------------------------------|
| I.a Qualified | <u>II.C</u> Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| .b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____ X
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure: _____
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____ X
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW

Criteria: DOR Guidelines ___; NUREG-0588, Cat. I X; NUREG-0588, Cat. II ___.

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>EQUIPMENT DESCRIPTION</u>			
Equipment Type	Limit Switch	Limit Switch	
Manufacturer's Name (5.2.2/-/-)	NAMCO	NAMCO Controls	
Model Number (5.2.2/-/-)	EA180-31302	EA-180, Type 23	
Serial Number	—	EA-180-11302, Rev.-D	
Features/Mounting (5.2.6/-/-)	—	Horizontal in Autoclave	
Connections/Interfaces (5.2.6/-/-)	—	—	
Location/Elevation	outside Containment	Not Applicable	
Equipment ID No.	ZS-DA-103A ZS-DA-103B	Not Applicable	
<u>QUALIFICATION REPORT</u> (8.0/5.0/5.0)			
Report ID Number	Not stated	No Report I/D Number	
Report Date	March 3, 1980	8/20/81	
Issued by	Cleveland Development Co.	ACME CLEVELAND DEVELOPMENT COMPANY	
Prepared for	—	NAMCO CONTROLS	
Referenced Reports	—	Not Stated	
Qualification Method (5.1, 5.3/2.1, 2.4/2.1, 2.4)	Sequential Test	Sequential Test	
<u>QUALIFICATION TEST PROGRAM</u>			
Functional Test Description (5.2.5/2.2.9/2.2.9)	—	Make/break contact	
Operating Conditions (-/2.2.10/2.2.10)	—	0.5Amps @ 100 Vdc	
Load/Cycles/Voltage/ Current/Freq.	—		



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 19

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Acceptance Criteria (5.2.5/2.2.1/2.2.1)	—	Not Stated	
Accuracy (5.2.5/-/-)	Not Required	Not Stated	
Number of Specimens	—	One (1)	
Test Instruments Calibrated	—	Yes	
Safety Function (Active/ Passive) (-/2.1.3/2.1.3)	Active		
Test Duration (5.2.1/-/-)	—	30 days	
Accident Duration (Envir. Above Normal) (5.2.1/-/-)	120 days	Not Applicable	Note 2, page 5f
Required Function Time	120 days	Not Applicable	
Test Sequence (General) (5.2.3/2.3.1/2.3.1)	—	Inspection/Base line data Heat/Humidity Aging Mechanical Aging Irradiation Seismic testing LOCA Simulation	
Test Sequence (NUREG-0588, Cat. I) (-/2.3.1/-)	—		
1. Representative Sample			
2. Baseline Data			
3. Performance Extremes			
4. Thermal Aging			
5. Radiation Aging			
6. Wear Aging			
7. Vibration/Seismic			
8. DBE Exposure			
9. Post-DBE Exposure			
10. Inspection			
Aging (5.2.4, 7.0/4.0/4.0)	see Note 3, page 5f.	120°C for 400 hours	
Thermal Aging/Basis			
Material Aging Evaluation (7.0/-/-)	—	Not Stated	
Materials Susceptible (Thermal) (5.2.4, 7.0/-/-)	—	Not Stated	
Radiation Aging, Type	—	Gamma	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Radiation Aging, Dose (rd)	8.8 E 2 Rads	204 Megarads	*
Radiation Aging, Dose Rate	—	0.7 Megarads/ hour	
Radiation Aging, Method	Sequential Test	Test	
Materials Susceptible (Radiation) (5.2.4, 7.0/-/-)	—	Not Stated	
Operational Aging (-/4.2/-)	—	100,000 Actuation Cycles	
Other Age Conditioning (-/4.2/-)	—	Not Stated	
Qualified Life Claimed/ Established (5.2.4/4.10/-)	None Claimed	None Claimed	See Note 1, page 5f.
Normal Ambient Temperature	120°F	Not Applicable	
Normal Ambient Radiation	—	Not Applicable	
Normal Ambient Humidity	—	Not Applicable	
On-Going Surveillance and Preventive Maintenance (7.0/-/-)	—	Not Applicable	See Note 3, page 5f.
On-Going Analysis of Failures and Degradation (7.0/-/-)	—	Not Applicable	
Margin (General) (6.0/3.0/3.0)	—	Not Stated/ Not Applicable	
Margin (NUREG-0588, Cat. I) (-/3.2/-)	—	Not Stated	
1. Temperature (+15°F)			
2. Pressure (+10%, 10 psig max)			
3. Radiation (not required)			
4. Time (+10%, +1 hour + function time minimum)			

* Radiation aging and accident doses were combined in a single Exposure prior to the LOCA Simulation.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>ACCIDENT CONDITIONS</u>			
LOCA/MSLB/HELB/Uncontrolled (4.1, 4.2, 4.3.1, 4.3.3/ 1.1, 1.2, 1.5/1.1, 1.2, 1.5)	LOCA	LOCA/MSLB	
Radiation Type	—	Gamma	
Radiation Dose (rd) (4.1.2/1.4/1.4)	8 E 6 Rads	204 Megarads	*
Radiation Dose Rate (rd/hr) Radiation Qual. Method (5.3.1/-/-)	— Test	0.7 Megarads per hour Test	
Proximity to Concentrated Radiation (4.1.2/1.4.6/1.4.6)	—	Not Applicable	
Equipment Susceptible to Beta Radiation (4.1.2/-/-)	—	Not Stated	
Radiation Dose (Normal + Accident) (4.1.2/-/-)	—	Not Stated	
Plateout Dose Considered (-/1.48/1.48)	—	Not Applicable	
Gamma + Beta Dose (rd) (4.1.2/1.4.7/1.4.7)	—	Not Applicable	

*Radiation aging and accident doses were combined in a single
 Exposure prior to the LOCA Simulation.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE No.)	
<u>ENVIRONMENTAL PROFILE OF ACCIDENT CONDITIONS</u>				
Rate of Temp./Press. Increase	Not Required	11°F/8psi/sec		
Peak: °F/psig/RH/Time		340/115/100/3h4s		
Decrease To: °F/psig/RH/Time		140/-/-/2h4r		
Decrease To: °F/psig/RH/Time		340/105/100/3hrs		
Decrease To: °F/psig/RH/Time		320/76/100/2hrs		
Decrease To: °F/psig/RH/Time		300/57/100/1hr		
Decrease To: °F/psig/RH/Time		250/25/100/4days		
Decrease To: °F/psig/RH/Time		150/10/100/25 days		
Equipment Surface Tempera- ture (MSLB) (-/1.2.5.C, 2.6/1.2.5.C, 2.2.6)			Not Applicable	
Spray Qualification Method (5.3.2/1.3, 2.2.8/1.3, 2.2.8)			Test	
Spray Composition (4.1.4/1.3, 2.2.8/ 1.3, 2.2.8)			Boric Acid/water/sodium thiosulfate/sodium hydrox- ide	
Spray Density (gpm/ft ²)			0.15	
Spray Duration			30Days	
Submergence Duration (4.1.3/2.2.5/2.2.5)		Not Applicable		
In-Leakage Considered (5.2.6, 5.3.2/-/-)		Not Applicable		
Time to Submergence		Not Applicable		
Dust Environment (-/2.2.11/2.2.11)		Not Applicable		



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 16

NOTES:

1. The qualification report (reference [4447]) provides a reasonable estimate of qualified life, viz. 5 years at 55°C. The licensee should implement a replacement program for complete qualification of this item.

2. This is a harsh environment due to radiation. The accident duration is assumed to be the full 120 days of the required function time.

3. The licensee's response to equipment aging is as follows:

Veeco has not fully developed an aging evaluation program to meet the current requirements for addressing aging as outlined in the Safety Evaluation Report and as discussed in the meetings held in Bethesda on July 7-10, 1981. As indicated previously in I.E. Bulletin 79-01B 90 Day Review, Revision 3, a program to assess the failure mechanisms of all class 1E electrical equipment has been developed and implemented at Surry.

The Atomic Industrial Forum is currently drafting a position paper which Veeco feels has merit with regard to addressing the aging concerns. Implementation of this program is contingent, however, on review of the existing preventive maintenance program at the station. Veeco is currently reviewing the draft AIF position paper on aging evaluation methods in conjunction with the existing preventive maintenance program at Surry. An aging evaluation program which meets the requirements of the SER will be implemented by June 1982.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 108

INSTALLED TMI LESSONS LEARNED IMPLEMENTATION EQUIPMENT SUMMARY

NRC requested an evaluation of the environmental qualification of safety-related electrical equipment located in harsh environments required for TMI Lessons Learned Implementation. The objective is to evaluate qualification documentation of equipment within the scope of IE Bulletin 79-01B, Supplement 3 (item 2), in accordance with criteria established by the NRC (see Section 2 of this report) in a manner identical to the evaluation of all other safety-related electrical equipment. The scope of this review is limited to TMI Action Plan equipment associated with specific sections of NUREG-0737 which have an installation implementation date of January 1, 1981 (sections are identified below). Where applicable, a review is to be performed on installed equipment with implementation dates after January 1, 1981 if adequately identified by the licensee.

This plant is a PWR X, BWR .

The NSSS Vendor is Westinghouse (W) X, Babcox & Wilcox (B&W) ,
Combustion Engineering (CE) , General Electric (GE) .

With respect to this equipment item, it is noted (applicable section checked):

- The Licensee does not provide adequate information with respect to identification of TMI Action Plan equipment installed as of 1/1/81.
- The Licensee has not provided the correlation of this equipment item with the specific sections of NUREG-0737. [The correlation is needed to ensure that all items are included in the review, e.g., if a transmitter is identified as a TMI Action Plan item, are the cable and the terminal blocks associated with the device also identified?]
- The Licensee has not provided the approximate installation date for the TMI Action Plan equipment items so that the appropriate qualification criteria (NUREG-0588 or DOR Guidelines) can be used in the EEQ evaluation.
- The Licensee has provided a standard Owners' Group position with respect to a NUREG-0737 technical area.
- The Licensee has requested extensions of implementation dates.
- X The Licensee has stated that this equipment item is associated with the following section of NUREG-0737. (This list of applicable NUREG-0737 sections has been identified by NRC as sections within the scope of this review):
 - II.B.3 (ALL/1-1-81) Post-Accident Sampling Capability of Reactor Coolant and Containment
 - II.D.3 (ALL/1-1-81) Direct Indication of Relief and Safety Valve Position



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

- II.E.1.2 (PWR/1-1-81) Auxiliary Feedwater System Automatic Initiation and Flow Indication
- II.E.3.1 (PWR/1-1-81) Emergency Power Supply for Pressurizer Heaters (Safety-Grade Interfaces)
- II.E.4.1 (ALL/7-1-81) Dedicated Hydrogen Penetrations
- II.E.4.2 (ALL/1-1-81) Containment Isolation Dependability
- II.F.2 (PWR/1-1-81) Instrumentation for Detection of Inadequate Core Cooling
- II.G.1 (PWR/1-1-81) Emergency Power for Pressurizer Equipment (Safety-Grade Interfaces)
- II.K.2.10 (PWR/B&W/7-1-81) Safety-Grade Anticipatory Reactor Trip
- II.K.3.9 (PWR/W/1-1-81) PID Controller Modification (If Hardware Change Involved)
- II.K.3.12 (PWR/W/1-1-81) Anticipatory Reactor Trip upon Turbine Trip
- II.K.3.13 (BWR/GE/7-1-81) Separation of HPCI and RCIC Initiation Signals
- II.K.3.15 (BWR/GE/7-1-81) Prevention of Spurious Isolation of HPCI and RCIC Systems
- II.K.3.19 (BWR/GE/7-1-81) Interlock on Recirculation Pump Loop
- II.K.3.21 (BWR/GE/7-1-81) Restart of Core Spray and LPCI Systems (If Hardware Changed Out)
- II.K.3.27 (BWR/GE/7-1-81) Provide Common Reference Level for Vessel Level Instrumentation (If Hardware Changed Out)



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 109

EQUIPMENT ITEM NO. 109
 ACCELEROMETER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 ENDEVCO MODEL 2273AM20
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 109
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRESSURIZER SAFETY AND PORV VALVE POSITION INDICATOR
 (YE-100A-1, -2; -100B-1, -2; -100C-1, -2; -101A-1, -2;
 101B-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): T-9 THROUGH T-18 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 10

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <input checked="" type="checkbox"/> I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 109

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____ **X**
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 109

LICENSEE RESPONSE TO NRC SER

3. Endeveco - Acoustical Monitoring Accelerometer

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
YE-VMS-100A-1	2273AM20	10.3-9
YE-VMS-100A-2	2273AM20	10.3-10
YE-VMS-100B-1	2273AM20	10.3-11
YE-VMS-100B-2	2273AM20	10.3-12
YE-VMS-100C-1	2273AM20	10.3-13
YE-VMS-100C-2	2273AM20	10.3-14
YE-VMS-101A-1	2273AM20	10.3-15
YE-VMS-101A-2	2273AM20	10.3-16
YE-VMS-101B-1	2273AM20	10.3-17
YE-VMS-101B-2	2273AM20	10.3-18

The monitoring equipment is currently in the process of being qualified to the requirements of IEEE 323-1974. The information on the worksheets is the levels to which the equipment will be tested.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 110

EQUIPMENT ITEM NO. 110
 HARDLINE COAXIAL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 ENDEVCO MODEL 3075M6
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 110
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): VALVE POSITION INDICATION SIGNAL TRANSMISSION (LOW NOISE
 CABLE)
 LICENSEE SUBMITTAL: SCEW(S): T-19 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable
new item

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 110

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
 - Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
 - Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
 - The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
 - The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
 - The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>(I.b)</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 110

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
3a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 110

LICENSEE RESPONSE TO NRC SER

4. Endevco Supplied Cable - Acoustical Monitoring Equipment

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
Low Noise Cable	3075M6	10.3-19

The cable is currently in the process of being qualified to the requirements of IEEE 323-1974. The information on the worksheet reflects the levels to which the equipment will be tested.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 111

EQUIPMENT ITEM NO. 111
 CHARGE PREAMPLIFIER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 UNHOLTZ-DICKIE MODEL 22CA-2TR
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 111
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRESSURIZER PORV AND SAFETY VALVE POSITION INDICATION
 (YY-VMS-100A-1, -2; B-1, -2; C-1, -2; -101A-1, -2; B-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): T-20 THROUGH T-29 [3]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 111

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
 - Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
 - Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
 - The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
 - The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
 - The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| <u>I.b</u> Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 111

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification X _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 111

LICENSEE RESPONSE TO NRC SER

2. Unholtz-Dickie - Acoustical Monitoring Preamplifier

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
YY-VMS-100A-1	22CA-2TR	10.3-20
YY-VMS-100A-2	22CA-2TR	10.3-21
YY-VMS-100B-1	22CA-2TR	10.3-22
YY-VMS-100B-2	22CA-2TR	10.3-23
YY-VMS-100C-1	22CA-2TR	10.3-24
YY-VMS-100C-2	22CA-2TR	10.3-25
YY-VMS-101A-1	22CA-2TR	10.3-26
YY-VMS-101A-2	22CA-2TR	10.3-27
YY-VMS-101B-1	22CA-2TR	10.3-28
YY-VMS-101B-2	22CA-2TR	10.3-29

The monitoring equipment is currently in the process of being qualified to the requirements of IEEE 323-1974. The information on the worksheets is the levels to which the equipment will be tested.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 1a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

EQUIPMENT ITEM NO. 112
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 VALCOR MODEL V526
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 112
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): POST-ACCIDENT SAMPLING (HCV-SS-100A, -100B)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-38, -39 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, Q1, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 117

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

NA new item

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------------|--------------------------------|
| <input checked="" type="radio"/> I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

LICENSEE RESPONSE TO NRC SER

6. Valcor - Solenoid Operated Valves

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
TV-SS-102A	V526-5683-19	10.3-32
TV-SS-102B	V526-5683-19	10.3-33
TV-SS-106A	V526-5683-19	10.3-34
TV-SS-106B	V526-5683-19	10.3-35
HCV-SS-101D	V526-5683-19	10.3-36
HCV-SS-102A	V526-5683-19	10.3-37
HCV-SS-100A	V526-5683-19	10.3-38
HCV-SS-100B	V526-5683-19	10.3-39
TV-SS-103A	V526-5683-19	10.3-40
TV-SS-103B	V526-5683-19	10.3-41
S1-XCV-1401A	V526-5683-19	10.3-62
S1-XCV-1401B	V526-5683-19	10.3-63
S1-XCV-1422A	V526-5683-19	10.3-64
S1-XCV-1422B	V526-5683-19	10.3-65
TV-GW-100	V526-5695-31	10.3-76
TV-GW-101	V526-5695-31	10.3-77
TV-GW-102	V526-5695-31	10.3-78
TV-GW-103	V526-5695-31	10.3-79
TV-GW-104	V526-5695-31	10.3-80
TV-GW-105	V526-5695-31	10.3-81
TV-GW-106	V526-5695-31	10.3-82
TV-GW-107	V526-5695-31	10.3-83

The vendor has been contacted for qualification test data.



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 50

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW

Criteria: DOR Guidelines ___; NUREG-0588, Cat. I X; NUREG-0588, Cat. II ___.

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>EQUIPMENT DESCRIPTION</u>			
Equipment Type	Solenoid Valve	Solenoid Valve	
Manufacturer's Name (5.2.2/-/-)	Valcor Engineering	Valcor Engineering	
Model Number (5.2.2/-/-)	V526-5683-19	V52600-5291-2	
Serial Number	and V526-5295-31		
Features/Mounting (5.2.6/-/-)			
Connections/Interfaces (5.2.6/-/-)			
Location/Elevation	Containment and Aux. Bldg.		
Equipment ID No.	Various		
<u>QUALIFICATION REPORT</u> (8.0/5.0/5.0)			
Report ID Number	not cited	QR-52600-5940-2	
Report Date		05-July-1979	
Issued by		Valcor Engineering Corp.	
Prepared for		Isomedix Inc.	
Referenced Reports		IFR-V877-01	
Qualification Method (5.1, 5.3/2.1, 2.4/2.1, 2.4)		Type Test	
<u>QUALIFICATION TEST PROGRAM</u>			
Functional Test Description (5.2.5/2.2.9/2.2.9)		Insulation Resistance Tests	
Operating Conditions (-/2.2.10/2.2.10)		108 VAC	
Load/Cycles/Voltage/ Current/Freq.		44 psig N ₂	



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Acceptance Criteria (5.2.5/2.2.1/2.2.1)	:	Pass Functional Tests, Demonstrate Satisfactory Operability	:
Accuracy (5.2.5/-/-)	:	ND	:
Number of Specimens	:	1	:
Test Instruments Calibrated	:	Yes	:
Safety Function (Active/ Passive) (-/2.1.3/2.1.3)	: Active; : Cont. : Isolation : and : Post Accident : Sampling : system	31 Days	:
Test Duration (5.2.1/-/-)	:		:
Accident Duration (Envir. Above Normal) (5.2.1/-/-)	:		:
Required Function Time	: 120 days		:
Test Sequence (General) (5.2.3/2.3.1/2.3.1)	:		:
Test Sequence (NUREG-0588, Cat. I) (-/2.3.1/-)	:	TA/OPER/RAD/SEIS/STM+CHSP	:
1. Representative Sample	:		:
2. Baseline Data	:		:
3. Performance Extremes	:		:
4. Thermal Aging	:		:
5. Radiation Aging	:		:
6. Wear Aging	:		:
7. Vibration/Seismic	:		:
8. DBE Exposure	:		:
9. Post-DBE Exposure	:		:
10. Inspection	:		:
Aging (5.2.4, 7.0/4.0/4.0)	:	318 deg.F, 172 Hr. To Simulate	:
Thermal Aging/Basis	:	40 Yrs. @ 120 deg.F	:
Material Aging Evaluation (7.0/-/-)	:	MR52600-515-2 Additional 442 Hr.@318°F	:
Materials Susceptible (Thermal) (5.2.4, 7.0/-/-)	:	to age polyimide to 40 Yr.	:
Radiation Aging, Type	:	Coil Materials	:
	:	GAMMA	:



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila. Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 5c

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
Radiation Aging, Dose (rd)		50 x 10 ⁶	
Radiation Aging, Dose Rate		0.75 Mrd/h	
Radiation Aging, Method		Test	
Materials Susceptible (Radiation) (5.2.4, 7.0/-/-)			
Operational Aging (-/4.2/-)		7500 cycles 44psig N ₂	
Other Age Conditioning (-/4.2/-)		Seismic Simulation	
Qualified Life Claimed/ Established (5.2.4/4.10/-)	none	40 Yr./40 Yr.	
Normal Ambient Temperature			
Normal Ambient Radiation			
Normal Ambient Humidity			
On-Going Surveillance and Preventive Maintenance (7.0/-/-)			
On-Going Analysis of Failures and Degradation (7.0/-/-)			
Margin (General) (6.0/3.0/3.0)			
Margin (NUREG-0588, Cat. I) (-/3.2/-)			
1. Temperature (+15°F)			
2. Pressure (+10%, 10 psig max)			
3. Radiation (not required)			
4. Time (+10%, +1 hour + function time minimum)			



Franklin Research Center
 A Division of The Franklin Institute
 20th and Race Streets. Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
 FRC Project No. C5257
 FRC Assignment No. 13
 FRC Task No. 482

Page
 5d

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE NO.)
<u>ACCIDENT CONDITIONS</u>			
LOCA/MSLB/HELB/Uncontrolled (4.1, 4.2, 4.3.1, 4.3.3/ 1.1, 1.2, 1.5/1.1, 1.2, 1.5)	:	:	:
Radiation Type	:	GAMMA	:
Radiation Dose (rd) (4.1.2/1.4/1.4)	$3.7 \times 10^7 \text{ rd}$	150×10^6	:
Radiation Dose Rate (rd/hr) Radiation Qual. Method (5.3.1/-/-)	:	0.75×10^6 , Test	:
Proximity to Concentrated Radiation (4.1.2/1.4.6/1.4.6)	:	:	:
Equipment Susceptible to Beta Radiation (4.1.2/-/-)	:	:	:
Radiation Dose (Normal + Accident) (4.1.2/-/-)	$3.7 \times 10^7 \text{ rd.}$	$200 \times 10^6 \text{ rad}$:
Plateout Dose Considered (-/1.48/1.48)	:	NA	:
Gamma + Beta Dose (rd) (4.1.2/1.4.7/1.4.7)	:	NA	:



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

NRC REQUIREMENTS WITH SECTION REFERENCE (DOR/0588-I/0588-II)	LICENSEE SUBMITTAL	QUALIFICATION DOCUMENTATION	DEFICIENCY (X OR NOTE No.)
<u>ENVIRONMENTAL PROFILE OF ACCIDENT CONDITIONS</u>			
Rate of Temp./Press. Increase		Not Stated But Within 3 - 5 Min.	
Peak: °F/psig/RH/Time	275/45/-/30min	346/113/100/3h	
Decrease To: °F/psig/RH/Time	275/45/ 150/1.0/-/30min	335/113/100/3h	
Decrease To: °F/psig/RH/Time	150/ 125/1.0/-/47hr.	315/69/100/4h	
Decrease To: °F/psig/RH/Time	150/1.0/-/120days	272/28/100/4h	
Equipment Surface Tempera- ture (MSLB) (-/1.2.5.C, 2.2.6/1.2.5.C, 2.2.6)		245/13/100/27.5d	
Spray Qualification Method (5.3.2/1.3, 2.2.8/1.3, 2.2.8)		Test (Simultaneous)	
Spray Composition (4.1.4/1.3, 2.2.8/ 1.3, 2.2.8)	H ₃ BO ₃ (2000 - 2200ppm)	2200 ppm Boron H ₃ BO ₃ 0.064m Na ₂ S ₂ O ₃ NaOH, ph=10.5	
Spray Density (gpm/ft ²)	NaOH buffer ph 8.5 - 11	0.15 gpm/ft ²	
Spray Duration	4 hr.	44,640 min.	
Submergence Duration (4.1.3/2.2.5/2.2.5)	NA		
In-Leakage Considered (5.2.6, 5.3.2/-/-)			
Time to Submergence	NA		
Dust Environment (-/2.2.11/2.2.11)			



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
5f

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

NOTES:

1. It was determined by analysis that polyimide would require additional thermal aging of 442 hr. @ 318°F to simulate 40 yrs @ 120°F. All other coil materials were subsequently overaged during the additional thermal aging.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 113

EQUIPMENT ITEM NO. 113
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL
 VALCOR MODEL V526
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 113
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (TV-SS-102A,
 -106A, -103A; HCV-SS-101D, -102A)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-32, -34, -40, -36, -37 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 112

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| <u>I.a</u> Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 113

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

See equipment item no. 112 for evaluation.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 113

LICENSEE RESPONSE TO NRC SER

6. Valcor - Solenoid Operated Valves

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
TV-SS-102A	V526-5683-19	10.3-32
TV-SS-102B	V526-5683-19	10.3-33
TV-SS-106A	V526-5683-19	10.3-34
TV-SS-106B	V526-5683-19	10.3-35
HCV-SS-101D	V526-5683-19	10.3-36
HCV-SS-102A	V526-5683-19	10.3-37
HCV-SS-100A	V526-5683-19	10.3-38
HCV-SS-100B	V526-5683-19	10.3-39
TV-SS-103A	V526-5683-19	10.3-40
TV-SS-103B	V526-5683-19	10.3-41
S1-XCV-1401A	V526-5683-19	10.3-62
S1-XCV-1401B	V526-5683-19	10.3-63
S1-XCV-1422A	V526-5683-19	10.3-64
S1-XCV-1422B	V526-5683-19	10.3-65
TV-GW-100	V526-5695-31	10.3-76
TV-GW-101	V526-5695-31	10.3-77
TV-GW-102	V526-5695-31	10.3-78
TV-GW-103	V526-5695-31	10.3-79
TV-GW-104	V526-5695-31	10.3-80
TV-GW-105	V526-5695-31	10.3-81
TV-GW-106	V526-5695-31	10.3-82
TV-GW-107	V526-5695-31	10.3-83

The vendor has been contacted for qualification test data.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 114

EQUIPMENT ITEM NO. 114
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING
 VALCOR MODEL V526
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 114
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): HYDROGEN ANALYZER CONTAINMENT ISOLATION (TV-GW-100
 THROUGH -107; TV-SS-102B, -103B, -106B; S1-XCV-1401A, B;
 -1422A, B)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-76 THROUGH -83; 10.3-33, -35, -41, -62,
 -63, -64, -65 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 114

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| <u>I.a</u> Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 114

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified X
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____

See equipment item no. 112 for evaluation



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 114

LICENSEE RESPONSE TO NRC SER

6. Valcor - Solenoid Operated Valves

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
TV-SS-102A	V526-5683-19	10.3-32
TV-SS-102B	V526-5683-19	10.3-33
TV-SS-106A	V526-5683-19	10.3-34
TV-SS-106B	V526-5683-19	10.3-35
HCV-SS-107D	V526-5683-19	10.3-36
HCV-SS-102A	V526-5683-19	10.3-37
HCV-SS-100A	V526-5683-19	10.3-38
HCV-SS-100B	V526-5683-19	10.3-39
TV-SS-103A	V526-5683-19	10.3-40
TV-SS-103B	V526-5683-19	10.3-41
S1-XCV-1401A	V526-5683-19	10.3-62
S1-XCV-1401B	V526-5683-19	10.3-63
S1-XCV-1422A	V526-5683-19	10.3-64
S1-XCV-1422B	V526-5683-19	10.3-65
TV-GW-100	V526-5695-31	10.3-76
TV-GW-101	V526-5695-31	10.3-77
TV-GW-102	V526-5695-31	10.3-78
TV-GW-103	V526-5695-31	10.3-79
TV-GW-104	V526-5695-31	10.3-80
TV-GW-105	V526-5695-31	10.3-81
TV-GW-106	V526-5695-31	10.3-82
TV-GW-107	V526-5695-31	10.3-83

The vendor has been contacted for qualification test data.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 115

EQUIPMENT ITEM NO. 115
LIMIT SWITCH LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
GORDOS MODEL MR8901
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 115
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): RHR SYSTEM OUTLET POST-ACCIDENT SAMPLING VALVE
(ZS-SS-100A-1, -2; -100B-1, -2)
LICENSEE SUBMITTAL: SCEW(S): 10.3-54, -55, -56, -57 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
(See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 115

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 115

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established
- Aging Degradation Evaluated Adequately
- Qualified Life or Replacement Schedule Established (If Required)
- Program Established to Identify Aging Degradation
- Criteria Regarding Aging Simulation Satisfied (If Required)
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate
 - o Peak Pressure Adequate
 - o Duration Adequate
 - o Required Profile Enveloped Adequately
 - o Steam Exposure (If Required) Adequate
- Criteria Regarding Spray Satisfied
- Criteria Regarding Submergence Satisfied
- Criteria Regarding Radiation Satisfied
- Criteria Regarding Test Sequence Satisfied
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied
- Criteria Regarding Functional Testing Satisfied
- Criteria Regarding Instrument Accuracy Satisfied
- Test Duration Margin (1 hour + Function Time) Satisfied
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I)

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified
- I.b Equipment Qualification Pending Modification
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified
- III.a Equipment Exempt From Qualification
- III.b Equipment Not in the Scope of the Qualification Review
- IV Documentation Not Made Available



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 115

LICENSEE RESPONSE TO NRC SER

7. Gordos - Limit Switches

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
ZS-SS-102A-1	MR8901	10.3-42
ZS-SS-102A-2	MR8901	10.3-43
ZS-SS-102B-1	MR8901	10.3-44
ZS-SS-102B-2	MR8901	10.3-45
ZS-SS-106A-1	MR8901	10.3-46
ZS-SS-106A-2	MR8901	10.3-47
ZS-SS-106B-1	MR8901	10.3-48
ZS-SS-106B-2	MR8901	10.3-49
ZS-SS-101D-1	MR8901	10.3-50
ZS-SS-101D-2	MR8901	10.3-51
ZS-SS-102A-3	MR8901	10.3-52
ZS-SS-102A-4	MR8901	10.3-53
ZS-SS-100A-1	MR8901	10.3-54
ZS-SS-100A-2	MR8901	10.3-55
ZS-SS-100B-1	MR8901	10.3-56
ZS-SS-100B-2	MR8901	10.3-57
ZS-SS-103A-1	MR8901	10.3-58
ZS-SS-103A-2	MR8901	10.3-59
ZS-SS-103B-1	MR8901	10.3-60
ZS-SS-103B-2	MR8901	10.3-61
ZS-XCV-1401A-1	MR8901	10.3-66
ZS-XCV-1401A-2	MR8901	10.3-67
ZS-XCV-1401B-1	MR8901	10.3-68
ZS-XCV-1401B-2	MR8901	10.3-69
ZS-XCV-1422A-1	MR8901	10.3-70
ZS-XCV-1422A-2	MR8901	10.3-71
ZS-XCV-1422B-1	MR8901	10.3-72
ZS-XCV-1422B-2	MR8901	10.3-73
ZS-GW-100-1	MR8901	10.3-84
ZS-GW-100-2	MR8901	10.3-85
ZS-GW-101-1	MR8901	10.3-86
ZS-GW-101-2	MR8901	10.3-87
ZS-GW-102-1	MR8901	10.3-88
ZS-GW-102-2	MR8901	10.3-89
ZS-GW-103-1	MR8901	10.3-90
ZS-GW-103-2	MR8901	10.3-91
ZS-GW-104-1	MR8901	10.3-92
ZS-GW-104-2	MR8901	10.3-93
ZS-GW-105-1	MR8901	10.3-94
ZS-GW-105-2	MR8901	10.3-95
ZS-GW-106-1	MR8901	10.3-96
ZS-GW-106-2	MR8901	10.3-97
ZS-GW-107-1	MR8901	10.3-98
ZS-GW-107-2	MR8901	10.3-99

The vendor has been contacted for qualification test data.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 116

EQUIPMENT ITEM NO. 116
 LIMIT SWITCH LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL
 GORDOS MODEL MR8901
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 116
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (ZS-SS-102A-1,
 -2; -106A-1, -2; -101D-1, -2; 102A-3, -4; 103A-1, -2)
 LICENSEE SBUMITTAL: SCEW(S): 10.3-42, -43, -46, -47, -50, -51, -52, -53,
 -58, -59 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3e, 3d
System Consideration Review	4a, 4b, 4e, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 110

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 116

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 116

LICENSEE RESPONSE TO NRC SER

7. Gordos - Limit Switches

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
ZS-SS-102A-1	MR8901	10.3-42
ZS-SS-102A-2	MR8901	10.3-43
ZS-SS-102B-1	MR8901	10.3-44
ZS-SS-102B-2	MR8901	10.3-45
ZS-SS-106A-1	MR8901	10.3-46
ZS-SS-106A-2	MR8901	10.3-47
ZS-SS-106B-1	MR8901	10.3-48
ZS-SS-106B-2	MR8901	10.3-49
ZS-SS-101D-1	MR8901	10.3-50
ZS-SS-101D-2	MR8901	10.3-51
ZS-SS-102A-3	MR8901	10.3-52
ZS-SS-102A-4	MR8901	10.3-53
ZS-SS-100A-1	MR8901	10.3-54
ZS-SS-100A-2	MR8901	10.3-55
ZS-SS-100B-1	MR8901	10.3-56
ZS-SS-100B-2	MR8901	10.3-57
ZS-SS-103A-1	MR8901	10.3-58
ZS-SS-103A-2	MR8901	10.3-59
ZS-SS-103B-1	MR8901	10.3-60
ZS-SS-103B-2	MR8901	10.3-61
ZS-XCV-1401A-1	MR8901	10.3-66
ZS-XCV-1401A-2	MR8901	10.3-67
ZS-XCV-1401B-1	MR8901	10.3-68
ZS-XCV-1401B-2	MR8901	10.3-69
ZS-XCV-1422A-1	MR8901	10.3-70
ZS-XCV-1422A-2	MR8901	10.3-71
ZS-XCV-1422B-1	MR8901	10.3-72
ZS-XCV-1422B-2	MR8901	10.3-73
ZS-GW-100-1	MR8901	10.3-84
ZS-GW-100-2	MR8901	10.3-85
ZS-GW-101-1	MR8901	10.3-86
ZS-GW-101-2	MR8901	10.3-87
ZS-GW-102-1	MR8901	10.3-88
ZS-GW-102-2	MR8901	10.3-89
ZS-GW-103-1	MR8901	10.3-90
ZS-GW-103-2	MR8901	10.3-91
ZS-GW-104-1	MR8901	10.3-92
ZS-GW-104-2	MR8901	10.3-93
ZS-GW-105-1	MR8901	10.3-94
ZS-GW-105-2	MR8901	10.3-95
ZS-GW-106-1	MR8901	10.3-96
ZS-GW-106-2	MR8901	10.3-97
ZS-GW-107-1	MR8901	10.3-98
ZS-GW-107-2	MR8901	10.3-99

The vendor has been contacted for qualification test data.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 117

EQUIPMENT ITEM NO. 117
 LIMIT SWITCH LOCATED IN THE AUXILIARY BUILDING
 GORDOS MODEL MR8901
 REQUIRED OPERATING TIME: 120 DAYS
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (ZS-SS-102B-2,
 -1; -106B-1, -2; 103B-1, -2; ZS-XCV-1401A-1, -2;
 -1401B-1, -2; 1422A-1, -2; -1422B-1, -2; ZS-GW-100-1, -2;
 -101-1, -2; -102-1, -2; -103-1, -2; -104-1, -2; -105-1,
 -2; -106-1, -2; -107-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-45, -44, -48, -49, -60, -61, -66 THROUGH
 -69, -70 THROUGH -73, -84 THROUGH -99 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,
 Not stated, Not applicable *New item*

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 117

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/has not) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|-------------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| <u>II.a</u> Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 117

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
X = DEFICIENCY

- Documented Evidence of Qualification Adequate X
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established X
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 117

LICENSEE RESPONSE TO NRC SER

7. Gordos - Limit Switches

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
ZS-SS-102A-1	MR8901	10.3-42
ZS-SS-102A-2	MR8901	10.3-43
ZS-SS-102B-1	MR8901	10.3-44
ZS-SS-102B-2	MR8901	10.3-45
ZS-SS-106A-1	MR8901	10.3-46
ZS-SS-106A-2	MR8901	10.3-47
ZS-SS-106B-1	MR8901	10.3-48
ZS-SS-106B-2	MR8901	10.3-49
ZS-SS-101D-1	MR8901	10.3-50
ZS-SS-101D-2	MR8901	10.3-51
ZS-SS-102A-3	MR8901	10.3-52
ZS-SS-102A-4	MR8901	10.3-53
ZS-SS-100A-1	MR8901	10.3-54
ZS-SS-100A-2	MR8901	10.3-55
ZS-SS-100B-1	MR8901	10.3-56
ZS-SS-100B-2	MR8901	10.3-57
ZS-SS-103A-1	MR8901	10.3-58
ZS-SS-103A-2	MR8901	10.3-59
ZS-SS-103B-1	MR8901	10.3-60
ZS-SS-103B-2	MR8901	10.3-61
ZS-XCV-1401A-1	MR8901	10.3-66
ZS-XCV-1401A-2	MR8901	10.3-67
ZS-XCV-1401B-1	MR8901	10.3-68
ZS-XCV-1401B-2	MR8901	10.3-69
ZS-XCV-1422A-1	MR8901	10.3-70
ZS-XCV-1422A-2	MR8901	10.3-71
ZS-XCV-1422B-1	MR8901	10.3-72
ZS-XCV-1422B-2	MR8901	10.3-73
ZS-GW-100-1	MR8901	10.3-84
ZS-GW-100-2	MR8901	10.3-85
ZS-GW-101-1	MR8901	10.3-86
ZS-GW-101-2	MR8901	10.3-87
ZS-GW-102-1	MR8901	10.3-88
ZS-GW-102-2	MR8901	10.3-89
ZS-GW-103-1	MR8901	10.3-90
ZS-GW-103-2	MR8901	10.3-91
ZS-GW-104-1	MR8901	10.3-92
ZS-GW-104-2	MR8901	10.3-93
ZS-GW-105-1	MR8901	10.3-94
ZS-GW-105-2	MR8901	10.3-95
ZS-GW-106-1	MR8901	10.3-96
ZS-GW-106-2	MR8901	10.3-97
ZS-GW-107-1	MR8901	10.3-98
ZS-GW-107-2	MR8901	10.3-99

The vendor has been contacted for qualification test data.



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 118

EQUIPMENT ITEM NO. 118
 HYDROGEN ANALYZER LOCATED IN THE AUXILIARY BUILDING
 COMSIP-DELPHI MODEL K-III
 REQUIRED OPERATING TIME: 120 DAYS
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT HYDROGEN ANALYZER (H2A-GW-101-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-74, -75 [14]

DESIGNATION FOR DEFICIENCY IDENTIFIED BY THE NRC SER - CIRCLED ITEM(S) ONLY:
 (See Section 3 of this TER for Legend)

R, T, QT, RT, P, H, CS, A, S, (R), M, I, QM, RPN, EXN, SEN, QI, RPS, None,

Not stated, Not applicable
new item

LISTING OF APPLICABLE CHECKSHEETS:

<u>Contents</u>	<u>Checksheet Page No.</u>
Equipment Item	1a
Summary of Licensee Responses to the NRC SER	1b
Equipment Environmental Qualification Summary Forms	2
Licensee Response to NRC SER	3a, 3b, 3c, 3d
System Consideration Review	4a, 4b, 4c, 4d, 4e, 4f
Equipment Environmental Qualification Review	5a, 5b, 5c, 5d, 5e, 5f, 5g, 5h, 5i, 5j
Installed TMI Lessons Learned Implementation Equipment Summary	6a, 6b
Maintenance and Replacement Schedule Summary	7a, 7b, 7c



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 11

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/~~has not~~) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/~~has not~~) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/~~has not~~) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/~~has not~~) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------------|---------------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| <u>I.a</u> Qualification Not Established | III.b Not in Scope |
| II.b Not Qualified | <u>IV</u> Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 118

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review _____
- IV Documentation Not Made Available _____ **X**



Franklin Research Center
A Division of The Franklin Institute
20th and Race Streets, Phila., Pa. 19103 (215) 448-1000

NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

Page
3a

EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 118

LICENSEE RESPONSE TO NRC SER

8. Comsip Delphi - Hydrogen Analyzer

<u>Plant ID No.</u>	<u>Model</u>	<u>Worksheet Page No.</u>
H2A-GW-101-1	K-III	10.3-74
H2A-GW-101-2	K-III	10.3-75

The vendor is retesting and evaluating component test. We have contacted the supplier for the qualification test data.

5. CONCLUSIONS

The tabulations in Section 4.2 represent a summary of the results of the equipment environmental qualification (EEQ) assessment conducted in accordance with the methodology presented in Section 3. The evaluations are based on the available qualification documentation provided by the Licensee, complemented in several cases by other relevant technical information. The major qualification deficiencies that have been identified and the results of the evaluation are shown in the Equipment Environmental Qualification Summary Forms (Tables 4-1, 4-2, 4-3, and 4-4).

Although Sections 4.3, 4.4, and Appendix C of this report present a detailed evaluation of (1) the Licensee's qualification methodology, (2) the equipment environmental qualification of each equipment item, and (3) the Licensee's response to the NRC SER, it is appropriate to highlight for the Licensee and the NRC certain conclusions reached as a result of the review which require special attention. These are summarized below.

In general, the Licensee's effort to establish similarity between a device tested and that installed in the plant was well done. The program used to determine the level of qualification of the Limitorque motorized valve actuators was very effective. Proving similarity of cable from tested to installed was the main exception. Some of the arguments were weak or inconclusive.

When a lack of qualification was found, the Licensee has generally chosen to replace the device.

As with all reviews to date, problems were noted with many aging evaluations and programs.

On February 1, 1982, the Licensee provided the following response concerning TMI Action Plan equipment [14]:

MASTER LIST

Class IE Electrical Equipment Required to Function

Under Postulated Accident Conditions

SYSTEM: REACTOR COOLANT

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
YE-VMS-100A-1	10.3-9 Accelerometer	x	
YE-VMS-100A-2	10.3-10 Accelerometer	x	
YE-VMS-100B-1	10.3-11 Accelerometer	x	
YE-VMS-100B-2	10.3-12 Accelerometer	x	
YE-VMS-100C-1	10.3-13 Accelerometer	x	
YE-VMS-100C-2	10.3-14 Accelerometer	x	
YE-VMS-101A-1	10.3-15 Accelerometer	x	
YE-VMS-101A-2	10.3-16 Accelerometer	x	
YE-VMS-101B-1	10.3-17 Accelerometer	x	
YE-VMS-101B-2	10.3-18 Accelerometer	x	
Low Noise Cable	10.3-19 Hardline Co-Axial Cable	x	
TITLE			
CHECKED	VIRGINIA ELECTRIC AND POWER COMPANY		
CORRECT	SURRY UNIT 1		
APPROVED			
REVISIONS	(2)	(3)	(4) (5)

FIGURE SUPPLIED BY THE LICENSEE

STONE & WEBSTER ENGINEERING CORPORATION

10.2-5

MASTER LIST

Class IE Electrical Equipment Required to Function
Under Postulated Accident Conditions

SYSTEM: REACTOR COOLANT

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
YY-VMS-100A-1	10.3-20 Remote Charge Preamplifier	x	
YY-VMS-100A-2	10.3-21 Remote Charge Preamplifier	x	
YY-VMS-100B-1	10.3-22 Remote Charge Preamplifier	x	
YY-VMS-100B-2	10.3-23 Remote Charge Preamplifier	x	
YY-VMS-100C-1	10.3-24 Remote Charge Preamplifier	x	
YY-VMS-100C-2	10.3-25 Remote Charge Preamplifier	x	
YY-VMS-101A-1	10.3-26 Remote Charge Preamplifier	x	
YY-VMS-101A-2	10.3-27 Remote Charge Preamplifier	x	
YY-VMS-101B-1	10.3-28 Remote Charge Preamplifier	x	
YY-VMS-101B-2	10.3-29 Remote Charge Preamplifier	x	
CHECKED	TITLE		
CORRECT	VIRGINIA ELECTRIC AND POWER COMPANY		
APPROVED	SURRY UNIT 1		
REVISIONS	(2)	(3)	(4) (5)

FIGURE SUPPLIED BY THE LICENSEE

STONE & WEBSTER ENGINEERING CORPORATION

10.2-7

MASTER LIST

Class IE Electrical Equipment Required to Function
Under Postulated Accident Conditions

SYSTEM: POST-ACCIDENT SAMPLING SYSTEM

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
TV-SS-102A	10.3-32 Solenoid Operated Valve	x	
TV-SS-102B	10.3-33 Solenoid Operated Valve		x
TV-SS-106A	10.3-34 Solenoid Operated Valve	x	
TV-SS-106B	10.3-35 Solenoid Operated Valve		x
HCV-SS-101D	10.3-36 Solenoid Operated Valve	x	
HCV-SS-102A	10.3-37 Solenoid Operated Valve	x	
HCV-SS-100A	10.3-38 Solenoid Operated Valve	x	
HCV-SS-100B	10.3-39 Solenoid Operated Valve	x	
TV-SS-103A	10.3-40 Solenoid Operated Valve	x	
TV-SS-103B	10.3-41 Solenoid Operated Valve		x
ZS-SS-102A-1	10.3-42 Open Position Limit Switch for TV-SS-102A	x	
TITLE			
CHECKED	VIRGINIA ELECTRIC AND POWER COMPANY		
CORRECT	SURRY UNIT 1		
APPROVED			
REVISIONS	(2)	(3)	(4) (5)

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE

MASTER LIST

Class IE Electrical Equipment Required to Function
Under Postulated Accident Conditions

SYSTEM: POST-ACCIDENT SAMPLING SYSTEM

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
ZS-SS-102A-2	10.3-43 Closed Position Limit Switch for TV-SS-102A	x	
ZS-SS-102B-1	10.3-44 Open Position Limit Switch for TV-SS-102B		x
ZS-SS-102B-2	10.3-45 Closed Position Limit Switch for TV-SS-102B		x
ZS-SS-106A-1	10.3-46 Open Position Limit Switch for TV-SS-106A	x	
ZS-SS-106A-2	10.3-47 Closed Position Limit Switch for TV-SS-106A	x	
ZS-SS-106B-1	10.3-48 Open Position Limit Switch for TV-SS-106B		x
ZS-SS-106B-2	10.3-49 Closed Position Limit Switch for TV-SS-106B		x
ZS-SS-101D-1	10.3-50 Open Position Limit Switch for HCV-SS-101D	x	
ZS-SS-101D-2	10.3-51 Closed Position Limit Switch for HCV-SS-101D	x	
ZS-SS-102A-3	10.3-52 Open Position Limit Switch for HCV-SS-102A	x	
ZS-SS-102A-4	10.3-53 Closed Position Limit Switch for HCV-SS-102A	x	
CHECKED		TITLE	
CORRECT		VIRGINIA ELECTRIC AND POWER COMPANY	
APPROVED		SURRY UNIT 1	
REVISIONS	(2)	(3)	(4) (5)

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE

STONE & WEBSTER ENGINEERING CORPORATION

10.2-9

MASTER LIST				
Class IE Electrical Equipment Required to Function				
Under Postulated Accident Conditions				
SYSTEM: POST-ACCIDENT SAMPLING SYSTEM				
Plant Identification Number	Generic Name	Location		
		Inside Containment	Outside Containment	
	Worksheet Page No.			
ZS-SS-100A-1	10.3-54	Open Position Limit Switch for HCV-SS-100A	x	
ZS-SS-100A-2	10.3-55	Closed Position Limit Switch for HCV-SS-100A	x	
ZS-SS-100B-1	10.3-56	Open Position Limit Switch for HCV-SS-100B	x	
ZS-SS-100B-2	10.3-57	Closed Position Limit Switch for HCV-SS-100B	x	
ZS-SS-103A-1	10.3-58	Open Position Limit Switch for TV-SS-103A	x	
ZS-SS-103A-2	10.3-59	Closed Position Limit Switch for TV-SS-103A	x	
ZS-SS-103B-1	10.3-60	Open Position Limit Switch for TV-SS-103B		x
ZS-SS-103B-2	10.3-61	Closed Position Limit Switch for TV-SS-103B		x
S1-XCV-1401A	10.3-62	Solenoid Operated Valve		x
S1-XCV-1401B	10.3-63	Solenoid Operated Valve		x
S1-XCV-1422A	10.3-64	Solenoid Operated Valve		x
CHECKED		TITLE VIRGINIA ELECTRIC AND POWER COMPANY SURRY UNIT 1		
CORRECT				
APPROVED				
REVISIONS	(2)			

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 92

SUMMARY OF LICENSEE RESPONSES TO THE NRC SER - ONLY CHECKED ITEMS ARE APPLICABLE:

- The Licensee (has/~~has not~~) provided a response to the SER concerns.
- The Licensee (has/has not) specifically stated that the equipment is qualified and/or will function when exposed to the applicable DBE environmental service conditions.
- The Licensee has presented information which shows there are no outstanding qualification deficiencies.
- The Licensee (has/has not) proposed a corrective action for this equipment item whose qualification has not been fully established.
- Justification for interim operation (has/has not) been provided by the Licensee for this equipment item.
- Corrective action specified by the Licensee:
 - Equipment replacement with qualified equipment
 - Equipment modification
 - Equipment relocation above submergence level
 - Relocate or shield equipment from radiation source
 - Verify qualification by additional (testing/analysis)
 - Equipment relocation to a mild environment
 - Qualification testing of equipment in progress
 - Other (_____)
- The Licensee has provided other information for this equipment item that can be construed as a basis for justification for interim operation.
- The Licensee (has/has not) provided a schedule for the proposed corrective action. (Schedule for accomplishing the corrective action _____.)
- The Licensee states that the equipment item does not require qualification and/or should be exempted from environmental qualification.

DESIGNATION OF RESULTANT NRC QUALIFICATION EVALUATION CATEGORY BASED ON REVIEW - CIRCLED ITEM ONLY: (See Section 3 of this TER for Legend)

- | | |
|------------------------------------|--------------------------------|
| I.a Qualified | II.c Qualified Life Deficiency |
| I.b Modification | III.a Exempt |
| II.a Qualification Not Established | III.b Not in Scope |
| I.b Not Qualified | IV Documentation Not Available |



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

EQUIPMENT ENVIRONMENTAL QUALIFICATION SUMMARY FORM

NRC REQUIREMENTS

DESIGNATION:
 X = DEFICIENCY

- Documented Evidence of Qualification Adequate _____
- Adequate Similarity Between Equipment and Test Specimen Established _____
- Aging Degradation Evaluated Adequately _____
- Qualified Life or Replacement Schedule Established (If Required) _____
- Program Established to Identify Aging Degradation _____
- Criteria Regarding Aging Simulation Satisfied (If Required) _____
- Criteria Regarding Temperature/Pressure Exposure:
 - o Peak Temperature Adequate _____
 - o Peak Pressure Adequate _____
 - o Duration Adequate _____
 - o Required Profile Enveloped Adequately _____
 - o Steam Exposure (If Required) Adequate _____
- Criteria Regarding Spray Satisfied _____
- Criteria Regarding Submergence Satisfied _____
- Criteria Regarding Radiation Satisfied _____
- Criteria Regarding Test Sequence Satisfied _____
- Criteria Regarding Test Failures or Severe Anomalies
 (If Any) Satisfied _____
- Criteria Regarding Functional Testing Satisfied _____
- Criteria Regarding Instrument Accuracy Satisfied _____
- Test Duration Margin (1 hour + Function Time) Satisfied _____
- Criteria Regarding Margins Satisfied (NUREG-0588, Cat. I) _____

NRC QUALIFICATION CATEGORY

DESIGNATION:
 X = CATEGORY

- I.a Equipment Qualified _____
- I.b Equipment Qualification Pending Modification _____
- II.a Equipment Qualification Not Established _____
- II.b Equipment Not Qualified _____
- II.c Equipment Satisfies All Requirements Except Qualified Life
 or Replacement Schedule Justified _____
- III.a Equipment Exempt From Qualification _____
- III.b Equipment Not in the Scope of the Qualification Review X _____
- IV Documentation Not Made Available _____



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 92

LICENSEE RESPONSE TO NRC SER

The present status of each component listed in Appendix B is indicated in the resolution column of Table 3. Each component has been placed into one of the following four categories:

- (1) COMPONENTS DELETED FROM THE MASTER LIST
- (2) COMPONENTS REQUIRING REPLACEMENT OR MODIFICATION
- (3) COMPONENTS DETERMINED TO BE QUALIFIED
- (4) COMPONENTS DETERMINED TO BE QUALIFIED EXCEPT FOR AGING



EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW OF EQUIPMENT ITEM NO. 97

LICENSEE RESPONSE TO NRC SER (Continued)

7.3.15 Solenoid Operated Valves (Safety Injection)

SOV-SI-102A1
SOV-SI-102A2
SOV-SI-102B1
SOV-SI-102B2

These valves serve to cross-connect the LHSI suction line from the Refueling Water Storage Tank (RWST) in Unit 2, to supply the LHSI pump suction for Unit 1. If an HELB occurs in the MSVH for Unit 1 (Location of LHSI line from the RWST of (Unit 1), these valves can be operated to put the RWST of Unit 2 on service. Due to the location of these valves, these valves will not see the effects of an HELB in Unit one's main steam valve house. Thus, these valves have been deleted.

MASTER LIST

Class IE Electrical Equipment Required to Function

Under Postulated Accident Conditions

SYSTEM: POST-ACCIDENT SAMPLING SYSTEM

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
S1-XCV-1422B	10.3-65	Solenoid Operated Valve	x
ZS-XCV-1401A-1	10.3-66	Open Position Limit Switch for S1-XCV-1401A	x
ZS-XCV-1401A-2	10.3-67	Closed Position Limit Switch for S1-XCV-1401A	x
ZS-XCV-1401B-1	10.3-68	Open Position Limit Switch for S1-XCV-1401B	x
ZS-XCV-1401B-2	10.3-69	Closed Position Limit Switch for S1-XCV-1401B	x
ZS-XCV-1422A-1	10.3-70	Open Position Limit Switch for S1-XCV-1422A	x
ZS-XCV-1422A-2	10.3-71	Closed Position Limit Switch for S1-XCV-1422A	x
ZS-XCV-1422B-1	10.3-72	Open Position Limit Switch for S1-XCV-1422B	x
ZS-XCV-1422B-2	10.3-73	Closed Position Limit Switch for S1-XCV-1422B	x
CHECKED		TITLE VIRGINIA ELECTRIC AND POWER COMPANY SURRY UNIT 1	
CORRECT			
APPROVED			
REVISIONS	(2) (3) (4) (5)		

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE

MASTER LIST

Class IE Electrical Equipment Required to Function
Under Postulated Accident Conditions

SYSTEM: HYDROGEN ANALYZER

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
H2A-GW-101-1	10.3-74	Hydrogen Analyzer	x
H2A-GW-101-2	10.3-75	Analyzer Remote Control Module	x
TV-GW-100	10.3-76	Solenoid Operated Valve	x
TV-GW-101	10.3-77	Solenoid Operated Valve	x
TV-GW-102	10.3-78	Solenoid Operated Valve	x
TV-GW-103	10.3-79	Solenoid Operated Valve	x
TV-GW-104	10.3-80	Solenoid Operated Valve	x
TV-GW-105	10.3-81	Solenoid Operated Valve	x
TV-GW-106	10.3-82	Solenoid Operated Valve	x
TV-GW-107	10.3-83	Solenoid Operated Valve	x
ZS-GW-100-1	10.3-84	Open Position Limit switch for TV-HC-100	x
CHECKED		TITLE VIRGINIA ELECTRIC AND POWER COMPANY SURRY UNIT 1	
CORRECT			
APPROVED			
REVISIONS	(2) (3) (4) (5)		

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE

MASTER LIST

Class IE Electrical Equipment Required to Function
Under Postulated Accident Conditions

SYSTEM: HYDROGEN ANALYZER

Plant Identification Number	Generic Name	Location	
		Inside Containment	Outside Containment
	Worksheet Page No.		
ZS-GW-100-2	10.3-85 Closed Position Limit Switch for TV-HC-100		x
ZS-GW-101-1	10.3-86 Open Position Limit Switch for TV-HC-101		x
ZS-GW-101-2	10.3-87 Closed Position Limit Switch for TV-HC-101		x
ZS-GW-102-1	10.3-88 Open Position Limit Switch for TV-HC-102		x
ZS-GW-102-2	10.3-89 Closed Position Limit Switch for TV-HC-102		x
ZS-GW-103-1	10.3-90 Open Position Limit Switch for TV-HC-103		x
ZS-GW-103-2	10.3-91 Closed Position Limit Switch for TV-HC-103		x
ZS-GW-104-1	10.3-92 Open Position Limit Switch for TV-HC-104		x
ZS-GW-104-2	10.3-93 Closed Position Limit Switch for TV-HC-104		x
ZS-GW-105-1	10.3-94 Open Position Limit Switch for TV-HC-105		x
ZS-GW-105-2	10.3-95 Closed Position Limit Switch for TV-HC-105		x
CHECKED		TITLE	
CORRECT		VIRGINIA ELECTRIC AND POWER COMPANY	
APPROVED		SURRY UNIT 1	
REVISIONS	(2)	(3)	(4) (5)

Supplement 3
February 1, 1981

FIGURE SUPPLIED
BY THE LICENSEE

6. REFERENCES

The references listed in this section of the report were used to develop the Equipment Environmental Qualification evaluation for this plant. The references have been separated into two lists: (1) Plant-Specific References and (2) Plant Generic References. All non-generic documents are listed on the "Plant-Specific References" list. All qualification documents that could be applicable to equipment installed in several plants were listed on the "Plant Generic References" list. These documents include topical reports, test reports, component and material analyses, etc. cited by the Licensee as evidence of qualification in accordance with the documentation reference instructions established by IE Bulletin 79-01B. Since these documents were compiled by a computer data base, the citation numbering was computer generated and the same document has the same generic reference number in all Technical Evaluation reports prepared under this equipment qualification program.

Throughout the text of the report, references are designated by a bracketed number; the reference numbers are not presented in sequential order.

PLANT-SPECIFIC REFERENCES

1. B. R. Sylvia
Letter to J. P. O'Reilly, NRC. Subject: IE
Bulletin 79-01B (90-Day Report). Surry
Power Station Unit Nos. 1 and 2
Virginia Electric & Power Co., 01-Oct-80
801
2. Letter to J. P. O'Reilly, NRC. Subject: Response to
IE Bulletin 79-01B, December 1, 1980 Revision
Virginia Electric & Power Co., 01-Dec-80
Serial No. 957
3. VEPCO Surry Unit 1 - IE Bulletin 79-01B
Revision 2 - Supplement 3 TMI Review
Virginia Electric & Power Co., 01-Dec-80
4. G. Lainas
Letter to A. Schwencer, NRC. Subject: Electrical
Equipment Environmental Qualification
USNRC, 19-Feb-80
5. Environmental Qualification of Electrical Equipment
USNRC/IE, 14-Jan-80
IEB 79-01B
6. Environmental Qualification of Class 1E Equipment
USNRC, 29-Feb-80
IEB 79-01B, Supp. 1
7. N. C. Moseley
Letter to B. H. Grier et al., NRC. Subject: Supplement
No. 2 to Bulletin 79-01B, Environmental Qualification of
Class 1E Equipment
USNRC, 29-Sep-80
8. N. C. Moseley
Letter to B. H. Grier et al., NRC. Subject: Supplement
No. 3 to Bulletin 79-01B, Environmental Qualification
of Class 1E Equipment
USNRC, 24-Oct-80

9. S. J. Chilk
Memorandum and Order Pursuant to Union of Concerned
Scientists Petition for Emergency and Remedial Relief
USNRC, 23-May-80
CLI-80-21
10. D. G. Eisenhut
Letter to All Power Reactor Licensees, Applicants, Vendors
Subject: Environmental Qualification of Safety-Related
Electrical Equipment; NRC Staff Positions
USNRC, 20-Apr-82
Gen. Ltr. 82-09
11. A. J. Szukiewicz
Interim Staff Position on Environmental Qualification of
Safety-Related Electrical Equipment; Including Staff
Responses to Public Comments
USNRC, 00-Jul-81
NUREG-0588, Rev. 1
12. Clarification of TMI Action Plan Requirements
USNRC, 00-Nov-80
NUREG-0737
13. B. R. Sylvia
Letter to J. P. O'Reilly, NRC. Subject: Response to
IE Bulletin 79-01B, Supplement 3, and Revision 3 to the
Ninety-Day Review Report
Virginia Electric & Power Co., 30-Jan-81
Serial No. 061
14. Surry Unit 1 - IE Bulletin 79-01B, TMI Review - Supplement
3, Revision 3 Change Package
Virginia Electric & Power Co., 01-Feb-81
15. Surry Unit 1 - IE Bulletin 79-01B 90-Day Review -
Revision 3 Change Package
Virginia Electric & Power Co., 01-Feb-81
16. Office of Nuclear Reactor Regulation
Safety Evaluation Report for Surry Power Station
Units 1 and 2
USNRC, 21-May-81
17. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga, NRC. Subject: Response
to Safety Evaluation Report for Environmental Qualification
... IE Bulletin 79-01B 90-Day Review; Surry Units 1 and 2
Virginia Electric & Power Co., 24-Aug-81
Serial No. 329

18. VEPCO Surry Unit 1 - IE Bulletin 79-01B 90-Day Review
Revision 4
Virginia Electric & Power Co., 24-Aug-81
19. Environmental Zone Description - Surry Power Station -
Units 1 and 2
(In Four Volumes)
Virginia Electric & Power Co., 24-Aug-81
20. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga, NRC. Subject: IE Bulletin
79-01B Supplement 3 - TMI Review - Surry Units 1 and 2 -
Transmittal of Additional Information to FRC
Virginia Electric & Power Co., 10-Sep-81
Serial No. 519
21. Response to NUREG-0737, Post TMI Requirements
Revision 1
Virginia Electric & Power Co., 31-May-81
22. R. H. Leasburg
Letter to S. A. Varga, NRC. Subject: Request for Additional
Information on Environment Qualification of Safety-Related
Electrical Equipment, Surry Power Station Unit No. 1 and 2
Virginia Electric & Power Co., 08-Feb-82
Serial No. 043
23. Surry Power Station Units 1 & 2; Equipment Qualification
Master Lists
Virginia Electric & Power Co., 14-Apr-82
24. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga, NRC. Subject:
Request for Additional Information, Environmental Qualifica-
tion of Safety Related Electrical Equipment; Surry 1 and 2
Virginia Electric & Power Co., 18-May-82
Serial No. 282
25. R. C. Wilson
Letter to C. J. Crane, FRC. Subject: Surry 1 and 2;
Environmental Qualification of Safety Related Electrical
Equipment; Submittal of Additional Information
NUS Corp., 21-May-82
26. Qualification Review Package: ASCO Class 1E Solenoid
Operated Valves, Surry Unit 1
NUS Corp., 05-Mar-82
QDR-5437-01-01, Rev. 1

27. Qualification Document Review: Limitorque Valve Motor Actuators for Outside Containment, Surry Unit 1
NUS Corp., 08-Mar-82
QDR-5437-03-01, Rev. 1
28. S. Kasturi
Letter to A. L. Parrish, III and J. E. Wroniewicz, VEPCO.
Subject: Limitorque Motor Operated Valve Inspection Reports,
with Attachments
NUS Corp., 19-Jun-81
N08.1-V01-039
29. Limitorque Type SMB Instruction and Maintenance Manual
Limitorque Corp.
30. Lubrication Inspection Procedure & Data
Limitorque Corp., 16-Oct-79
LC-8, Rev. 4
31. Limitorque Maintenance Procedure
Limitorque Corp., 21-Jun-77
LC-9
32. Qualification Review Package: Westinghouse Class 1E Motors for Nuclear Plant Outside Containment Charging Pumps, Surry Unit 1
NUS Corp., 02-Mar-82
QDR-5437-8-01
33. J. B. Cookinham
Letter to S. C. Brown, Jr., VEPCO. Subject: North Anna Power Station; NUREG-0588 Equipment Qualification
Westinghouse, 30-Oct-80
NAW-3615
34. Qualification Review Package: Electric Hydrogen Recombiner Power Supplies, Surry Unit 1
NUS Corp., 12-Mar-82
QDR-5437-16-01
35. Electric Hydrogen Recombiner Technical Manual
Westinghouse
Proprietary
36. H. W. Durkin
Letter to S. C. Brown, Jr. and H. H. Blake, VEPCO. Subject: Environmental Qualification of Equipment, Surry Power Station Units 1 & 2
Stone & Webster Engineering, 04-Mar-81
MPPA-8008-SE1031

37. F. A. Tolerico
Letter to J. H. Barnhart, S&W. Subject: Surry Power Station
1 and 2; Environmental Qualification of Hydrogen Recombiner
Westinghouse, 08-Dec-80
PI-80-0659
38. J. F. Stolz
Letter to T. M. Anderson, Westinghouse. Subject: Evaluation
of WCAP-7709L, Supplements 5, 6, and 7, with Attachment
USNRC, 22-Jun-78
39. Qualification Review Package: Siemens-Allis, Inc., Random
Wound Induction Motors Central Exhaust Fan Motors, Surry
Unit 1
NUS Corp., 23-Mar-82
QDR-5437-18-01, Rev. 1
40. Qualification Review Package: RCS, Inc., Safety Related 1E
Equipment Dampers for Filters 3A & 3B, Surry Unit 1
NUS Corp., 29-Mar-82
QDR-5437-19-01
41. Qualification Review Package: G. E. Vertical Induction Motors
Inside Containment Recirculation Spray Pumps, Surry Unit 1
NUS Corp., 22-Feb-82
QDR-5437-34-01, Rev. 1
42. M. W. Sheets
Topical Report: General Electric Vertical Induction Motors
Inside Containment Recirculation Spray Pumps for the Surry
and North Anna Stations
General Electric, 30-Jan-81
491HA689, Rev. 1
43. Qualification Review Package: Limitorque Valve Motor
Actuators for Inside Containment, Surry Unit 1
NUS Corp., 10-Mar-82
QDR-5437-35-01, Rev. 1
44. S. Kasturi
Letter to A. L. Parrish, III and J. E. Wroniewicz, VEPCO.
Subject: NUS Inspection of Limitorque Motor Actuators at
Surry 1 In-Containment
NUS Corp., 01-Jul-81
N08.1-V01-051
45. Qualification Review Package: Westinghouse Electrical
Hydrogen Recombiner, Surry Unit 1
NUS Corp., 11-Mar-82
QDR-5437-41-01, Rev. 1

46. Instruction and Maintenance Manual for Series 413 & 417
AC Power Controllers with Time Proportioning Control
Robicon Corp.
900 052
47. Instructions: R7350 A, B, G & H DialaTrol On-Off or Time
Proportioning Temperature Controllers with Relay Output,
Thermocouple, Millivolt or RTD Input
Honeywell, 00-May-71
95-8148
48. Qualification Review Package: Class 1E - Outside
Recirculation Spray Pump Motors, G. E. Induction Motors,
Surry Unit 1
NUS Corp., 24-Nov-81
QDR-5437-42-01, Rev. 1
49. M. W. Sheets
Qualification Report of General Electric Vertical Induction
Motors for Class 1E Outside Recirculation Spray Pumps
for the Surry Power Plant
General Electric, 20-Feb-81
492HA248
50. Instructions: TriClad Vertical Induction Motors; High Thrust
Hollow and Solid Shaft, P Base Frames 444-449, 6284-6289,
6314-6349 Open Enclosures
General Electric
GEH-3292C
51. Qualification Review Package: Westinghouse Class 1E Motors
(WCAP-8754) Outside Containment LHSI Pumps, Surry Unit 1
NUS Corp., 24-Feb-82
QDR-5437-43-01, Rev. 1
52. Qualification Review Package: Collyer 600V XLPE Insulated
Cables, Surry Unit 1
NUS Corp., 23-Nov-81
QDR-5437-44-01, Rev. 1
53. Qualification Review Package: Collyer 5000V XLPE Power
Cables, Surry Unit 1
NUS Corp., 16-Nov-81
QDR-5437-46-01, Rev. 1
54. F. J. Mahoney
Certified Inspection Test Report
Collyer Insulated Wire, 05-Oct-70
1104

55. F. J. Mahoney
Certified Inspection Test Report
Collyer Insulated Wire Co., 27-Oct-80
1131
56. F. J. Mahoney
Certified Inspection Test Report
Collyer Insulated Wire Co., 16-Dec-70
1209
57. Qualification Review Package: Okonite 5000V EPR Insulated
Cables, Surry Unit 1
NUS Corp., 26-Oct-81
QDR-5437-48-01, Rev. 1
58. J. S. Lasky
Letter to J. H. Barnhart, S&W. Subject: Environmental
Qualification of Equipment, Surry Power Station Units 1 & 2
Okonite Co., 17-Dec-80
59. J. S. Lasky
Letter to J. H. Barnhart, S&W. Subject: Qualification
Information
Okonite Co., 22-Dec-80
60. Qualification Review Package: Conax Power Penetrations,
Conax Type ID, IC, IIB, IIC, IIA; Surry Unit 1
NUS Corp., 25-Nov-81
QDR-5437-49-01, Rev. 1
61. Connecting of Electrical Cables, Conax Penetration
Assemblies to Field Cables; Virginia Electric and Power
Company, Surry Power Station Units 1 and 2
Conax Corp., 19-Dec-72
IPS-91
62. Installation & Maintenance Manual for Electrical Penetration
Assemblies; Virginia Electric and Power Company, North Anna
Power Station - 1975-Extension - Units 1 and 2
Conax Corp., 14-Dec-72
IPS-74, Rev. A
63. R. W. Graham
Seismic Analysis of Electrical Penetration Assemblies for
Virginia Electric and Power Company, Surry Power Station
Units 1 and 2
Conax Corp., 11-Dec-72
IPS-92

64. T. P. Schaefer
Prototype Test Report for Electrical Penetration Assemblies
for Surry Power Station Units 1 and 2
Conax Corp., 14-Feb-75
IPS-179
65. W. G. Bernbeck
Insulation Service Life; Prototype Test Report for Low
Voltage Power Penetrations for North Anna Power Stations 1
and 2
Conax Corp., 28-Feb-74
IPS-73.1, Proprietary
66. W. G. Bernbeck
Test Report on Fault Current Testing of LVP Electrical
Penetration Assemblies for North Anna Power Station 1 & 2
Conax Corp., 10-Jun-74
IPS-73.2, Proprietary
67. T. P. Schaefer
Maximum Emergency Environmental Test Report for Electrical
Penetration Assemblies for North Anna Power Stations 1 & 2
Conax Corp., 07-Feb-75
IPS-73.4, Proprietary
68. W. C. Federick
Qualification Report for Electric Penetration Assemblies for
North Anna Power Station Units 1 & 2
Conax Corp., 15-Oct-80
IPS-601, Proprietary
69. Qualification Review Package: Cerro 600V XLPE Cables;
Surry Unit 1
NUS Corp., 27-Oct-81
QDR-5437-50-01, Rev. 1
70. R. H. Dubuc
Letter to R. Clark, S&W. Subject: Quotation No. 062669
Regarding Cables
Cerro Wire & Cable Co., 01-Aug-69
71. Pyro-Trol III 600 Volt Control Cable Chemically Cross-Linked
Polyethylene Insulated, Neoprene Sheathed
Cerro Wire & Cable Co., 01-Nov-68
RSS-3-701, Iss. 4
72. Qualification Review Package: Cerro 600V XLPE Insulated
Cables; Surry Unit 1
NUS Corp., 29-Oct-81
QDR-5437-51-01, Rev. 1

73. Firewall III Multi-Conductor Tray Cable ... Specification
Rockbestos Co., 04-May-79
RSS-3-021, Iss. 5
74. Qualification Review Package: Cerro 300V XLPE Insulated
Cables; Surry Unit 1
NUS Corp., 19-Nov-81
QDR-5437-53-01, Rev. 1
75. Qualification Review Package: Raychem Corp. 300V XLPE
Instrument Cables; Surry Unit 1
NUS Corp., 19-Nov-81
QDR-5437-54-01, Rev. 1
76. Qualification Review Package: Cerro 1000V XLPE Insulated
Cables, Surry Unit 1
NUS Corp., 16-Oct-81
QDR-5437-55-01, Rev. 1
77. Qualification Review Package: Okonite 600V XLPE Cables,
Surry Unit 1
NUS Corp., 20-Oct-81
QDR-5437-56
78. Qualification Review Package: 1000V Control EPR Okonite
Cables, Surry Unit 1
NUS Corp., 21-Oct-81
QDR-5437-57-01, Rev. 1
79. J. S. Lasky
Letter to J. Bonner, S&W. Subject: Surry Power Station,
Cables Supplied
Okonite Co., 15-Oct-80
80. Qualification Review Package: 1000V Control EPR Okonite
Cables, Surry Unit 1
NUS Corp., 22-Oct-81
QDR-5437-58-01, Rev. 1
81. Qualification Review Package: Amphenol Electrical Penetra-
tion Assemblies, Surry Unit 1
NUS Corp., 02-Dec-81
QDR-5437-59-01, Rev. 1
82. R. L. Andrews
Engineering Proposal: Electrical Penetrations for Nuclear
Reactor Containment
Amphenol Corp., 12-Jan-68
W-15-28

83. Qualification Review Package: Continental Wire & Cable 600V
XLPE/Hypalon, Instrument Cable; Surry Unit 1
NUS Corp., 23-Apr-82
QDR-5437-60-01, Rev. 1
84. D. Neighbors
Summary of Meeting Held on July 7, 1978 to Discuss the
Environmental Qualification of Cables; Surry Power Station
Units 1 and 2
USNRC, 18-Jul-78
85. D. G. Eisenhut
Letter to W. L. Proffitt, VEPCO. Subject: Need to Perform
Environmental Qualification Testing on the Continental Cable
Used at Surry Station in Safety Related Areas
USNRC, 14-Sep-78
86. A. Schwencer
Letter to W. L. Proffitt, VEPCO Subject: Environmental
Qualification Testing on Continental Cable Used at the
Surry Power Station
USNRC, 12-Oct-78
87. A. Schwencer
Letter to W. L. Proffitt, VEPCO. Subject: Test Report of
Environmental Qualification Testing Performed on the
Continental Instrument Cable at Surry Power Station
USNRC, 22-Feb-79
88. A. Schwencer
Letter to W. L. Proffitt, VEPCO. Subject: Environmental
Testing on Continental Cable
USNRC, 18-Oct-78
89. A. Schwencer
Letter to W. L. Proffitt, VEPCO. Subject: Environmental
Qualification Testing on Continental Instrumentation Cable
Used at Surry Power Station
USNRC, 25-Jul-79
90. C. H. Stallings
Letter to H. R. Denton and A. Schwencer, NRC. Subject:
Cables Manufactured by Continental Wire and Cable Company;
with Attachments
Virginia Electric & Power Co., 14-Jul-78
Serial No. 401
91. P. S. Cardello
Letter to H. Redgate, S&W. Subject: VEPCO/Surry Generating
Station; Instrumentation Cable
Anaconda, 14-Jul-78

92. C. M. Stallings
Letter to D. G. Eisenhut, NRC. Subject: Environmental Qualification Testing on Certain Continental Cable Used at Surry Power Station; with Attachments
Virginia Electric & Power Co., 29-Sep-78
Serial 534/091473
93. R. Schaffer
Trip Report. Subject: LOCA and MSLB Tests on Instrument Cable; with Attachment
Virginia Electric & Power Co., 22-Nov-78
94. Qualification Review Package: Anaconda 600V EPR Insulated Cables, Surry Unit 1
NUS Corp., 13-Nov-81
QDR-5437-61-01, Rev. 1
95. T. H. Ling
Letter to J. Bonner, S&W. Subject: Surry Power Station, 600-Volt Power Cable; with Attachments
Anaconda Ericsson, 28-Oct-80
96. W. F. Priest
Certificate of Compliance
Anaconda Wire & Cable Co., 10-Dec-71
13433
97. T. H. Ling
Letter to I. MacFarlane, S&W. Subject: Surry Power Station, 600-Volt Power Cable
Anaconda Ericsson, 23-Feb-81
98. Qualification Review Package: Okonite 600V EPR Insulated Cables, Surry Unit 1
NUS Corp., 22-Oct-81
QDR-5437-62-01, Rev. 1
99. Qualification Review Package: Hydrogen Analyzer Surry Unit 1
NUS Corp., 17-Mar-82
QDR-5437-21201R
100. J. I. McNamara
Letter to R. Desmond, S&W. Subject: Proposal for Supply of Hydrogen Analysis Systems, with Attachments
Comsip, Inc., 25-Jan-80

101. Request for Additional Information: Equipment Environmental Qualification (EEQ); Review of Licensees' Resolution of Outstanding Issues from NRC Equipment Environmental Qualification Safety Evaluation Reports (SER) and TMI Action Plan Installed Equipment; Virginia Electric and Power Company, Surry Unit 1
FRC, 30-Nov-81

102. Request for Additional Information: Equipment Environmental Qualification (EEQ); Review of Licensees' Resolution of Outstanding Issues from NRC Equipment Environmental Qualification Safety Evaluation Reports (SER) and TMI Action Plan Installed Equipment; Virginia Electric and Power Company, Surry Unit 1; Revision 1
FRC, 07-Apr-82

103. Request for Additional Information: Equipment Environmental Qualification (EEQ); Review of Licensees' Resolution of Outstanding Issues from NRC Equipment Environmental Qualification Safety Evaluation Reports (SER) and TMI Action Plan Installed Equipment; Virginia Electric and Power Company, Surry Unit 1; Revision 2
FRC, 04-Jun-82

PLANT GENERIC REFERENCES

604. I. Rodens and R. H. DeLisle
Environmental Qualification of Class 1E Motors for
Nuclear Out-of-Containment Use
Westinghouse, 00-Jun-76
WCAP-8754
606. C. V. Fields
Fan Cooler Motor Unit Test
Westinghouse, 00-Apr-72
WCAP-7829
649. Qualification Tests of Solenoid Valves by Environmental Ex-
posure to Elevated Temperature, Radiation, Wear Aging, Seis-
mic Simulation, Vibration Endurance, Accident Radiation
Isomedix Inc., 00-Jul-79
AQS21678/TR, Rev. A, Proprietary
659. J. B. Drab
Limitorque Valve Actuator Qualification for Nuclear
Power Station Service
Limitorque Corp., 11-Jan-80
B0058
662. T. Hess, Jr.
Qualification Type Test Report: Limitorque Valve
Actuators for Class 1E Service Outside Primary
Containment in Nuclear Power Station Service
Limitorque Corp., 28-May-76
B0003
663. S. P. Carfagno, L. E. Witcher, and W. H. Steigelmann
Qualification Test of Limitorque Valve Actuator
in a Steam Environment
FIRL, 00-Feb-72
F-C3271, Proprietary
676. N. M. Burstein and L. E. Witcher
Qualification Tests of Electrical Cables Under Simulated
Reactor Containment Service Conditions Including
LOCA While Electrically Energized
FIRL, 00-Mar-74
F-C3798

687. A. E. Ellis and R. B. Miller
Environmental Qualification of Safety Related
Class 1E Process Instrumentation
Westinghouse, 00-Sep-77
WCAP-9157, Proprietary
706. W. Sykes
Test Report: Limitorque Valve Actuators for PWR Service
Limitorque Corp., 01-Dec-75
600456
712. Qualification Tests of Solenoid Valves by Environmental Exposure
to Elevated Temperature, Radiation, Wear Aging, Seismic Simulation,
Vibration Endurance, Accident Radiation
Isomedix Inc., 00-Mar-78
AQS21678/TR, Proprietary
959. L. E. Witcher and D. V. Paulson
Technical Report: Tests of Raychem Flamtrol (TM) Insulated
and Jacketed Electrical Cables under Simultaneous Exposure
to Heat, Gamma Radiation, Steam, and Chemical Spray
FIRL, 00-Jan-75
F-C4033-1
1049. G. Y. Chinn, W. C. Federick, F. J. Illig, and G. M. Rhodes
Design Qualification Material Test Report for Material Used
in Conax Electric Penetration Assemblies and Electric
Conductor Seal Assemblies
Conax Corp., 02-Nov-79
IPS-325, Rev. C, Proprietary
1110. G. S. Buettner and J. R. Marth
Qualification of Firewall III Class 1E Electric Cables
(Chemically Cross-Linked Insulation)
Rockbestos Co., 26-Nov-79
1167. G. C. Sorensen
Technical Report: Loss of Coolant Accident
Testing of Unitized Header Penetration Assemblies
Amphenol SAMS Div., 18-Jun-74
123-1247, Rev. A, Proprietary
1207. J. D. DePasquale
Test Report: Qualification Test Program of Electrical
Instrumentation Cables for Virginia Electric & Power Co.
for Surry Units 1 & 2
Conax Corp., 29-Nov-78
IPS-383

1218. E. R. Campbell
Qualification Test Report for Two Static O-Ring Pressure Switches
(Mod. No. 7828-100) for Yankee Atomic Electric Co.
Wyle Labs, 02-Nov-78
44296-2
1339. Test Report: Qualification of Okonite Ethylene-Propylene
Rubber Insulation of Nuclear Plant Service
Okonite Co., 07-Apr-77
NQRN-1
1340. D. V. Paulson and L. E. Witcher
Technical Report: Type Test Cable Qualification Program and
Data for Nuclear Plant Designed Life Simulation Through
Simultaneous Exposure
FIRL, 00-Jan-74
F-C3694
1347. L. E. Witcher, W. M. Denny, and D. V. Paulson
Technical Report: Tests of Electrical Cables Subjected to
Thermal Aging, Gamma Radiation, and a Loss-of-Coolant
Accident Simulation
FIRL, 00-Jul-76
F-C4350-3
1391. G. S. Buettner and J. R. Marth
Qualification of Firewall III, Class 1E
Electrical Cables
Rockbestos Co., 07-Jul-77
1417. S. P. Carfagno and R. J. Gibson
A Review of Equipment Aging Theory and Technology
EPRI, 00-Sep-80
NP-1558
1559. F. Cook
Summary Report: Nuclear Power Motor Systems Type Test
Support Analysis Random Wound Motors
Reliance Electric Co., 01-Jul-78
NUC-9
1571. J. F. Wilson
Electrical Hydrogen Recombiner for Water
Reactor Containment - Initial Development
Report for AEC/DRL
Westinghouse, 00-Jul-71
WCAP-7709-L, Proprietary

1572. J. F. Wilson
Electric Hydrogen Recombiner for PWR Containments:
Final Development Report
Westinghouse, 00-Apr-72
WCAP-7709-L, Supp. 1, Proprietary
1573. J. F. Wilson
Electric Hydrogen Recombiner for PWR
Containments: Equipment Qualification Report
Westinghouse, 00-Sep-73
WCAP-7709-L, Supp. 2, Proprietary
1574. J. F. Wilson
Electric Hydrogen Recombiner for PWR Containments:
Long Term Tests
Westinghouse, 04-Jan-74
WCAP-7709-L, Supp. 3, Proprietary
1575. J. F. Wilson
Electric Hydrogen Recombiner for
PWR Containments
Westinghouse, 00-Apr-74
WCAP-7709-L, Supp. 4, Proprietary
1576. J. F. Wilson
Electric Hydrogen Recombiner Special Tests
Westinghouse, 00-Dec-75
WCAP-7709-L, Supp. 5, Proprietary
1577. J. F. Wilson
Electric Hydrogen Recombiner: IEEE 323-1974 Qualification
Westinghouse, 00-Oct-76
WCAP-7709-L, Supp. 6, Proprietary
1578. J. F. Wilson
Electric Hydrogen Recombiner LWR Containments:
Supplemental Test No. 2
Westinghouse, 00-Aug-77
WCAP-7709-L, Supp. 7, Proprietary
1584. R. C. Sadlier
EEQ Test Program on One Electronic Transmitter,
One Pressure Transmitter, One D. P. Transmitter,
One Alphasine Transmitter for Bechtel Power Corp.
Wyle Labs, 12-Dec-78
26304, Proprietary



1617. C. Eicheldinger
Letter to D. B. Vassallo, NRC. Subject: Attached Report,
"Failure Mode Analysis for Safety Related Solenoid Valves
in an Accident Environment"
Westinghouse, 15-Aug-75
NS-CE-755
1691. Report of Seismic Test on SMBO-25 Motor Actuator for
Limatorque Corporation
Aero Nav Laboratories, Inc., 06-Jan-75
5720
1692. Report of Seismic Test on SMB-1 Motor Actuator for
Limatorque Corporation
Aero Nav Laboratories, Inc., 07-Jan-75
5722
1712. S. J. Franklin
Seismic Test Program Performed on Nine Solenoid Valves,
for Isomedix, Inc.
Dayton T. Brown, 07-Nov-77
DTBO4R77-1651RVA
1764. H. Nordeen
Qualification Test Report for Rosemount Pressure Transmitter
Model 1153 Series A
Rosemount Inc., 23-Mar-78
3788
1815. Raychem-Flamtrol (TM) Qualification to IEEE Standard 383
Raychem Corp., 10-Jun-76
1816. E. J. McGowan
The Effects of Radiation and Aging on Flamtrol (TM)
Insulated Wire
Raychem Corp., 08-Apr-72
EM 517A
1818. E. J. McGowan
Flamtrol, Pressure and Temperature Tests
Raychem Corp., 23-Apr-74
EM 974
1819. E. J. McGowan
Flamtrol - Air Pressure Heat Test
Raychem Corp., 19-Jun-74
EM 1000

1820. E. J. McGowan
Horizontal Flame Tests on Flamtrol (TM) Cable
Raychem Corp., 22-Sep-74
EM 1028
1821. E. J. McGowan
Flamtrol - High Temperature Voltage Withstand Tests
Raychem Corp., 24-Sep-74
EM 1030
1822. E. J. McGowan
Raychem Flamtrol (TM) - Elevated Temperature Water Immersion
- 2-3/4 Years (1000 Days)
Raychem Corp., 02-Oct-75
EM 1074
1823. E. J. McGowan
Vertical Flame Resistance Tests on Raychem-Flamtrol (TM)
Raychem Corp., 03-Dec-74
EM 1075B
1824. E. J. McGowan
Flamtrol - Coaxial Cables; Retest of FIRL Samples
Raychem Corp., 26-Sep-75
EM 1174A
1825. E. J. McGowan
Flamtrol: Vertical Tray-Gas Burner Flame Test
Raychem Corp., 17-Sep-75
EM 1188
1826. E. J. McGowan
Raychem Flamtrol (TM) - Flame Tests
Raychem Corp., 18-Sep-75
EM 1189
1827. E. J. McGowan and F. M. Ballew
Flamtrol - Vertical Tray Tests - 30% Cable Fill
Raychem Corp., 15-Dec-75
EM 1222
1828. E. J. McGowan and F. M. Ballew
Flamtrol - Horizontal Tray Tests - 30% Cable Fill
Raychem Corp., 17-Dec-75
EM 1224
1829. E. J. McGowan
Raychem Flamtrol (TM) - Heat Distortion
Raychem Corp., 21-Jan-76
EM 1236

1830. E. J. McGowan
Raychem-Flamtrol (TM) - Continuation of LOCA Test for
Qualification to IEEE Standard 383
Raychem Corp., 21-Jun-76
EM 1237
1831. E. J. McGowan and F. M. Ballew
Raychem-Flamtrol (TM) - Vertical Flame Tests
Raychem Corp., 04-Mar-76
EM 1238
1832. E. J. McGowan
Raychem-Flamtrol (TM) Coaxial and Triaxial Cable - Vertical
Flame Resistance
Raychem Corp., 04-Mar-76
EM 1239
1833. E. J. McGowan and F. M. Ballew
Raychem Flamtrol (TM) Oil-Rag and Vertical Tray-Gas Burner
Flame Tests
Raychem Corp., 17-Feb-76
EM 1240
1851. R. C. Myrick, J. J. Anderson, W. Franz, and A. Heeseman
Environmental Qualification Test Report of Raychem WCSF-N
Nuclear In-Line Cable Splice Assemblies for Raychem Corp.
Wyle Labs, 15-May-80
58442-1
2051. E. J. McGowan
The Effects of Radiation and Aging on a Coaxial Cable
Raychem Corp., 18-May-72
EM 518A
2070. R. Perez and M. Perez
Test Report: IEEE-323-1974 Qualification of Delphi IV
Hydrogen Analyzer as Manufactured by COMSIP DELPHI, INC.
Engineering Analysis & Test, 00-Dec-80
1035-1, Proprietary
2103. F. M. McAvoy
Aging, Exposure to 200 Megarads of Gamma Radiation and
Accident Condition Qualification Testing of Power Cables,
Control Cables and Splice
Okonite Co., 29-Feb-72
E. R. 141
2104. E. E. McIlveen, V. L. Garrison, and G. T. Dobrowolski
Class 1E Cables for Nuclear Power Generating Stations
IEEE, 16-Nov-73
T 74 044-4

2694. R. B. Blodgett and R. G. Fisher
Insulations and Jackets for Control and Power Cables in
Thermal Reactor Nuclear Generating Stations
IEEE Transactions, 00-May-69
Vol. PAS-88, No. 5
2818. S. P. Carfagno and L. E. Witcher
Technical Report: Test of Electrical Cables Under Simulated
Post-Accident Reactor Containment Service
FIRL, 00-Oct-70
F-C2935, Proprietary
2821. L. E. Witcher and W. H. Steigelmann
Technical Report: Test of Electrical Cables Under Simulated
Post-Accident Reactor Containment Service
FIRL, 00-Sep-70
F-C2857
2850. Qualification Specification for Automatic Switch Co. (ASCO)
of Florham Park, N. J. for Solenoid Valves
Isomedix Inc.,
AQS-21678/Rev. B
2852. R. F. Soltis
Report of Test on Limitorque Corporation SMBO Operator
W/Motor (40 ft. lb.) and Motor (25 ft. lb.)
Lockheed Electronics Co. Inc., 17-Jun-74
3521-4811
3001. R. C. Herrick and L. E. Witcher
Technical Report: Test of Electrical Cables Under Simulated
Post-Accident Reactor Containment Service
FIRL, 00-Jun-69
F-C2404-01
3190. G. C. Sorensen
Design Verification Test Report on Glass Filled Epoxy
Modules Unitized Header Electrical Penetration Assemblies
Amphenol SAMS Division, 05-May-72
123-1275
3411. L. S. Chapman and J. G. Stone
Tests of Electrical Cables After Simulated Post Accident
Reactor Containment Service, Supplement FIRL Report F-C2857
Cerro Wire & Cable, 00-Mar-71
NP-04
3569. Draft Interim Report of Flamtrol Thermal Aging Study
Raychem Corp., 00-Feb-76
Lab Rept. 5058

3582. Qualification of Firewall III Class 1E Electrical Cables;
Palo Verde Nuclear Generating Station
Rockbestos Co., 22-Jun-78
3752. Qualification Test of 300-hp Motor for Nuclear Power
Generating Station Service
FIRL, 00-Mar-73
F-C3519
3753. C. H. Kaplan
Report of Tests on Electric Motor 5K6319XJ1B
Stanford Techology Corp., 00-Nov-72
23711
3798. H. Nordeen
Qualification Test Report: Model 1152GP9 Pressure
Transmitter
Rosemount Inc., 23-Nov-76
117622, Rev. A
3830. J. R. Marth
Qualification of Firewall III Class 1E Electric Cables
Cerro Wire & Cables Co., 00-May-76
3836. T. M. Anderson
Letter to J. F. Stolz, NRC. Subject: Transmittal of Report
"Qualification Testing of Barton Pressure and Differential Pressure
Transmitters"
Westinghouse, 29-Sep-78
NS-TMA-1950, Proprietary
4005. D. D. Yue
Technical Report: Special Prototype Radiation, Environmental
and Short Circuit Testing of a Type 2 Low Voltage Power
Penetration Assembly Used on Davis-Besse Nuclear Station
Amphenol SAMS Division, 12-Mar-75
123-1268
4019. L. E. Witcher and N. M. Burstein
Technical Report: Qualification Testing of Electrical
Cables Under Simulated Reactor Containment Service Condition
and Loss of Coolant Accident
FIRL, 00-Jul-72
F-C3306-01
4447. J. R. Bendokaitis
Qualification of EA180 Series Limit Switches for Use in
Nuclear Power Plants in Compliance with IEEE Standards
323-1974, 382-1972, and 344-1975
NAMCO Controls, 20-Aug-81
QTR-105, Rev. 3

5212. D. M. Mullen
Equipment Qualification for Class 1E Safety Related Service
in Power Generation Stations Outside Containment Random
Wound Motors
Siemens-Allis, Inc., 27-Jan-82
NQ90352-1, Rev. 1
5213. Equipment Qualification - Random Wound Motors (for Class 1E
Safety-Related Service)
Siemens-Allis, Inc., 06-Dec-79
90352-01
5216. J. Sikorcin
Qualification Test Report: Type Test Qualification Program
for Electric Damper Operators Used on the Taiwan - Kuosheng
Nuclear Power Plant
Raymond Control Systems, 13-Dec-79
5217. Type Test Qualification Procedure for Electric Damper
Operators; Taiwan - Kuosheng Nuclear Power Station
Raymond Control Systems, 31-Mar-78
50558-QTP, Rev. A
5218. R. A. Hall and E. R. Campbell
Qualification Test Report on Two Electric Actuators
Model MAR-49-30-4 & MAR-160-30-4 for Raymond Control Systems
Wyle Labs, 04-Oct-79
44235-2
5261. R. J. Gehm and K. J. Giannattoi
Qualification of Firewall III Class 1E Electric Cables
(Chemically Cross-Linked Insulation)
Rockbestos Co., 23-Dec-80
5264. E. J. McGowan
The Effects of Radiation on Flamtrol at Elevated
Temperatures
Raychem Corp., 11-Jul-74
EM 1010
5265. F. E. LaFetra
Service Life Simulation
Raychem Corp.
5284. ~~Design Qualification Test Report on Glass Reinforced Epoxy
Modules and Unitized Header Electric Penetration Assemblies
for Davis-Besse Nuclear Power Station Unit No. 1
Amphenol SAMS Division, 15-Apr-75
123-2033, Rev. 1~~

5285. B. Bernert
Stress and Strain Analysis of Glass Reinforced Epoxy Modules
Under Short Circuit Test Conditions for Electric Penetration
Assemblies Used in Nuclear Power Plants
Amphenol SAMS Division, 18-Jun-74
W-15-61, Rev. 1
5286. D. D. Yue
Special Prototype Radiation, Environmental and Short Circuit
Testing of a Type 1A Medium Voltage Power Penetration
Assembly Used on Davis-Besse Nuclear Power Station Unit 1
Amphenol SAMS Division, 07-Mar-75
123-1269
5287. G. C. Sorensen
Technical Report: Loss of Coolant Accident Testing of
Unitized Header Penetration Assemblies
Amphenol SAMS Division, 00-Apr-73
123-1247, Proprietary
5288. D. D. Yue
Special Prototype Radiation and Environmental (LOCA) Tests
of Medium and Low Voltage Electric Penetration Assembly Used
on Arkansas Nuclear One Unit 2
Amphenol SAMS Division, 28-Mar-75
123-2045, Rev. A
5310. Environmental Qualification of Class 1E Motors for Nuclear
Out-of-Containment Use
Westinghouse
WCAP-8754, Rev. 1
5329. R. J. Crowell
Environmental Test Report: Hermetic Feed Through Connector
Type 1A, 19/C-No. 16 AWG and Mating Plugs Used on Electrical
Penetrations at the Surry Power Station
D. G. O'Brien, 28-Feb-72
C19QA061

APPENDIX A - ENVIRONMENTAL SERVICE CONDITIONS

The specific environmental service conditions corresponding to different plant locations that were used in this technical evaluation are stated in this appendix, based upon the information presented in the Licensee's submittal [17, 19].

Accident Conditions Inside Primary Containment

For PWR plants, the DOR Guidelines state that the environmental service conditions inside containment for the loss-of-coolant accident (LOCA) should be established by the Licensee based on the FSAR analysis. In addition, for plants equipped with automatic containment spray systems not subject to single component failure or delayed initiation, the Guidelines state that equipment qualified for the LOCA environment is also considered qualified for the postulated main-steam-line break accident (MSLB). The design of this plant satisfies these criteria. The Licensee has stated that equipment qualified for a LOCA environment can be considered qualified for a MSLB accident environment.

The temperature and pressure profiles contained herein form the basis for the temperature and pressure noted by the Licensee in the "Environment Required" column on the Licensee's Equipment Qualification Report Evaluation sheets.

This appendix contains the following environmental information [19]:

- Figure A-1. Auxiliary Building Penetration Area, Elev. 2'0"
- Figure A-2. Auxiliary Building Charging Pump Cubicles, Elev. 2'0"
- Figure A-3. Auxiliary Building, General, Elev. 13'0"
- Figure A-4. Auxiliary Building Cable Vault, Elev. 13'0"
- Figure A-5. Auxiliary Building, General, Elev. 27'6" (excluding cont. vacuum pump cubicles)

- Figure A-6. Auxiliary Building, General, Elev. 45'10"
- Figure A-7. Containment Spray Pump House, Elev. 11'6"
- Figure A-8. Containment Spray Pump House, Elev. 27'6"
- Figure A-9. Main Steam Valve House, General, Elev. 11'6"
- Figure A-10. Main Steam Valve House, General, Elev. 27'6"
- Figure A-11. Containment Inside Cranewall, Elev. (-)3'6"
- Figure A-12. Containment Outside Cranewall, Elev. (-)3'6"
- Figure A-13. Containment Outside Cranewall, Elev. 18'4"
- Figure A-14. Containment, General, Elev. (-)27'7"
- Figure A-15. Containment, Elev. (-)27'7" Submerged (Below (-)21'11")
- Figure A-16. Containment Inside Cranewall, Elev. 47'4"
- Figure A-17. Containment Outside Cranewall, Elev. 47'4"
- Figure A-18. Mechanical Equipment Room 3
- Figure A-19. Safeguards Area
- Figure A-20. Turbine Building, General, Elev. 9'6"
- Figure A-21. Turbine Building, Mezzanine Level
- Figure A-22. Environmental Qualification of Electrical Equipment Zone Key Plan.

Based on these considerations, each equipment item was evaluated with respect to the environmental service conditions presented in this appendix.

The Licensee's methodology for the development of environmental service conditions was stated in Reference 19 as follows:

"The Environmental Zone Description (EZD) documents the specification of parameters for environmentally harsh areas of the Surry Power Station Units 1 & 2 which contain safety-related equipment (IE Bulletin 79-01B). These areas have been ascribed environmental zones which possess more or less uniform environments relating to temperature, pressure, relative humidity, chemical spray, radiation, and submergence. As applicable for each environmental zone, the environmental parameters are specified for normal operation as well as LOCA, MSLB, and HELB conditions.

In certain instances, it was desirable to determine for specific plant components and environmental parameters a specification for an area contained within an environmental zone (i.e., temperature stratification and radiation zones).

Each environmental zone is described on a zone sheet (EZD pages 3 through 23). Reference numbers appearing on the zone sheets are identified by the reference list (EZD pages 24 through 25). The reference list also identifies secondary references which support/supplement the primary references. A copy of each of both types of references is provided in the succeeding volumes of the EZD.

Primary references have numerical tabs which correspond to their respective reference numbers, whereas secondary references have alphabetical tabs. Immediately preceding each primary reference is one or more pages of the user's guide; the user's guide identifies the specific pages of each primary reference where information from the zone sheet can be located."

With respect to primary containment service conditions, the Licensee stated [17]:

"A description of the containment spray systems at Surry is provided in Section 6.3.1.4 of the Surry FSAR. This system contains redundant 100% capacity trains which are not subjected to a disabling single-component failure."

The Licensee also provided the following response with respect to temperature margins applied to the primary containment accident profile [17]:

"Stratification would only be present for a short time period (since the containment spray system becomes effective within 100 seconds) following a LOCA or MSLB. The spray delivery to the upper regions of the containment would quickly cool the stratified region.

No safety-related electrical equipment is located in the upper third of the containment volume. This precludes any equipment from being exposed to a higher-than-average temperature due to stratification in the upper regions of the containment following a LOCA or MSLB.

Even if safety related electrical equipment were located in the upper third of the containment volume, the computer codes and models used to calculate the maximum containment average temperature of 278°F for LOCA contain significant conservatisms such that the calculated temperature is an overprediction of the expected average temperature. These conservatisms include:

- (1) the blowdown model, which maximizes release rates to the containment
- (2) overprediction of the energy available for release to the containment

- (3) underprediction of the containment heat sinks and containment volume
- (4) assuming the most severe containment initial conditions
- (5) minimizing containment spray heat removal
- (6) the modeling of the behavior of the break effluent to maximize the containment pressure and temperature.

The combination of all these factors results in calculated containment pressure and temperature transients which are substantially greater than expected values. Therefore, there is sufficient margin in the calculated temperature to account for stratified regions of higher-than-average temperatures for an MSLB.

Stratification of steam in the upper regions of the containment is not expected to occur after a LOCA. The location of the break is below the operating floor in the lower portion of the containment. The high, subcooled liquid blowdown rates will result in a high degree of mixing which will prevent the accumulation of stratified steam.

A sample of the methodology used to determine the inside containment LOCA profiles can be found in the Environmental Zone Descriptions for Surry Power Station behind Reference Tab #2.¹

¹A copy of the Environmental Zone Descriptions (EZD) Surry Power Stations Units 1 and 2 are provided with the SER response."

With regard to submergence inside containment, the Licensee stated [17]:

"1. Inside Reactor Containment Building

The methodology used to determine the submergence level inside containment is provided for your review in the Environmental Zone Descriptions for Surry Power Station behind Reference Tab #6. This methodology is in accordance with the requirements of I.E. Bulletin 79-01B.

The maximum fluid level in the calculation is elevation -21'11".to which all components were reviewed. The 6 motor operated valves (MOV 1865 A, B, C and MOV 2865 A, B, C) are below the submergence level.

These motor operated valves have been removed from the master list. The valves serve to isolate the safety injection accumulator tanks during refueling. They are administratively locked open whenever the reactor is critical by locking out the breakers that supply power to the valves. The valves will then remain in their locked open position and available to mitigate the consequences of a LOCA

or MSLB. No power is supplied to these motor operated valves during critical operation; therefore, there can be no adverse effects to the electrical bus which normally supplies power to the valves. There is no position indication on these valves, thus the operator cannot be misled due to the submergence of the valves. Since the valves are locked open, the question of operating time across the spectrum of events in relation to submergence need not be addressed."

With regard to submergence outside containment, the Licensee stated [17]:

"2. Outside Reactor Containment Building

Submergence outside of containment was not specifically addressed during the I.E. Bulletin 79-01B 90 Day Review. The effects of piping system breaks outside of containment was analyzed in Appendix D of the Surry FSAR. This review takes into account the effects of discharging fluids that may result in failure of equipment important to safety.

A detailed review of the effects of flooding on equipment important to safety is provided in the North Anna FSAR Appendix C, Effects of Piping System Breaks Outside Containment. The Auxiliary Building was the only area affected by the postulated high-energy line breaks with regard to submergence. The maximum water level in the Auxiliary Building is 1 inch above the floor. All equipment important to safety was found to be at least 15 inches above the floor.

A similar review of the effects of flooding was not done for Surry. We can determine for Surry, however, that no equipment outside of containment important to safety will become submerged due to the postulated pipe breaks because of the similarity in design of the piping systems, the Auxiliary Building layout, and equipment location for North Anna and Surry.

Since we have determined that there is no equipment outside containment that would be subjected to submergence due to a LOCA or HELB, the submergence column on the Component Evaluation Sheet has been marked Not Required (NR)."

With regard to chemical spray, the Licensee stated [17]:

"The component evaluation sheets have been revised to show consistent units for chemical spray concentration. Each component on the master list which is subjected to chemical sprays has been reviewed to ensure that the chemical spray environment in the test report envelops the specified chemical spray environment. The results of the review are indicated on the worksheets included in Revision 4 of the IE Bulletin 79-01B 90 Day Review. Specific chemical spray deficiencies which were identified in Appendix B have also been reviewed and resolutions to these deficiencies are indicated on the Revision 4 component evaluation worksheets.

Details of the qualification review for chemical spray can be found in the qualification review packages contained in the central file."

With respect to radiation values inside primary containment, the Licensee stated [17]:

"The calculated total integrated gamma radiation doses inside containment range from 7.4×10^6 to 3.8×10^7 rads, depending on the location of the dose points. They are shown in Table 2. The radiation doses were calculated based on power level of 2546 MW thermal and containment free volume of 1.8×10^6 ft³. The shielding credit of crane wall and operating floor was taken into consideration. A sample calculation is provided in the Environmental Zone Descriptions for Surry Power Station behind Reference Tab #3.

TABLE 2

40-year normal plus LOCA gamma dose inside containment

<u>Location</u>		<u>Dose (rads)</u>
el. 47'4"	- Inside crane wall	3.7×10^7
el. 47'4"	- Outside crane wall	7.4×10^6
el. 18'4"	- Outside crane wall	7.4×10^6
el. (-) 3'6"	- Inside crane wall	3.7×10^7
el. (-) 3'6"	- Outside crane wall	7.4×10^6
el. (-)27'7"	- Above sump water	3.5×10^7
el. (-)27'7"	- Submerged in sump water	3.8×10^7

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: AB-2B
 DESCRIPTION: Auxiliary Building Penetration Area, Elev. 2'0"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	14	NA	_____	NA	_____	120-205F, 0-30 secs 205F, 30-40 secs 205-190F, 40-1000 secs 190-145F, 1000-2000 secs 145-120F, 2000 secs-1 hr	4
PRESSURE (psia)	NA	_____	NA	_____	NA	_____	15.2, 0-1 min 14.9, 1-60 min	4
RELATIVE HUMIDITY (%)	NC	_____	NA	_____	NA	_____	100	4
CHEMICAL SPRAY	NA	_____	NA	_____	NA	_____	NA	_____
RADIATION (rads)	2.5 x 10 ⁶	7	2.5 x 10 ⁶	7	NA	_____	NA	_____
SUBMERGENCE (elev)	NA	_____	NA	_____	NA	_____	Note	_____

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

NOTE: Not applicable. No safety-related electrical equipment will be affected by the submergence level at the 2'0" elevation of the Auxiliary Building.

Figure A-1. Auxiliary Building Penetration Area, Elev. 2'0"

FIGURE SUPPLIED BY THE LICENSEE.

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: AB-2C
 DESCRIPTION: Auxiliary Building Charging Pump Cubicles, Elev. 2'0"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Normally un-occupied machinery spaces, 120F	94	NA	_____	NA	_____	120-140F, 0-30 secs 140F, 30-1000 secs 140-125F, 1000-2000 secs 125-120F, 2000 secs-1 hr	4
PRESSURE (psia)	NA	_____	NA	_____	NA	_____	15.2, 0-1 min 14.9, 1-60 min	4
RELATIVE HUMIDITY (%)	NC	_____	NA	_____	NA	_____	100	4
CHEMICAL SPRAY	NA	_____	NA	_____	NA	_____	NA	_____
RADIATION (rads)	2.8 x 10 ⁶	7	8.0 x 10 ⁶	7	NA	_____	NA	_____
SUBMERGENCE (elev)	NA	_____	NA	_____	NA	_____	NOTE	_____

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

NOTE: Not applicable. No safety related electrical equipment will be affected by the submergence level at the 2'0" elevation of the Auxiliary Building.

Figure A-2. Auxiliary Building Charging Pump Cubicles, Elev. 2'0"

FIGURE SUPPLIED
BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: AB-13A
 DESCRIPTION: Auxiliary Building, General, Elev. 13'0"

PARAMETER	NORMAL ENVIRONMENT	REFERENCE	LOCA ENVIRONMENT	REFERENCE	MSLB ENVIRONMENT	REFERENCE	HELB ENVIRONMENT	REFERENCE
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	14	NA	_____	NA	_____	120-205F, 0-30 secs 205F, 30-40 secs 205-190F, 40-1000 secs 190-145F, 1000-2000 secs 145-120F, 2000 secs-1hr	4
PRESSURE (psia)	NA	_____	NA	_____	NA	_____	15.2, 0-1 min 14.9, 1-60 min	4
RELATIVE HUMIDITY (%)	NC	_____	NA	_____	NA	_____	100	4
CHEMICAL SPRAY	NA	_____	NA	_____	NA	_____	NA	_____
RADIATION (rads)	NOTE	10	9.3 x 10 ⁶	10	NA	_____	NA	_____
SUBMERGENCE (elev)	NA	_____	NA	_____	NA	_____	NA	_____

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

NOTE: The radiation dose of 2.66x10⁷ for the 40-yr normal operation in zone AB-13A is caused by the primary drain tank and gas stripper located in radiation zone Q (Units 1 & 2). The radiation dose is calculated to be 4.87x10³ in radiation zones O (Unit 1) and N (Unit 2) and 1.40x10⁵ in radiation zones T (Unit 1) and S (Unit 2).

Figure A-3. Auxiliary Building, General, Elev. 13'0"

FIGURE SUPPLIED BY THE LICENSEE

A-9

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: AB-13B
 DESCRIPTION: Auxiliary Building Cable Vault, Elev. 13'0"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Normally un-occupied machinery spaces, 120F	74	NA	_____	NA	_____	NA	_____
PRESSURE (psia)	NA	_____	NA	_____	NA	_____	NA	_____
RELATIVE HUMIDITY (%)	NC	_____	NA	_____	NA	_____	NA	_____
CHEMICAL SPRAY	NA	_____	NA	_____	NA	_____	NA	_____
RADIATION (rads)	1.96 x 10 ⁶	10	3.2 x 10 ⁶	10	NA	_____	NA	_____
SUBMERGENCE (elev)	NA	_____	NA	_____	NA	_____	NA	_____

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-4. Auxiliary Building Cable Vault, Elev. 13'0"

FIGURE SUPPLIED
 BY THE LICENSEE

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
Units: 1 and 2
Dockets: 50-280 and 50-281

ZONE: AB-27

DESCRIPTION: Auxiliary Building, General Elev. 27'6" [excluding cont. vacuum pump cubicles]

PARAMETER	NORMAL	REFERENCE	LOCA	REFERENCE	MSLB	REFERENCE	HELB	REFERENCE
	ENVIRONMENT		ENVIRONMENT		ENVIRONMENT		ENVIRONMENT	
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	14	NA		NA		120-205F, 0- 30 secs 205F, 30-40 secs 205-190F, 40-1000 secs 190-145F, 1000-2000 secs 145-120F, 2000 secs-1 hr	4
PRESSURE (psia)	NA		NA		NA		15.2, 0-1 min 14.9, 1-60 min	4
RELATIVE HUMIDITY (%)	NC		NA		NA		100	4
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	1.3 x 10 ⁶	10	6.8 x 10 ²	10	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-5. Auxiliary Building, General, Elev. 27'6" (excluding cont. vacuum pump cubicles)

FIGURE SUPPLIED
BY THE LICENSEE

A-11

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: AB-45
 DESCRIPTION: Auxiliary Building, General, Elev. 45'10"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	14	NA		NA		120-125F, 0-300 secs 125-122F, 300-2000 secs 122-120F, 2000 secs-1 hr	4
OPRESSURE (psia)	NA		NA		NA		15.2, 0-1 min 14.9, 1-60 min	4
RELATIVE HUMIDITY (%)	NC		NA		NA		100	4
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	1.1×10^5	10	2.7×10^5	10	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-6. Auxiliary Building, General, Elev. 45'10" **FIGURE SUPPLIED BY THE LICENSEE**

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
Units: 1 and 2
Dockets: 50-280 and 50-281

ZONE: CSPH-11
DESCRIPTION: Containment Spray Pump House, Elev. 11'6"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	10	NA		NA		NA	
PRESSURE (psia)	NA		NA		NA		NA	
RELATIVE HUMIDITY (%)	NC		NA		NA		NA	
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	8.8×10^2	11	5.9×10^6	11	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-7. Containment Spray Pump House, Elev. 11'6"

FIGURE SUPPLIED BY THE OPERATOR

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: CSPH-27
 DESCRIPTION: Containment Spray Pump House, Elev. 27'6"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100°F Normally un-occupied machinery spaces, 120°F	14	NA		NA		NA	
PRESSURE (psia)	NA		NA		NA		NA	
RELATIVE HUMIDITY (%)	NC		NA		NA		NA	
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	8.6 x 10 ⁻²	11	5.3 x 10 ⁻²	11	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-8. Containment Spray Pump House, Elev. 27'6"

FIGURE SUPPLIED
 BY THE LICENSEE

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
Units: 1 and 2
Dockets: 50-280 and 50-281

ZONE: MSVH-11
DESCRIPTION: Main Steam Valve House, General, Elev. 11'6"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Normally un-occupied machinery spaces, 120F	14	NA		NA		NA	
PRESSURE (psia)	NA		NA		NA		NA	
RELATIVE HUMIDITY (%)	NC		NA		NA		NA	
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	8.8 x 10 ²	11	5.9 x 10 ⁶	11	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-9. Main Steam Valve House, General, Elev. 11'6"

FIGURE SUPPLIED
BY THE LICENSEE

A-15

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: MSVH-27
 DESCRIPTION: Main Steam Valve House, General, Elev. 27'6"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Normally un-occupied machinery spaces, 120F	14	NA		NA		Note	12
PRESSURE (psia)	NA		NA		NA		16.5, 0-10 sec 16.2, 10 sec- 1 hr	12
RELATIVE HUMIDITY (%)	NC		NA		NA		100	12
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	8.8 x 10 ²	11	1.7 x 10 ⁴	11	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

NOTE: The HELB temperature of 300°F (0-1 hr) was calculated for environmental zone MSVH-27 which extends from elevation 27'6" to the roof. The HELB temperature for equipment located between elevations 27'6" and 38'0" is calculated to be 250°F (0-1 hr).

Figure A-10. Main Steam Valve House, General, Elev. 27'6"

FIGURE SUPPLIED
BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-3A
 DESCRIPTION: Containment Inside Cranewall, Elev. (-)3'6"

PARAMETER	NORMAL ENVIRONMENT		LOCA ENVIRONMENT		MSLB ENVIRONMENT		HELB ENVIRONMENT	
		REFERENCE		REFERENCE		REFERENCE		REFERENCE
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2		NA
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2		NA
RELATIVE HUMIDITY (%)	NC		100, 0-120 days	2	100, 0-120 days	2		NA
CHEMICAL SPRAY	NA		Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2		NA
RADIATION (rads)	1.3 x 10 ⁷	3	≤2.4 x 10 ⁷	3	<2.4 x 10 ⁷	3,5		NA
SUBMERGENCE (elev)	NA		NA		NA			NA

NA = Not applicable. NC = Not calculated. Numbers appearing in reference columns are identified at the end of this section.

Figure A-11. Containment Inside Cranewall, Elev. (-)3'6"

FIGURE SUPPLIED BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-3B
 DESCRIPTION: Containment Outside Cranewall, Elev. (-)3'6"

PARAMETER	NORMAL ENVIRONMENT	REFERENCE	LOCA ENVIRONMENT	REFERENCE	MSLB ENVIRONMENT	REFERENCE	HELB ENVIRONMENT	REFERENCE
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 2 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days		280F, 0-30 min 2 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days		NA	
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 2 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days		59.7, 0-30 min 2 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days		NA	
RELATIVE HUMIDITY (%)	NC		100, 0-120 days 2		100, 0-120 days 2		NA	
CHEMICAL SPRAY	NA		Solution of 2 2000-2200 ppm H ₃ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days		Solution of 2 2000-2200 ppm H ₃ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days		NA	
RADIATION (rads)	3.5 x 10 ⁶	3	7.4 x 10 ⁶	3	<7.4 x 10 ⁶	3,5	NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-12. Containment Outside Cranewall, Elev. (-)3'6"

FIGURE SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-18B
 DESCRIPTION: Containment Outside Cranewall, Elev. 18'4"

PARAMETER	NORMAL ENVIRONMENT		LOCA ENVIRONMENT		MSLB ENVIRONMENT		HELB ENVIRONMENT	
		REFERENCE		REFERENCE		REFERENCE		REFERENCE
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2		NA
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2		NA
RELATIVE HUMIDITY (%)	NC		100, 0-120 days	2	100, 0-120 days	2		NA
CHEMICAL SPRAY	NA		Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2		NA
RADIATION (rads)	3.5 x 10 ⁶	3	7.4 x 10 ⁶	3	<7.4 x 10 ⁶	3,5		NA
SUBMERGENCE (elev)	NA		NA		NA			NA

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-13. Containment Outside Cranewall, Elev. 18'4"

FIGURE SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-27A
 DESCRIPTION: Containment General, Elev. (-)27'7"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Design, 105F Maximum, 125F	95 1	280F, 0-30 min 2 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days		280F, 0-30 min 2 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days		NA	
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 2 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days		59.7, 0-30 min 2 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days		NA	
RELATIVE HUMIDITY (%)	NC		100, 0-120 days 2		100, 0-120 days 2		NA	
CHEMICAL SPRAY	NA		Solution of 2 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days		Solution of 2 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days		NA	
RADIATION (rads)	3.5 x 10 ⁶	3	3.5 x 10 ⁷	3	<3.5 x 10 ⁷	3,5	NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-14. Containment, General, Elev. (-)27'7"

FIGURE SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-27B*

DESCRIPTION: Containment, Elev. (-)27'7" Submerged (Below (-)21'11")

PARAMETER	NORMAL	REFERENCE	LOCA	REFERENCE	MSLB	REFERENCE	HELB	REFERENCE
	ENVIRONMENT		ENVIRONMENT		ENVIRONMENT		ENVIRONMENT	
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	NA	
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	NA	
RELATIVE HUMIDITY (%)	NC		100, 0-120 days	2	100, 0-120 days	2	NA	
CHEMICAL SPRAY	NA		Solution of 2000-2200 ppm H ₃ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	Solution of 2000-2200 ppm H ₃ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	NA	
RADIATION (rads)	3.5 x 10 ⁴	3	3.8 x 10 ⁷	3	<3.8 x 10 ⁷	3,5	NA	
SUBMERGENCE (elev)	NA		(-)21'11"	6	(-)21'11"	6	NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

* No safety-related electrical equipment is contained in environmental zone RC-27B.

Figure A-15. Containment, Elev. (-)27'7" Submerged (Below (-)21'11")

ORIGINAL SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-47A
 DESCRIPTION: Containment Inside Cranewall, Elev. 47'4"

PARAMETER	NORMAL ENVIRONMENT		LOCA ENVIRONMENT		MSLB ENVIRONMENT		HELB ENVIRONMENT	
		REFERENCE		REFERENCE		REFERENCE		REFERENCE
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2		NA
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2		NA
RELATIVE HUMIDITY (%)	NC		100, 0-120 days	2	100, 0-120 days	2		NA
CHEMICAL SPRAY	NA		Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2		NA
RADIATION (rads)	<1.3 x 10 ⁷	3	2.4 x 10 ⁷	3	<2.4 x 10 ⁷	3,5		NA
SUBMERGENCE (elev)	NA		NA		NA			NA

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-16. Containment Inside Cranewall, Elev. 47'4"

FIGURE SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: RC-47B
 DESCRIPTION: Containment Outside Cranewall, Elev. 47'4"

PARAMETER	NORMAL ENVIRONMENT		LOCA ENVIRONMENT		MSLB ENVIRONMENT		HELB ENVIRONMENT	
		REFERENCE		REFERENCE		REFERENCE		REFERENCE
TEMPERATURE (°F)	Design, 105F Maximum, 125F	15 1	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2	280F, 0-30 min 280-150F, 30-60 min 150-120F, 1-48 hr 120F, 2-120 days	2 2		NA
PRESSURE (psia)	9.0-11.1	1	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2	59.7, 0-30 min 59.7-14.7, 30-60 min 14.7-12.7, 1-48 hr 12.7, 2-120 days	2 2		NA
RELATIVE HUMIDITY (%)	NC		100, 0-120 days	2	100, 0-120 days	2		NA
CHEMICAL SPRAY	NA		Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2	Solution of 2000-2200 ppm H ₂ BO ₃ buffered with NaOH to pH of 8.5-11, 0-4 hr Same solution with pH of between 8.0 and 9.5, 4 hr-120 days	2		NA
RADIATION (rads)	3.5 x 10 ⁶	3	7.4 x 10 ⁶	3	<7.4 x 10 ⁶	3,5		NA
SUBMERGENCE (elev)	NA		NA		NA			NA

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-17. Containment Outside Cranewall, Elev. 47'4"

FIGURE SUPPLIED
 BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: SB-9B
 DESCRIPTION: Mechanical Equipment Room 3

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	10	NA		NA		310F, 0-30 min 8 310-130F, 30-60 min	
PRESSURE (psia)	NA		NA		NA		15.0	8
RELATIVE HUMIDITY (%)	NC		NA		NA		100	8
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	<2500	11	<2500	13	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-18. Mechanical Equipment Room 3

FIGURE SUPPLIED
 BY THE LICENSEE

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
Units: 1 and 2
Dockets: 50-280 and 50-281

ZONE: SFGD-1
DESCRIPTION: Safeguards Area

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELB ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	14	NA		NA		NA	
PRESSURE (psia)	NA		NA		NA		NA	
RELATIVE HUMIDITY (%)	NC		NA		NA		NA	
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	8.8 x 10 ²	7	8.0 x 10 ⁶	9	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-19. Safeguards Area

FIGURE SUPPLIED
BY THE LICENSEE

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: TS-9
 DESCRIPTION: Turbine Building, General, Elev. 9'6"

<u>PARAMETER</u>	<u>NORMAL ENVIRONMENT</u>	<u>REFERENCE</u>	<u>LOCA ENVIRONMENT</u>	<u>REFERENCE</u>	<u>MSLB ENVIRONMENT</u>	<u>REFERENCE</u>	<u>HELD ENVIRONMENT</u>	<u>REFERENCE</u>
TEMPERATURE (°F)	Occupied spaces, 80°F Normally un-occupied machinery spaces, 120°F	14	NA		NA		310°F, 0-30 min @ 310-330°F, 30-60 min	
PRESSURE (psia)	NA		NA		NA		15.0	0
RELATIVE HUMIDITY (%)	NC		NA		NA		100	0
CHEMICAL SPRAY	NA		NA		NA		NA	
RADIATION (rads)	<2500	11	<2500	13	NA		NA	
SUBMERGENCE (elev)	NA		NA		NA		NA	

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-20. Turbine Building, General, Elev. 9'6"

**FIGURE SUPPLIED
 BY THE LICENSEE**

TER-C5257-482

ENVIRONMENTAL ZONE DESCRIPTION SHEET

Facility: VEPSCO, SURRY
 Units: 1 and 2
 Dockets: 50-280 and 50-281

ZONE: TB-35
 DESCRIPTION: Turbine Building, Mezzanine Level

PARAMETER	NORMAL ENVIRONMENT	REFERENCE	LOCA ENVIRONMENT	REFERENCE	MSLB ENVIRONMENT	REFERENCE	MSLB ENVIRONMENT	REFERENCE
TEMPERATURE (°F)	Occupied spaces, 100F Normally un-occupied machinery spaces, 120F	10	NA	_____	NA	_____	310F, 0-30 min 330-330F, 30-60 min	8
PRESSURE (psia)	NA	_____	NA	_____	NA	_____	15.0	8
RELATIVE HUMIDITY (%)	NC	_____	NA	_____	NA	_____	100	8
CHEMICAL SPRAY	NA	_____	NA	_____	NA	_____	NA	_____
RADIATION (rads)	<2500	11	<2500	13	NA	_____	NA	_____
SUBMERGENCE (elev)	NA	_____	NA	_____	NA	_____	NA	_____

NA = Not applicable. NC = Not calculated. Numbers appearing in Reference columns are identified at the end of this section.

Figure A-21. Turbine Building, Mezzanine Level

**FIGURE SUPPLIED
BY THE LICENSEE**




Figure A-22. Environmental Qualification of Electrical Equipment Zone Key Plan

FIGURE SUPPLIED
BY THE LICENSEE

TER-C5257-482

APPENDIX B - LISTING OF SAFETY-RELATED ELECTRICAL EQUIPMENT

The following table lists the groupings of safety-related electrical equipment items for Surry Power Station Unit 1. Equipment items provided in the table are used in the detailed equipment environmental qualification evaluation presented in Section 4.4 and summarized in Section 4.2. This table was generated from the lists of equipment provided by the Licensee [14, 17].

The Licensee identified an extensive list of safety-related electrical equipment in various locations of the plant. The equipment listed by the Licensee was analyzed, and all identical equipment located within plant areas that are exposed to the same environmental service conditions was grouped together and designated an "equipment item." In this report, the term "equipment item" refers to a specific type of electrical equipment, designated by manufacturer and model, which is representative of all identical equipment in a plant area exposed to the same environmental service conditions (e.g., Flow Transmitter, Fischer & Porter, Model 10B2496, located within containment). This analysis resulted in a reduced listing of equipment (equipment items) that formed the basis for the review. This appendix contains the tabulation of the equipment items, locations, function, plant identification numbers, required operating time, and applicable qualification documentation references.

EQUIPMENT ITEM NO. 1
PRESSURE TRANSMITTER LOCATED IN THE AUXILIARY BUILDING (AB-13A)
FISCHER AND PORTER MODEL 50EN1071BCXA
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 1
LICENSEE REFERENCE(S): 687
FUNCTION (PLANT ID): REACTOR CONTAINMENT PRESSURE (PT-LM-100A, B, C, D)
LICENSEE SUBMITTAL: SCEW(S): 6-116 TO -119

EQUIPMENT ITEM NO. 2
PRESSURE TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL
FISCHER AND PORTER MODEL 10B2496QBXA NS
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 2
LICENSEE REFERENCE(S): 687
FUNCTION (PLANT ID): PRESSURIZER PRESSURE INDICATION AND HIGH/LOW PROTECTION,
(PT-1455, -1456, -1457)
LICENSEE SUBMITTAL: SCEW(S): 6-174 TO -176

EQUIPMENT ITEM NO. 3
PRESSURE TRANSMITTER LOCATED IN THE SAFEGUARDS AREA
FISCHER AND PORTER MODEL 50EP1031BCXA
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 3
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): OUTSIDE R.S. PUMP DISCHARGE (PT-RS-156A, B)
LICENSEE SUBMITTAL: SCEW(S): 6-272, -273

EQUIPMENT ITEM NO. 4
PRESSURE TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
ROSEMOUNT MODEL 1153AGD9 XM 54854
REQUIRED OPERATING TIME: NOT SPECIFIED
TER CHECKSHEET NO. 4
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): RCS WIDE RANGE (PT-RC-1402-1; PT-1402)
LICENSEE SUBMITTAL: SCEW(S): 6-268, -267

EQUIPMENT ITEM NO. 5
PRESSURE TRANSMITTER LOCATED IN THE TURBINE BUILDING (TB-35)
FISCHER AND PORTER MODEL 50EP1041BCXANS
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 5
LICENSEE REFERENCE(S): 687
FUNCTION (PLANT ID): STEAM HEADER PRESSURE (PT-1464; -1466, -1468)
LICENSEE SUBMITTAL: SCEW(S): 6-136 TO -138

EQUIPMENT ITEM NO. 6
 PRESSURE TRANSMITTER LOCATED IN THE MAIN STEAM VALVE HOUSE
 FISCHER AND PORTER MODEL 50EP1041BCXANS
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 6
 LICENSEE REFERENCE(S): 687
 FUNCTION (PLANT ID): STEAM GENERATOR STEAM PRESSURE (PT-1474 TO -1476, -1484
 TO -1486, -1494 TO -1496)
 LICENSEE SUBMITTAL: SCEW(S): 6-139 TO -147

EQUIPMENT ITEM NO. 7
 PENETRATION LOCATED IN THE RC-18B INSIDE AND OUTSIDE CONTAINMENT, OUTSIDE
 CRANEWALL
 CONAX, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 7
 LICENSEE REFERENCE(S): 1049, 60
 FUNCTION (PLANT ID): SUPPLIES POWER TO SAFETY SYSTEM (SPEC. NO. NAS-21,
 NA-313/1313)
 LICENSEE SUBMITTAL: SCEW(S): 6-27 TO -31

EQUIPMENT ITEM NO. 8
 ELECTRICAL PENETRATION LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 AMPHENOL MODEL TYPE 1A
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 8
 LICENSEE REFERENCE(S): 5329, 1167, 5288, 4005, 5286, 3190, 81
 FUNCTION (PLANT ID): ELECTRICAL PENETRATION (SPEC. NO. NUS-41, 65/1065)
 LICENSEE SUBMITTAL: SCEW(S): 6-43 TO -45

EQUIPMENT ITEM NO. 9
 ELECTRICAL PENETRATION LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 AMPHENOL MODEL TYPE III
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 9
 LICENSEE REFERENCE(S): 5329, 1167, 5288, 4005, 5286, 3190, 81
 FUNCTION (PLANT ID): SUPPLIES POWER TO SAFETY SYSTEM (SPEC. NO. NUS-41,
 65/1065)
 LICENSEE SUBMITTAL: SCEW(S): 6-46

EQUIPMENT ITEM NO. 10

ELECTRICAL PENETRATION LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 AMPHENOL MODEL TYPE IV

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 10

LICENSEE REFERENCE(S): 5329, 1167, 5288, 4005, 5286, 3190, 81

FUNCTION (PLANT ID): SUPPLIES POWER TO SUPPLY SYSTEM (SPEC. NO. NUS-41,
 65/1065)

LICENSEE SUBMITTAL: SCEW(S): 6-47

EQUIPMENT ITEM NO. 11

FLOW TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-47B)
 FISCHER AND PORTER MODEL 10B2496PBNS

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 11

LICENSEE REFERENCE(S): 687

FUNCTION (PLANT ID): SGLA AUXILIARY FEEDWATER FLOW (FT-FW-100C, B, A)

LICENSEE SUBMITTAL: SCEW(S): 6-84 TO -86

EQUIPMENT ITEM NO. 12

FLOW TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 FISCHER AND PORTER MODEL 10B2496QB

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 12

LICENSEE REFERENCE(S): 687

FUNCTION (PLANT ID): STEAM-FLOW TRANSMITTER (FT-1485, -1484, -1475, -1474,
 -1495, -1494)

LICENSEE SUBMITTAL: SCEW(S): 6-130 TO -135

EQUIPMENT ITEM NO. 13

FLOW TRANSMITTER LOCATED IN THE SAFEGUARDS AREA (SFGD-1)
 ROSEMOUNT MODEL 1152DP5

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 13

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): LOW HEAD INJECTION HEADER FLOW (FT-1945, -1946)

LICENSEE SUBMITTAL: SCEW(S): 6-277, -278

EQUIPMENT ITEM NO. 14

FLOW TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-27B)
 BARTON MODEL 386

REQUIRED OPERATING TIME: NOT SPECIFIED

TER CHECKSHEET NO. 14

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): COLD LEG SAFETY INJECTION FLOW (FT-1963, -1962, -1961)

LICENSEE SUBMITTAL: SCEW(S): 6-274 TO -276

EQUIPMENT ITEM NO. 15
 FLOW TRANSMITTER LOCATED IN THE AUXILIARY BUILDING
 FISCHER AND PORTER MODEL 10B2496QB
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 15
 LICENSEE REFERENCE(S): 687
 FUNCTION (PLANT ID): CHARGING FLOW/MINIMUM BORATION (FT-1122)
 LICENSEE SUBMITTAL: SCEW(S): 6-11

EQUIPMENT ITEM NO. 16
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B, RC-18B)
 ROSEMOUNT MODEL 1153 SERIES A
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 16
 LICENSEE REFERENCE(S): 1764
 FUNCTION (PLANT ID): STEAM GENERATOR NARROW RANGE LEVEL (LT-1494 TO -1496,
 -1484 TO -1486, -1476, -1475)
 LICENSEE SUBMITTAL: SCEW(S): 6-89 TO -95

EQUIPMENT ITEM NO. 17
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 ROSEMOUNT MODEL 1153DA4
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 17
 LICENSEE REFERENCE(S): 1764
 FUNCTION (PLANT ID): STEAM GENERATOR 1 NARROW RANGE LEVEL (LT-1474)
 LICENSEE SUBMITTAL: SCEW(S): 6-87

EQUIPMENT ITEM NO. 18
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-27B)
 ROSEMOUNT MODEL 1153ADP5 XM54854
 REQUIRED OPERATING TIME: NOT SPECIFIED
 TER CHECKSHEET NO. 18
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): STEAM GENERATOR WIDE RANGE (LT-1477, -1487, -1497)
 LICENSEE SUBMITTAL: SCEW(S): 6-269 TO -271

EQUIPMENT ITEM NO. 19
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-18B)
 BARTON MODEL 386
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 19
 LICENSEE REFERENCE(S): 3836
 FUNCTION (PLANT ID): PRESSURIZER LEVEL INDICATION CONTROL AND PROTECTION
 (LT-1459 TO -1461)
 LICENSEE SUBMITTAL: SCEW(S): 6-171 TO -173

EQUIPMENT ITEM NO. 20
LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-27B)
GEMS MODELS XM54853, XM54854
REQUIRED OPERATING TIME: NOT SPECIFIED
TER CHECKSHEET NO. 20
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CONTAINMENT SUMP LEVEL (LT-RS-151B, A)
LICENSEE SUBMITTAL: SCEW(S): 6-266, -265

EQUIPMENT ITEM NO. 21
TERMINAL BLOCK LOCATED INSIDE CONTAINMENT (RC-3A)
BURNDY, MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 21
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): VALVE POSITION INDICATION AND CONTROL
LICENSEE SUBMITTAL: SCEW(S): 6-264

EQUIPMENT ITEM NO. 22
TERMINAL BLOCK LOCATED INSIDE CONTAINMENT (RC-3A)
BUCHANAN, MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 22
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): VALVE POSITION INDICATION AND CONTROL
LICENSEE SUBMITTAL: SCEW(S): 6-263

EQUIPMENT ITEM NO. 23
TERMINAL BLOCK LOCATED INSIDE CONTAINMENT (RC-3A)
GENERAL ELECTRIC, MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 23
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): VALVE POSITION INDICATOR AND CONTROL
LICENSEE SUBMITTAL: SCEW(S): 6-261

EQUIPMENT ITEM NO. 24
HYDROGEN ANALYZER LOCATED IN THE AUXILIARY BUILDING, 13'0" LEVEL (AB-13A)
BENDIX MODEL THERMATRON T3
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 24
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): RADIOACTIVE WASTE GAS/POST-ACCIDENT MONITORING
(1-GW-H2A-103)
LICENSEE SUBMITTAL: SCEW(S): 6-104

EQUIPMENT ITEM NO. 25
 LIMIT SWITCH LOCATED INSIDE CONTAINMENT (RC-3A)
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 25
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): VALVE POSITION INDICATION AND CONTROL
 LICENSEE SUBMITTAL: SCEW(S): 6-260

EQUIPMENT ITEM NO. 26
 ELECTRICAL CABLE SPLICE LOCATED INSIDE CONTAINMENT (RC-3A)
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 26
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): VALE POSITION INDICATION AND CONTROL
 LICENSEE SUBMITTAL: SCEW(S): 6-262

EQUIPMENT ITEM NO. 27
 HYDROGEN RECOMBINER LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-47B)
 WESTINGHOUSE, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 27
 LICENSEE REFERENCE(S): 1571 TO 1578, 37, 38, 45
 FUNCTION (PLANT ID): HYDROGEN RECOMBINER (1-GW-HC-2A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-102, -103

EQUIPMENT ITEM NO. 28
 DAMPER LOCATED IN THE AUXILIARY BUILDING VENTILATION (AB-45)
 BUFFALO FORGE MODEL TYPE BL
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 28
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): DAMPER FOR CHARCOAL FILTRATION SYSTEM (DAMPER 3A, B (2))
 LICENSEE SUBMITTAL: SCEW(S): 6-109, -110

EQUIPMENT ITEM NO. 29
 DISTRIBUTION PANEL LOCATED IN THE AUXILIARY BUILDING CABLE VAULT (AB-13B)
 WESTINGHOUSE MODEL A
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 29
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): SUPPLY POWER H2 RECOMBINER UNITS (POWER SUPPLY FOR
 1-GW-HC-2A)
 LICENSEE SUBMITTAL: SCEW(S): 6-105

EQUIPMENT ITEM NO. 30
 DISTRIBUTION PANEL LOCATED IN THE AUXILIARY BUILDING CABLE VAULT (AB-13B)
 WESTINGHOUSE MODEL A
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 30
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): SUPPLY POWER H2 RECOMBINER UNITS (POWER SUPPLY FOR
 1-GW-HC-2B)
 LICENSEE SUBMITTAL: SCEW(S): 6-106

EQUIPMENT ITEM NO. 31
 TEMPERATURE ELEMENT LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
 ROSEMOUNT MODEL 176KS
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 31
 LICENSEE REFERENCE(S): 687
 FUNCTION (PLANT ID): RCS TEMPERATURE ELEMENT HOT LEG LOOPS (TE-1433, -1413,
 -1423)
 LICENSEE SUBMITTAL: SCEW(S): 6-188, -180, -184
 FUNCTION (PLANT ID): RC DELTA T/TAVG PROTECTION SYSTEM LOOPS (TE-1432D, B;
 1422D, B; -1412B, D)
 LICENSEE SUBMITTAL: SCEW(S): 6-187, -186, -183, -182, -178, -179
 FUNCTION (PLANT ID): RCS TEMPERATURE ELEMENT COLD LEG LOOPS (TE-1430, -1420)
 LICENSEE SUBMITTAL: SCEW(S): 6-185, -181
 FUNCTION (PLANT ID): RCS TEMPERATURE ELEMENT (WIDE-RANGE) (TE-1410)
 LICENSEE SUBMITTAL: SCEW(S): 6-177

EQUIPMENT ITEM NO. 32
 ELECTRICAL CONTROL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
 CERRO WIRE AND CABLE MODEL XLPE/NEOPRENE
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 32
 LICENSEE REFERENCE(S): 676, 70, 71, 69
 FUNCTION (PLANT ID): SUPPLIES POWER TO SAFETY SYSTEMS (SPEC NO. NAS-120,
 NA-312/1312; NAS-3187, NA-3187/4187)
 LICENSEE SUBMITTAL: SCEW(S): 6-32, -33

EQUIPMENT ITEM NO. 33
 ELECTRICAL INSTRUMENT CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 (RC-3A)
 BOSTON INSULATED WIRE MODEL XLPE/NEOPRENE
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 33
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): SUPPLIES SIGNAL (SPEC. NO. NAS-128, NA-265/1265)
 LICENSEE SUBMITTAL: SCEW(S): 6-34

EQUIPMENT ITEM NO. 34

ELECTRICAL INSTRUMENT CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
(RC-3A)

CERRO WIRE AND CABLE MODEL XLPE/NEOPRENE

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 34

LICENSEE REFERENCE(S): 1110, 74

FUNCTION (PLANT ID): SUPPLY SIGNAL (SPEC. NO. NAS-430, NA-392/1392)

LICENSEE SUBMITTAL: SCEW(S): 6-35

EQUIPMENT ITEM NO. 35

ELECTRICAL INSTRUMENT CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
(RC-3A)

RAYCHEM MODEL FLAMTROL

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 35

LICENSEE REFERENCE(S): 1831, 1832, 75

FUNCTION (PLANT ID): 300V INSTRUMENT CABLE (SPEC. NO. NAS-3190, 3190/4190)

LICENSEE SUBMITTAL: SCEW(S): 6-36

EQUIPMENT ITEM NO. 36

ELECTRICAL CONTROL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)

CERRO WIRE AND CABLE MODEL PYROTROL III

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 36

LICENSEE REFERENCE(S): 676, 70, 71, 76

FUNCTION (PLANT ID): 1000V CONTROL CABLE (SPEC. NOS. NUS-325, SN-246;
NUS-381C, SN-446; NUS-381E, SN-1447/1246; NUS-362,
SN-1246)

LICENSEE SUBMITTAL: SCEW(S): 6-37 TO -39, 6-42A

EQUIPMENT ITEM NO. 37

ELECTRICAL CONTROL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)

GENERAL ELECTRIC MODEL XPLE/NEOPRENE

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 37

LICENSEE REFERENCE(S): 3582

FUNCTION (PLANT ID): 1000V CONTROL CABLE (SPEC. NO. NUS-381, SN-398)

LICENSEE SUBMITTAL: SCEW(S): 6-40

EQUIPMENT ITEM NO. 38

ELECTRICAL CONTROL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
CONTINENTAL WIRE MODEL XPLE/NEOPRENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 38
LICENSEE REFERENCE(S): 3582
FUNCTION (PLANT ID): 1000V CONTROL CABLE (SPEC. NO. NUS-420, SN-1463)
LICENSEE SUBMITTAL: SCEW(S): 6-42

EQUIPMENT ITEM NO. 39

ELECTRICAL CONTROL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
OKONITE MODEL ETHYLENE PROPYLENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 39
LICENSEE REFERENCE(S): 1339, 58, 59
FUNCTION (PLANT ID): 1000V CONTROL CABLE (SPEC. NO. NUS-381B, SN-440/1440;
NUS-410, SIN-1446)
LICENSEE SUBMITTAL: SCEW(S): 6-42B, -41

EQUIPMENT ITEM NO. 40

ELECTRICAL POWER CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
KAISER MODEL XLPE/NEOPRENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 40
LICENSEE REFERENCE(S): 3582
FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NUS-225, SN-251; NUS-365A,
SN-1251)
LICENSEE SUBMITTAL: SCEW(S): 6-48, -49

EQUIPMENT ITEM NO. 41

ELECTRICAL POWER CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
OKONITE MODEL XPLE/NEOPRENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 41
LICENSEE REFERENCE(S): 1340, 77
FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NUS-365B, SN-1380; NUS-365C,
SN-1392; NUS-365D, SN-1417)
LICENSEE SUBMITTAL: SCEW(S): 6-50 TO 6-52
FUNCTION (PLANT ID): 600V ALUMINUM POWER CABLE (SPEC. NO. NUS-374, SN-375)
LICENSEE SUBMITTAL: SCEW(S): 6-53

EQUIPMENT ITEM NO. 42
 ELECTRICAL POWER CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
 COLLYER INSULATED WIRE MODEL XLPE/NEOPRENE
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 42
 LICENSEE REFERENCE(S): 4019
 FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NUS-365E, SN-457)
 LICENSEE SUBMITTAL: SCEW(S): 6-54

EQUIPMENT ITEM NO. 43
 ELECTRICAL POWER CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
 ANACONDA WIRE AND CABLE MODEL EPR/NEOPRENE
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 43
 LICENSEE REFERENCE(S): 1347, 95, 97, 94
 FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NUS-365F, SN-462)
 LICENSEE SUBMITTAL: SCEW(S): 6-55

EQUIPMENT ITEM NO. 44
 ELECTRICAL POWER CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
 OKONITE MODEL EP/NEOPRENE
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 44
 LICENSEE REFERENCE(S): 2103, 1339, 98
 FUNCTION (PLANT ID): SUPPLY POWER TO SAFETY SYSTEMS (SPEC. NO. NAS-116A,
 NA-128/1128)
 LICENSEE SUBMITTAL: SCEW(S): 6-56
 FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NAS-3185, 3185/4185)
 LICENSEE SUBMITTAL: SCEW(S): 6-57

EQUIPMENT ITEM NO. 45
 ELECTRICAL INSTRUMENT CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 (RC-3A)
 CONTINENTAL WIRE MODEL XLPE/HYPALON
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 45
 LICENSEE REFERENCE(S): 1207, 89, 83
 FUNCTION (PLANT ID): 600V POWER CABLE (SPEC. NO. NUS-341, SN-285/1285)
 LICENSEE SUBMITTAL: SCEW(S): 6-58
 FUNCTION (PLANT ID): 600V INSTRUMENT CABLE (SPEC. NO. NUS-411, SN-1458;
 NUS-341A, SN-1439)
 LICENSEE SUBMITTAL: SCEW(S): 6-59, 6-59A

EQUIPMENT ITEM NO. 46
ELECTRICAL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
CONTINENTAL WIRE MODEL SILICONE RUBBER
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 46
LICENSEE REFERENCE(S): 2818
FUNCTION (PLANT ID): SUPPLY POWER TO SAFETY SYSTEM (SPEC. NO. NUS-326, NO.
330)
LICENSEE SUBMITTAL: SCEW(S): 6-60

EQUIPMENT ITEM NO. 47
ELECTRICAL POWER CABLE LOCATED OUTSIDE CONTAINMENT (AB-27)
COLLYER INSULATED WIRE MODEL XLPE/NEOPRENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 47
LICENSEE REFERENCE(S): 4019
FUNCTION (PLANT ID): 5000V POWER CABLE (SPEC. NO. NUS-364, SN-1250)
LICENSEE SUBMITTAL: SCEW(S): 6-60A

EQUIPMENT ITEM NO. 48
ELECTRICAL POWER CABLE LOCATED OUTSIDE CONTAINMENT (AB-27)
OKONITE MODEL OKOGUARD
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 48
LICENSEE REFERENCE(S): 2103, 58, 59
FUNCTION (PLANT ID): 5 KV POWER CABLE (SPEC. NO. 364A, SN-1443)
LICENSEE SUBMITTAL: SCEW(S): NUS-364A

EQUIPMENT ITEM NO. 49
ELECTRICAL POWER CABLE LOCATED OUTSIDE CONTAINMENT
KAISER MODEL XLPE/NEOPRENE
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 49
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): 5000V POWER CABLE (SPEC. NO. NUS-217, SN-250)
LICENSEE SUBMITTAL: SCEW(S): 6-60B

EQUIPMENT ITEM NO. 50
ELECTRIC MOTOR LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-3A)
GENERAL ELECTRIC MODEL 5K6319XJ1B
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 50
LICENSEE REFERENCE(S): 42, 41
FUNCTION (PLANT ID): RECIRCULATION SPRAY PUMP MOTOR (1-RS-P-1A, B)
LICENSEE SUBMITTAL: SCEW(S): 6-111, -112

EQUIPMENT ITEM NO. 51
 ELECTRIC MOTOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 WESTINGHOUSE MODEL ABDP
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 51
 LICENSEE REFERENCE(S): 604, 606, 51
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION PUMP MOTOR (1-SI-P-1B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-199, -198

EQUIPMENT ITEM NO. 52
 ELECTRIC MOTOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 GENERAL ELECTRIC MODEL 5K6287XH41A
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 52
 LICENSEE REFERENCE(S): 42, 48
 FUNCTION (PLANT ID): RECIRCULATION SPRAY PUMP MOTOR (1-RS-P-2B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-157, -156

EQUIPMENT ITEM NO. 53
 ELECTRIC MOTOR LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-1)
 GENERAL ELECTRIC MODEL 5KC37JG770X
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 53
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): SERVICE WATER RETURN FROM RECIRCULATION SPRAY HEAT
 EXCHANGER RADIATION MONITOR (1-SW-P-5A, -5B, -5C, -5D)
 LICENSEE SUBMITTAL: SCEW(S): 6-250 TO -253

EQUIPMENT ITEM NO. 54
 ELECTRIC MOTOR LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-27)
 MANUFACTURER AND MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 54
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): AUXILIARY FEEDWATER PUMP (1-FW-P-3B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-101B, A

EQUIPMENT ITEM NO. 55
 MOTOR CONTROL CENTER LOCATED IN THE AUXILIARY BUILDING CABLE VAULT (AB-13B)
 CUTLER HAMMER MODEL UNITROL
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 55
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): SUPPLY POWER TO SAFETY SYSTEM (1-H1-2 NORTH, SOUTH;
 1-J1-2 WEST, EAST)
 LICENSEE SUBMITTAL: SCEW(S): 6-23 TO -26

EQUIPMENT ITEM NO. 56
ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING VENTILATION (AB-45)
SIEMENS-ALLIS MODEL 444TS
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 56
LICENSEE REFERENCE(S): 5213
FUNCTION (PLANT ID): AUXILIARY BUILDING CONTROL AREA EXHAUST FAN MOTOR
(1-VS-F-58B, A)
LICENSEE SUBMITTAL: SCEW(S): 6-108, -107

EQUIPMENT ITEM NO. 57
ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE
WESTINGHOUSE MODEL 68659
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 57
LICENSEE REFERENCE(S): 604, 606, 32
FUNCTION (PLANT ID): HIGH HEAD SAFETY INJECTION/NORMAL CHARGING (1-CH-P-1A,
B, C)
LICENSEE SUBMITTAL: SCEW(S): 6-7 TO 6-9

EQUIPMENT ITEM NO. 58
ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
GENERAL ELECTRIC, MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 58
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CHARGING PUMP COOLING (1-CC-P-2A, B)
LICENSEE SUBMITTAL: SCEW(S): 6-61, -62

EQUIPMENT ITEM NO. 59
ELECTRIC MOTOR LOCATED IN THE AUXILIARY BUILDING
MANUFACTURER AND MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 59
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP MOTOR (1-CV-P-1B, A)
LICENSEE SUBMITTAL: SCEW(S): 6-79, -78

EQUIPMENT ITEM NO. 60
MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
(AB-2B)
LIMITORQUE MODEL SMBO WITH CLASS B INSULATION
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 60
LICENSEE REFERENCE(S): 662, 659, 27
FUNCTION (PLANT ID): BORIC ACID INJECTION TANK OUTLET VALVE (MOV-1842)
LICENSEE SUBMITTAL: SCEW(S): 6-200

EQUIPMENT ITEM NO. 61
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP
 CUBICLE (AB-2C)
 LIMITORQUE MODEL SMB WITH CLASS B INSULATION; SIZES 00, 000 WITH MOTOR-
 BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 61
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM REFUELING WATER STORAGE TANK
 (MOV-1115D)
 LICENSEE SUBMITTAL: SCEW(S): 6-15
 FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM VOLUME CONTROL TANK
 (MOV-1115B)
 LICENSEE SUBMITTAL: SCEW(S): 6-13

EQUIPMENT ITEM NO. 62
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMB1 WITH MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 62
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION DISCHARGE VALVE (MOV-1864B, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-229, -228

EQUIPMENT ITEM NO. 63
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMB2 WITH CLASS B INSULATION; MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 63
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION STOP VALVE (MOV-1890A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-215 TO -217

EQUIPMENT ITEM NO. 64
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP
 CUBICLE (AB-2C)
 LIMITORQUE MODEL WITH PEERLESS MOTOR CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 64
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE
 TANK (MOV-1275A)
 LICENSEE SUBMITTAL: SCEW(S): 6-2

EQUIPMENT ITEM NO. 65
 MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL,
 SUBMERGED (RC-3A)
 LIMITORQUE, MODEL NOT STATED
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 65
 LICENSEE REFERENCE(S): 43
 FUNCTION (PLANT ID): ACCUMULATOR ISOLATION (MOV-1865A TO 1865C)
 LICENSEE SUBMITTAL: SCEW(S): 6-207 TO -209

EQUIPMENT ITEM NO. 66
 MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)
 LIMITORQUE MODEL SMBOO WITH CLASS B INSULATION
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 66
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION SUCTION (MOV-1862B)
 LICENSEE SUBMITTAL: SCEW(S): 6-204
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION SUCTION FROM REFUELING WATER
 STORAGE TANK (MOV-1862A)
 LICENSEE SUBMITTAL: SCEW(S): 6-203
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION PUMP RECIRCULATION (MOV-1885A,
 B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-230C, B, A
 FUNCTION (PLANT ID): RECIRCULATION SPRAY PUMP SUCTION (MOV-RS-156A, B; -155A,
 B)
 LICENSEE SUBMITTAL: SCEW(S): 6-158 TO -161

EQUIPMENT ITEM NO. 67
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
 (AB-2B)
 LIMITORQUE MODEL SMBOO
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 67
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): BORON INJECTION TANK BYPASS (MOV-1869B)
 LICENSEE SUBMITTAL: SCEW(S): 6-230
 FUNCTION (PLANT ID): SAFETY INJECTION TO REACTOR HOT LEG ISOLATION (MOV-1869A)
 LICENSEE SUBMITTAL: SCEW(S): 6-214
 FUNCTION (PLANT ID): BORON INJECTION TANK OUTLET ISOLATION (MOV-1867D)
 LICENSEE SUBMITTAL: SCEW(S): 6-213
 FUNCTION (PLANT ID): BORIC ACID INJECTION TANK OUTLET VALVE (MOV-1867C)
 LICENSEE SUBMITTAL: SCEW(S): 6-212
 FUNCTION (PLANT ID): BORIC ACID INJECTION TANK VALVE (MOV-1867A)
 LICENSEE SUBMITTAL: SCEW(S): 6-210
 FUNCTION (PLANT ID): CHARGING TO REGENERATIVE HEAT EXCHANGER STOP VALVE
 (MOV-1289A)

EQUIPMENT ITEM NO. 67 (CONTINUED)
 LICENSEE SUBMITTAL: SCEW(S): 6-17
 FUNCTION (PLANT ID): CHARGING HEADER PENETRATION AREA (MOV-1289B)
 LICENSEE SUBMITTAL: SCEW(S): 6-18
 FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE
 TANK HEADER ISOLATION (MOV-1373)
 LICENSEE SUBMITTAL: SCEW(S): 6-5

EQUIPMENT ITEM NO. 68
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 LIMITORQUE MODEL SMB00 WITH CLASS B INSULATION; MOTOR-BRAKE ASSEMBLY
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 68
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION DISCHARGE (MOV-1863A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-205, -206

EQUIPMENT ITEM NO. 69
 MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
 LIMITORQUE MODEL SMB000
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 69
 LICENSEE REFERENCE(S): 659, 706, 43
 FUNCTION (PLANT ID): PRESSURIZER RELIEF BLOCK VALVE (MOV-1535, -1536)
 LICENSEE SUBMITTAL: SCEW(S): 6-196, -197

EQUIPMENT ITEM NO. 70
 MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP
 CUBICLE (AB-2C)
 LIMITORQUE MODEL SMB WITH CLASS B INSULATION; SIZES 00, 000
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 70
 LICENSEE REFERENCE(S): 662, 659, 27
 FUNCTION (PLANT ID): CHARGING PUMP SUCTION FROM VOLUME CONTROL TANK
 (MOV-1115C, E)
 LICENSEE SUBMITTAL: SCEW(S): 6-14, -16
 FUNCTION (PLANT ID): CHARGING PUMP RECIRCULATION TO REFUELING WATER STORAGE
 TANK (MOV-1275B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-3, -4

EQUIPMENT ITEM NO. 71

MOTORIZED VALVE ACTUATOR LOCATED IN THE CONTAINMENT SPRAY PUMP HOUSE (CSPH-11)
BELOW ELEV. 27'6"

LIMITORQUE MODEL SMBOO WITH CLASS B INSULATION

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 71

LICENSEE REFERENCE(S): 662, 659, 27

FUNCTION (PLANT ID): CHEMICAL ADDITION TANK ISOLATION (MOV-CS-102B)

LICENSEE SUBMITTAL: SCEW(S): 6-77

FUNCTION (PLANT ID): CHEMICAL ADDITION (MOV-CS-102A)

LICENSEE SUBMITTAL: SCEW(S): 6-76

FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (MOV-CS-101D)

LICENSEE SUBMITTAL: SCEW(S): 6-75

FUNCTION (PLANT ID): SPRAY PUMP DISCHARGE ISOLATION (MOV-CS-101C, B, A)

LICENSEE SUBMITTAL: SCEW(S): 6-74, -73, -72

EQUIPMENT ITEM NO. 72

MOTORIZED VALVE ACTUATOR LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-11)

LIMITORQUE MODEL SMBOO WITH CLASS B INSULATION

REQUIRED OPERATING TIME: 120 DAYS

LICENSEE REFERENCE(S): 662, 659, 27

FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER (MOV-SW-105D, C)

LICENSEE SUBMITTAL: SCEW(S): 6-249, -248

FUNCTION (PLANT ID): SERVICE WATER OUTLET RECIRCULATION SPRAY HEAT EXCHANGER
(MOV-SW-105B)

LICENSEE SUBMITTAL: SCEW(S): 6-247

FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER SERVICE WATER RETURN
(MOV-SW-105A, -104D)

LICENSEE SUBMITTAL: SCEW(S): 6-246, -245

FUNCTION (PLANT ID): RECIRCULATION SPRAY HEAT EXCHANGER SERVICE WATER SUPPLY
(MOV-SW-104C, B, A)

LICENSEE SUBMITTAL: SCEW(S): 6-244, -243, -242

EQUIPMENT ITEM NO. 73

MOTORIZED VALVE ACTUATOR LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-47B)

LIMITORQUE MODEL SMBOO

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 73

LICENSEE REFERENCE(S): 659, 706, 43

FUNCTION (PLANT ID): AUXILIARY FEEDWATER/HELB MITIGATION (MOV-FW-151A TO F)

LICENSEE SUBMITTAL: SCEW(S): 6-96 TO -101

EQUIPMENT ITEM NO. 74

MOTORIZED VALVE ACTUATOR LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA
(AB-29)

LIMITORQUE MODEL SMB000 WITH CLASS B INSULATION

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 74

LICENSEE REFERENCE(S): 662, 659, 27

FUNCTION (PLANT ID): BORIC ACID INJECTION TANK INLET VALVE (MOV-1867B)

LICENSEE SUBMITTAL: SCEW(S): 6-211

FUNCTION (PLANT ID): REACTOR COOLING PUMP SEAL WATER RETURN (MOV-1381)

LICENSEE SUBMITTAL: SCEW(S): 6-6

EQUIPMENT ITEM NO. 75

MOTORIZED VALVE ACTUATOR LOCATED IN THE SAFEGUARD AREA (SFGD-1)

LIMITORQUE MODEL SMB000 WITH CLASS B INSULATION

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 75

LICENSEE REFERENCE(S): 662, 659, 27

FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION RECIRCULATION VALVE (MOV-1860A)

LICENSEE SUBMITTAL: SCEW(S): 6-201

FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION PUMP RECIRCULATION (MOV-1885D)

LICENSEE SUBMITTAL: SCEW(S): 6-230D

FUNCTION (PLANT ID): LOW HEAD SAFETY INJECTION RECIRCULATION WATER (MOV-1860B)

LICENSEE SUBMITTAL: SCEW(S): 6-202

EQUIPMENT ITEM NO. 76

SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)

ASCO MODEL LB831654E

REQUIRED OPERATING TIME: 60 SECONDS

TER CHECKSHEET NO. 76

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): BORON INJECTION TANK RECIRCULATION (SOV-1884C, B, A)

LICENSEE SUBMITTAL: SCEW(S): 6-227, -226, -225

EQUIPMENT ITEM NO. 77

SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL

ASCO MODEL LB831654

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 77

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): PRESSURIZER AUXILIARY SPRAY ISOLATION/MINIMUM BORATION
(SOV-1311)

LICENSEE SUBMITTAL: SCEW(S): 6-12

EQUIPMENT ITEM NO. 78
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL HBX8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 78
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150C, A)
 LICENSEE SUBMITTAL: SCEW(S): 6-82, -80
 FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100C)
 LICENSEE SUBMITTAL: SCEW(S): 6-169
 FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER TANK VENT (SOV-VG-109A)
 LICENSEE SUBMITTAL: SCEW(S): 6-166
 FUNCTION (PLANT ID): NITROGEN SUPPLY LINE (SOV-DG-108A)
 LICENSEE SUBMITTAL: SCEW(S): 6-164

EQUIPMENT ITEM NO. 79
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL HBX8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 79
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR CONTAINMENT SUMP PUMP DISCHARGE (SOV-DA-100B)
 LICENSEE SUBMITTAL: SCEW(S): 6-163
 FUNCTION (PLANT ID): COMPONENT COOLING RETURN FROM CONTAINMENT COOLERS
 ISOLATION (SOV-CC-110A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-69 TO -71

EQUIPMENT ITEM NO. 80
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL HBX832081RF
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 80
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLING HOT LEG SAMPLE (SOV-SS-106A)
 LICENSEE SUBMITTAL: SCEW(S): 6-240
 FUNCTION (PLANT ID): PRESSURE RELIEF TANK SAMPLE (SOV-SS-104A)
 LICENSEE SUBMITTAL: SCEW(S): 6-238

EQUIPMENT ITEM NO. 81
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
 LAWRENCE MODEL 3300WA742DC
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 81
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRESSURIZER POWER OPERATED RELIEF VALVE ACTUATION/LOCA
 AND MSLB MITIGATION (SOV-1456-3, SOV-1455C-3)
 LICENSEE SUBMITTAL: SCEW(S): 6-195, -192

EQUIPMENT ITEM NO. 82
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
ASCO MODEL HT8316C47E
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 82
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): MAIN STEAM TRIP VALVE (SOV-MS-101AA, AB, BA, BB, CA, CB)
LICENSEE SUBMITTAL: SCEW(S): 6-148 TO -153

EQUIPMENT ITEM NO. 83
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)
ASCO, MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 83
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): REFUELING WATER STORAGE TANK CROSS CONNECT
(SOV-SI-102B2, A2)
LICENSEE SUBMITTAL: SCEW(S): 6-224, -222

EQUIPMENT ITEM NO. 84
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
MANUFACTURER AND MODEL NOT STATED
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 84
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100A)
LICENSEE SUBMITTAL: SCEW(S): 6-170
FUNCTION (PLANT ID): PRIMARY GRADE WATER TO PRESSURIZER RELIEF TANK
(SOV-1519A)
LICENSEE SUBMITTAL: SCEW(S): 6-189

EQUIPMENT ITEM NO. 85
SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-11)
ASCO, MODEL NOT STATED
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 85
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): MAIN STEAM LINE DRAINS TO CONDENSER (SOV-MS-110)
LICENSEE SUBMITTAL: SCEW(S): 6-155

EQUIPMENT ITEM NO. 86
SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL (RC-47A)
ASCO MODEL NP831654E
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 86
LICENSEE REFERENCE(S): 2850
FUNCTION (PLANT ID): CHEMICAL VOLUME CONTROL SYSTEM ISOLATION VALVE FOR
LETDOWN (SOV-1200A, B, C)
LICENSEE SUBMITTAL: SCEW(S): 6-20, -21, -22
FUNCTION (PLANT ID): PRESSURIZER POWER OPERATED RELIEF (SOV-1456-2, -1;
-1455C-1, -2)
LICENSEE SUBMITTAL: SCEW(S): 6-190 TO -194

EQUIPMENT ITEM NO. 87
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
ASCO MODEL 830281RF
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 87
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER PUMP/CONTAINMENT ISOLATION VALVE
OPERATOR (SOV-DG-108B)
LICENSEE SUBMITTAL: SCEW(S): 6-165
FUNCTION (PLANT ID): PRIMARY COOLANT HOT LEG SAMPLE (SOV-SS-106B)
LICENSEE SUBMITTAL: SCEW(S): 6-241
FUNCTION (PLANT ID): PRESSURE RELIEF TANK SAMPLE (SOV-SS-104B)
LICENSEE SUBMITTAL: SCEW(S): 6-239
FUNCTION (PLANT ID): RESIDUAL HEAT REMOVAL SAMPLE (SOV-SS-103)
LICENSEE SUBMITTAL: SCEW(S): 6-237
FUNCTION (PLANT ID): PRESSURE VAPOR SPACE (SOV-SS-101B1)
LICENSEE SUBMITTAL: SCEW(S): 6-234
FUNCTION (PLANT ID): PRESSURE LIQUID SPACE SAMPLE (SOV-SS-100B1)
LICENSEE SUBMITTAL: SCEW(S): 6-232

EQUIPMENT ITEM NO. 88
SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
ASCO MODEL 8320A12
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 88
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): REACTOR CONTAINMENT PUMP DISCHARGE (SOV-DA-100A)
LICENSEE SUBMITTAL: SCEW(S): 6-162

EQUIPMENT ITEM NO. 89
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 ASCO MODEL 8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 89
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-101B)
 LICENSEE SUBMITTAL: SCEW(S): 6-129

EQUIPMENT ITEM NO. 90
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 8320A12
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 90
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): NITROGEN RELIEF (SOV-SI-101B)
 LICENSEE SUBMITTAL: SCEW(S): 6-220
 FUNCTION (PLANT ID): NITROGEN SUPPLY (SOV-SI-100)
 LICENSEE SUBMITTAL: SCEW(S): 6-218
 FUNCTION (PLANT ID): RADIATION MONITORING TRIP VALVE (SOV-RM-100B)
 LICENSEE SUBMITTAL: SCEW(S): 6-168
 FUNCTION (PLANT ID): PRIMARY DRAIN TRANSFER TANK VENT (SOV-VG-109B)
 LICENSEE SUBMITTAL: SCEW(S): 6-167
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150D)
 LICENSEE SUBMITTAL: SCEW(S): 6-83
 FUNCTION (PLANT ID): REACTOR CONTAINMENT PUMP COOLANT WATER ISOLATION
 (SOV-CC-105A, B, C)
 LICENSEE SUBMITTAL: SCEW(S): 6-63 TO -65

EQUIPMENT ITEM NO. 90 (CONTINUED)
 FUNCTION (PLANT ID): REACTOR COOLANT PUMP THERMAL BARRIER ISOLATION
 (SOV-CC-107)
 LICENSEE SUBMITTAL: SCEW(S): 6-66
 FUNCTION (PLANT ID): COOLING WATER RETURN FROM RESIDUAL HEAT EXCHANGER
 ISOLATION (SOV-CC-109A, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-67, -68
 FUNCTION (PLANT ID): CONTAINMENT VACUUM PUMP TRIP VALVE (SOV-CV-150B)
 LICENSEE SUBMITTAL: SCEW(S): 6-81

EQUIPMENT ITEM NO. 91
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
 ASCO MODEL NP8320A173B
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 91
 LICENSEE REFERENCE(S): 2850
 FUNCTION (PLANT ID): CONTAINMENT INSTRUMENTATION AIR COMPRESSOR SUCTION
 (SOV-BD-100E)
 LICENSEE SUBMITTAL: SCEW(S): 6-258
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100C)
 LICENSEE SUBMITTAL: SCEW(S): 6-256
 FUNCTION (PLANT ID): OUTSIDE BLOWDOWN TRIP VALVE (SOV-BD-100A)
 LICENSEE SUBMITTAL: SCEW(S): 6-254

EQUIPMENT ITEM NO. 92
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING CHARGING PUMP CUBICLE (AB-2C)
 ASCO MODEL 830282G
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 92
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG (SOV-SI-102B1, A1)
 LICENSEE SUBMITTAL: SCEW(S): 6-223, -221

EQUIPMENT ITEM NO. 93
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
 ASCO MODEL 8320A102
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 93
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100D, B)
 LICENSEE SUBMITTAL: SCEW(S): 6-257, -255

EQUIPMENT ITEM NO. 94
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING (AB-13A)
 ASCO MODEL 8320A102
 REQUIRED OPERATING TIME: 60 SECONDS
 TER CHECKSHEET NO. 94
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-100A TO G)
 LICENSEE SUBMITTAL: SCEW(S): 6-120 TO -126
 FUNCTION (PLANT ID): CONTAINMENT PRESSURE (SOV-LM-100H)
 LICENSEE SUBMITTAL: SCEW(S): 6-127
 FUNCTION (PLANT ID): CONTAINMENT LEAKAGE MONITORING (SOV-LM-101A)
 LICENSEE SUBMITTAL: SCEW(S): 6-128
 FUNCTION (PLANT ID): AIR TO BLOWDOWN TRIP VALVE (SOV-BD-100F)
 LICENSEE SUBMITTAL: SCEW(S): 6-259

EQUIPMENT ITEM NO. 95
SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-27)
ASCO MODEL 80174
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 95
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): MAIN STEAM LINE DRAINS TO CONDENSER (SOV-MS-109)
LICENSEE SUBMITTAL: SCEW(S): 6-154

EQUIPMENT ITEM NO. 96
SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
ASCO MODEL NP8320175E
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 96
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): NITROGEN RELIEF (SOV-SI-101A)
LICENSEE SUBMITTAL: SCEW(S): 6-219

EQUIPMENT ITEM NO. 97
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
ASCO MODEL 831654
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 97
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): LETDOWN INLET NON-REGENERATIVE HEAT EXCHANGER (SOV-1204)
LICENSEE SUBMITTAL: SCEW(S): 6-19

EQUIPMENT ITEM NO. 98
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
ASCO MODEL 830281R
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 98
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLE (SOV-SS-102B1)
LICENSEE SUBMITTAL: SCEW(S): 6-236

EQUIPMENT ITEM NO. 99
SOLENOID VALVE LOCATED IN THE MAIN STEAM VALVE HOUSE (MSVH-27)
ASCO MODEL HBX8320A26
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 99
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): AIR REMOVAL TO CONTAINMENT (SOV-SV-102)
LICENSEE SUBMITTAL: SCEW(S): 6-1

EQUIPMENT ITEM NO. 100
SOLENOID VALVE LOCATED INSIDE CONTAINMENT (RC-3B)
ASCO MODEL HBX8320A26
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 100
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR SUCTION
(SOV-IA-101A)
LICENSEE SUBMITTAL: SCEW(S): 6-114

EQUIPMENT ITEM NO. 101
SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL (RC-3B)
ASCO MODEL 830281R
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 101
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLE (SOV-SS-102A1)
LICENSEE SUBMITTAL: SCEW(S): 6-235
FUNCTION (PLANT ID): PRESSURE LIQUID SPACE SAMPLE (SOV-SS-101A1, -100A1)
LICENSEE SUBMITTAL: SCEW(S): 6-233, -231

EQUIPMENT ITEM NO. 102
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING PENETRATION AREA (AB-2B)
ASCO MODEL HBX8320A26
REQUIRED OPERATING TIME: 60 SECONDS
TER CHECKSHEET NO. 102
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR SUCTION
(SOV-IA-101B)
LICENSEE SUBMITTAL: SCEW(S): 6-115
FUNCTION (PLANT ID): CONTAINMENT INSTRUMENT AIR COMPRESSOR DISCHARGE
(SOV-IA-100)
LICENSEE SUBMITTAL: SCEW(S): 6-113

EQUIPMENT ITEM NO. 103
SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING
MANUFACTURER AND MODEL NOT STATED
REQUIRED OPERATING TIME: 120 DAYS
TER CHECKSHEET NO. 103
LICENSEE REFERENCE(S): NOT CITED
FUNCTION (PLANT ID): CHARGING FLOW CONTROL/MINIMUM BORATION (FCV-1122)
LICENSEE SUBMITTAL: SCEW(S): 6-10

EQUIPMENT ITEM NO. 104
 PRESSURE TRANSMITTER LOCATED IN THE AUXILIARY BUILDING
 ROSEMOUNT MODEL 1152AP7A22PB
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 104
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): CONTAINMENT PRESSURE POST-ACCIDENT MONITORING
 (PT-LM-101A, -101B)
 LICENSEE SUBMITTAL: SCEW(S): T-1, T-2 [3]

EQUIPMENT ITEM NO. 105
 SOLENOID VALVE LOCATED IN THE SAFEGUARDS AREA
 ASCO MODEL NP831654E
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 105
 LICENSEE REFERENCE(S): 649
 FUNCTION (PLANT ID): CONTAINMENT ISOLATION (SOV-DA-103A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-3, T-4 [3]

EQUIPMENT ITEM NO. 106
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 GEMS MODELS XM-54854 AND XM-54853
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 106
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR COOLANT WATER LEVEL (WIDE RANGE) (LT-RS-151A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-30, T-31 [3]

EQUIPMENT ITEM NO. 107
 LEVEL TRANSMITTER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 GEMS MODEL XM-54854
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 107
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): REACTOR COOLANT SUMP WATER LEVEL, NARROW RANGE
 (LT-DA-110A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-5, T-6 [3]

EQUIPMENT ITEM NO. 108
 LIMIT SWITCH LOCATED IN THE SAFEGUARDS AREA
 NAMCO MODEL EA180-31302
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 108
 LICENSEE REFERENCE(S): 4447
 FUNCTION (PLANT ID): CONTAINMENT ISOLATION AUXILIARY BUILDING SUMP
 (ZS-DA-103A, B)
 LICENSEE SUBMITTAL: SCEW(S): T-7, T-8 [3]

EQUIPMENT ITEM NO. 109

ACCELEROMETER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL

ENDEVCO MODEL 2273AM20

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 109

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): PRESSURIZER SAFETY AND PORV VALVE POSITION INDICATOR
(YE-100A-1, -2; -100B-1, -2; -100C-1, -2; -101A-1, -2;
101B-1, -2)

LICENSEE SUBMITTAL: SCEW(S): T-9 THROUGH T-18 [3]

EQUIPMENT ITEM NO. 110

HARDLINE COAXIAL CABLE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL

ENDEVCO MODEL 3075M6

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 110

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): VALVE POSITION INDICATION SIGNAL TRANSMISSION (LOW NOISE
CABLE)

LICENSEE SUBMITTAL: SCEW(S): T-19 [3]

EQUIPMENT ITEM NO. 111

CHARGE PREAMPLIFIER LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL

UNHOLTZ-DICKIE MODEL 22CA-2TR

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 111

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): PRESSURIZER PORV AND SAFETY VALVE POSITION INDICATION
(YY-VMS-100A-1, -2; B-1, -2; C-1, -2; -101A-1, -2; B-1,
-2)

LICENSEE SUBMITTAL: SCEW(S): T-20 THROUGH T-29 [3]

EQUIPMENT ITEM NO. 112

SOLENOID VALVE LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL

VALCOR MODEL V526

REQUIRED OPERATING TIME: 120 DAYS

TER CHECKSHEET NO. 112

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): POST-ACCIDENT SAMPLING (HCV-SS-100A, -100B)

LICENSEE SUBMITTAL: SCEW(S): 10.3-38, -39 [14]

EQUIPMENT ITEM NO. 113
 SOLENOID VALVE LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL
 VALCOR MODEL V526
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 113
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (TV-SS-102A,
 -106A, -103A; HCV-SS-101D, -102A)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-32, -34, -40, -36, -37 [14]

EQUIPMENT ITEM NO. 114
 SOLENOID VALVE LOCATED IN THE AUXILIARY BUILDING
 VALCOR MODEL V526
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 114
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): HYDROGEN ANALYZER CONTAINMENT ISOLATION (TV-GW-100
 THROUGH -107; TV-SS-102B, -103B, -106B; S1-XCV-1401A, B;
 -1422A, B)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-76 THROUGH -83; 10.3-33, -35, -41, -62,
 -63, -64, -65 [14]

EQUIPMENT ITEM NO. 115
 LIMIT SWITCH LOCATED INSIDE CONTAINMENT, INSIDE CRANEWALL
 GORDOS MODEL MR8901
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 115
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): RHR SYSTEM OUTLET POST-ACCIDENT SAMPLING VALVE
 (ZS-SS-100A-1, -2; -100B-1, -2)
 LICENSEE SUBMITTAL: SCEW(S): 10.3-54, -55, -56, -57 [14]

EQUIPMENT ITEM NO. 116
 LIMIT SWITCH LOCATED INSIDE CONTAINMENT, OUTSIDE CRANEWALL
 GORDOS MODEL MR8901
 REQUIRED OPERATING TIME: 120 DAYS
 TER CHECKSHEET NO. 116
 LICENSEE REFERENCE(S): NOT CITED
 FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (ZS-SS-102A-1,
 -2; -106A-1, -2; -101D-1, -2; 102A-3, -4; 103A-1, -2)
 LICENSEE SBUMITTAL: SCEW(S): 10.3-42, -43, -46, -47, -50, -51, -52, -53,
 -58, -59 [14]

EQUIPMENT ITEM NO. 117

LIMIT SWITCH LOCATED IN THE AUXILIARY BUILDING

GORDOS MODEL MR8901

REQUIRED OPERATING TIME: 120 DAYS

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): PRIMARY COOLANT COLD LEG SAMPLING VALVE (ZS-SS-102B-2,
-1; -106B-1, -2; 103B-1, -2; ZS-XCV-1401A-1, -2;
-1401B-1, -2; 1422A-1, -2; -1422B-1, -2; ZS-GW-100-1, -2;
-101-1, -2; -102-1, -2; -103-1, -2; -104-1, -2; -105-1,
-2; -106-1, -2; -107-1, -2)

LICENSEE SUBMITTAL: SCEW(S): 10.3-45, -44, -48, -49, -60, -61, -66 THROUGH
-69, -70 THROUGH -73, -84 THROUGH -99 [14]

EQUIPMENT ITEM NO. 118

HYDROGEN ANALYZER LOCATED IN THE AUXILIARY BUILDING

COMSIP-DELPHI MODEL K-III

REQUIRED OPERATING TIME: 120 DAYS

LICENSEE REFERENCE(S): NOT CITED

FUNCTION (PLANT ID): CONTAINMENT HYDROGEN ANALYZER (H2A-GW-101-1, -2)

LICENSEE SUBMITTAL: SCEW(S): 10.3-74, -75 [14]

APPENDIX C - PLANT SAFETY-RELATED SYSTEMS AND DISPLAY INSTRUMENTATION

C.1 LIST OF SAFETY-RELATED SYSTEMS

In accordance with IE Bulletin 79-01B or NUREG-0588, the Licensee was required to (1) establish a list of systems and equipment required to mitigate the consequences of a loss-of-coolant accident (LOCA) and a high energy line break (HELB) and (2) identify components needed to perform the functions of safety-related display information, post-accident sampling and monitoring, and radiation monitoring.

The list of safety-related systems provided by the Licensee was reviewed by the NRC staff against a staff-developed master list. The NRC staff had developed a generic master list based upon a review of plant safety analyses and emergency procedures. The systems list was established on the basis of the functions that must be performed for accident mitigation (without regard to location of equipment relative to hostile environments). The instrumentation selected included that needed to monitor overall plant performance as well as to monitor the performance of systems on the list.

Based upon information in the Licensee's submittal, the equipment location references, and in some cases conversations with the Licensee, the NRC staff verified that the systems included in the Licensee's submittal were those required to achieve or support: (1) emergency reactor shutdown, (2) containment isolation, (3) reactor core cooling, (4) containment heat removal, (5) core residual heat removal, and (6) prevention of significant release of radioactive material to the surrounding environment. With the exception of items deferred for later review (cold-shutdown equipment and TMI Lessons-Learned modifications), the staff concluded that the systems identified by the Licensee were acceptable. The list of systems identified by the Licensee and accepted by the NRC staff is as follows:

<u>Function</u>	<u>System¹</u>
Emergency Reactor Shutdown	Reactor Coolant Reactor Protection Safeguards Actuation Chemical and Volume Control
Containment Isolation	Containment Isolation
Reactor Core Cooling	High Pressure Injection Low Pressure Injection Accumulators
Containment Heat Removal	Containment Spray Containment Ventilation Containment Sump Recirculation
Core Residual Heat	Residual Heat Removal Pressurizer Spray Power Operated Relief Valves Main Feedwater Auxiliary Feedwater Main Steam Steam Dump Component Cooling Water Service Water
Prevention of Significant Release of Radioactive Material to Environment	Containment Spray (Iodine Removal) Containment Air Purification Containment Gas Control Containment Radiation Monitoring Containment Radiation Sampling
Supporting Systems	Emergency Power Control Room and Safety Equipment Area Ventilation

1. The NRC staff recognized that there are differences in nomenclature of systems because of plant vintage and engineering design; consequently, some systems performing identical or similar functions may have different names. In those instances it was necessary to verify the function of the system(s) with the responsible IE regional reviewer and/or the licensee.

.2 SAFETY-RELATED INSTRUMENTATION

In Section 3.1 of the NRC SER dated May 21, 1981 [16], the NRC made the following statement:

"Display instrumentation which provides information for the reactor operators to aid them in the safe handling of the plant was not specifically identified by the licensee. A complete list of all display instrumentation mentioned in the LOCA and HELB emergency procedures must be provided. Equipment qualification information in the form of summary sheets should be provided for all components of the display instrumentation exposed to harsh environments. Instrumentation which is not considered to be safety related but which is mentioned in the emergency procedure should appear on the list. For these instruments, (1) justification should be provided for not considering the instrument safety related and (2) assurance should be provided that its subsequent failure will not mislead the operator or adversely affect the mitigation of the consequences of the accident. The environmental qualification of post-accident sampling and monitoring and radiation monitoring equipment is closely related to the review of the TMI Lessons-Learned modifications and will be performed in conjunction with that review."

In Reference 17, the Licensee provided the following response:

"A list of display instrumentation referenced in the Emergency Procedures is provided in Table 1 [Table C-1 of this TER]. The equipment in Table 1 has been divided into three categories.

Category A - Display instrumentation which has been previously included on the master list of the I.E. Bulletin 79-01B 90 Day Review, Revision 3. The appropriate worksheet page number for each item in this category can be found in Table 1.

Category B - Display instrumentation which is in a harsh environment but not previously listed on the master list of I.E. Bulletin 79-01B 90 Day Review, Revision 3. Equipment in this category has been added to the master list of I.E. Bulletin 79-01B 90 Day Review, Revision 4, as a result of our review of the Emergency Procedures. The appropriate worksheet page number for the equipment in this category can be found in Table 1.

The qualification status and proposed corrective action of equipment in Category B is as follows:

LT-RS251A, B

Containment Sump Level

This equipment is being replaced as part of the TMI Lessons-Learned modifications. The transmitters were included on the master list for the

TMI Review Supplement 3 response submitted
February 1, 1981.

PT-2402

RCS Wide Range Pressure

PT-RC2401-1

RCS Wide Range Pressure

LT-2477, 87, 97

Steam Generator Wide Range Pressure

PT-RS256A, B

Outside Recirculation Spray Pump Discharge
Pressure

FT-2961, 62, 63

Cold Leg. SI Flow

FT-2945, 46

Low Head Injection Header Flow

The sensor, cable and terminations of the indication listed above will be reviewed for qualification. Those portions of the instrumentation loop that are exposed to a harsh environment will be upgraded with qualified equipment. This will ensure that the operator will not be provided with erroneous indication due to the effects of a harsh environment on this equipment in the event of a LOCA or MSLB.

The majority of the display instrumentation in the Surry control room is supplied directly from protection channels. However, to ensure the integrity of the trip function, an isolation device is provided to supply the indicator so that faults at the indicator will not be reflected into the safety trip portion of the circuit. Therefore, the cables that run from the safety trip circuit to the indicator are not treated as Class 1E cables with respect to cable separation. This approach allows for redundant indicators to be positioned side-by-side for comparison of readings.

Qualification of Post Accident Monitoring equipment referenced in the Emergency Procedures is a new requirement. Vepco will review the qualification status of this equipment and advise the NRC of the schedule for implementation of any required corrective action by June 30, 1982.

Category C - Display instrumentation which is not exposed to a harsh environment. These components will be included on the master list for equipment which is in a mild environment and will be reviewed as such. At present there is no requirement to provide Component Evaluation sheets for equipment in a mild environment."

Evaluation

In view of the Licensee's response, this item is considered resolved.



Table C-1. Display Instrumentation Referenced
in the Emergency Procedures [17]

Surry 1 and 2
August 24, 1981

TABLE 1
CATEGORY A

<u>MARK NUMBER</u>	<u>DESCRIPTION</u>	<u>EXPOSED TO A HARSH ENVIRONMENT</u>	<u>PREVIOUSLY LISTED ON MASTER LIST</u>	<u>WORKSHEET</u>	<u>COMMENT</u>
TE-2413	RCS Temperature Element (Wide Range)	X	X	191	--
TE-2423	RCS Temperature Element (Wide Range)	X	X	195	--
TE-2433	RCS Temperature Element (Wide Range)	X	X	199	--
PT-LM200A	Containment Pressure (Narrow Range)	X	X	128	--
PT-LM200B	Containment Pressure (Narrow Range)	X	X	129	--
PT-LM200C	Containment Pressure (Narrow Range)	X	X	130	--
PT-LM200D	Containment Pressure (Narrow Range)	X	X	131	--
LT-2459	Pressurizer Level Protection	X	X	182	--
LT-2460	Pressurizer Level Protection	X	X	183	--
LT-2461	Pressurizer Level Protection	X	X	184	--
LT-2474	Steam Generator Narrow Range Protection	X	X	90	--
LT-2484	Steam Generator Narrow Range Protection	X	X	93	--

NOTE: Surry Unit Two mark numbers are provided. Table 1 also applies to Surry Unit 1 equipment.

**FIGURE SUPPLIED
BY THE LICENSEE**

Table C-1 (cont.)

Surry 1 and 2
August 24, 1981

TABLE 1
CATEGORY A - (Continued)

<u>MARK NUMBER</u>	<u>DESCRIPTION</u>	<u>EXPOSED TO A HARSH ENVIRONMENT</u>	<u>PREVIOUSLY LISTED ON MASTER LIST</u>	<u>WORKSHEET</u>	<u>COMMENT</u>
LT-2494	Steam Generator Narrow Range Protection	X	X	96	--
LT-2475	Steam Generator Narrow Range Protection	X	X	91	--
LT-2485	Steam Generator Narrow Range Protection	X	X	94	--
LT-2495	Steam Generator Narrow Range Protection	X	X	97	--
LT-2476	Steam Generator Narrow Range Protection	X	X	92	--
LT-2486	Steam Generator Narrow Range Protection	X	X	95	--
LT-2496	Steam Generator Narrow Range Protection	X	X	98	--
PT-2474	Steam Generator 1 Pressure	X	X	151	--
PT-2475	Steam Generator 1 Pressure	X	X	152	--
PT-2476	Steam Generator 1 Pressure	X	X	153	--
PT-2484	Steam Generator 2 Pressure	X	X	154	--
PT-2485	Steam Generator 2 Pressure	X	X	155	--

FIGURE SUPPLIED
BY THE LICENSEE

TER-C5257-482

Table C-1 (Cont.)

Surry 1 and 2
August 24, 1981

TABLE 1

CATEGORY A - (Continued)

<u>MARK NUMBER</u>	<u>DESCRIPTION</u>	<u>EXPOSED TO A HARSH ENVIRONMENT</u>	<u>PREVIOUSLY LISTED ON MASTER LIST</u>	<u>WORKSHEET</u>	<u>COMMENT</u>
PT-2486	Steam Generator 2 Pressure	X	X	156	--
PT-2494	Steam Generator 3 Pressure	X	X	157	--
PT-2495	Steam Generator 3 Pressure	X	X	158	--
PT-2496	Steam Generator 3 Pressure	X	X	159	--
FT-FW200A	Aux Steam Generator Feed Pump Flow	X	X	87	--
FT-FW200B	Aux Steam Generator Feed Pump Flow	X	X	88	--
FT-FW200C	Aux Steam Generator Feed Pump Flow	X	X	89	--

**FIGURE SUPPLIED
BY THE LICENSEE**

Table C-1 (cont.)

Surry and 2
August 24, 1981

TABLE 1

CATEGORY B

<u>MARK NUMBER</u>	<u>DESCRIPTION</u>	<u>EXPOSED TO A HARSH ENVIRONMENT</u>	<u>PREVIOUSLY LISTED ON MASTER LIST</u>	<u>WORKSHEET</u>	<u>COMMENT</u>
LT-RS251A	Containment Sump Level	X		10.3-30	TMI Reveiw Supplement 3
LT-RS251B	Containment Sump Level	X		10.3-31	TMI Reveiw Supplement 3
PT-2402	RCS Wide Range Pressure	X		6-273	--
PT-RC2402-1	RCS Wide Range Pressure	X		6-274	--
LT-2477	Steam Generator Wide Range Level	X		6-275	--
LT-2487	Steam Generator Wide Range Level	X		6-276	--
LT-2497	Steam Generator Wide Range Level	X		6-277	--
PT-RS256A	Outside Recirculation Spray Pump Discharge Pressure	X		6-278	--
PT-RS256B	Outside Recirculation Spray Pump Discharge Pressure	X		6-279	--
FT-2961	Clod Leg Safety Injection Flow	X		6-280	--
FT-2962	Clod Leg Safety Injection Flow	X		6-281	--
FT-2963	Clod Leg Safety Injection Flow	X		6-282	--
FT-2945	Low Head Injection Header Flow	X		6-283	--
FT-2946	Low Head Injection Header Flow	X		6-284	--

FIGURE SUPPLIED
BY THE LICENSEE

Table C-1 (Cont.)

Surry 1 and 2
August 24, 1981

TABLE 1
CATEGORY C

<u>MARK NUMBER</u>	<u>DESCRIPTION</u>	<u>EXPOSED TO A HARSH ENVIRONMENT</u>	<u>PREVIOUSLY LISTED ON MASTER LIST</u>	<u>WORKSHEET</u>	<u>COMMENT</u>
LT-CS200A	Refueling Water Storage Tank Level			NA	--
LT-CS200B	Refueling Water Storage Tank Level			NA	--
LT-CN200	Consensate Storage Tank Level			NA	--
LT-CS200C	Consensate Storage Tank Level			NA	--
LT-CS200D	Consensate Storage Tank Level			NA	--

C-10

**FIGURE SUPPLIED
BY THE LICENSEE.**

APPENDIX D - REVIEW OF LICENSEE'S RESPONSE TO NRC EEQ
SER CONCERNING JUSTIFICATION FOR INTERIM OPERATION

1. BACKGROUND

The NRC Safety Evaluation Report (SER) concerning equipment environmental qualification (EEQ) states [16]:

"Subsection 4.2 identified deficiencies that must be resolved to establish the qualification of the equipment; the staff requires that the information lacking in this category be provided within 90 days of receipt of this SER. Within this period, the licensee should either provide documentation of the missing qualification information which demonstrates that such equipment meets the DOR guidelines or NUREG-0588 or commit to a corrective action (requalification, replacement, relocation, and so forth) consistent with the requirements to establish qualification by June 30, 1982. If the latter option is chosen, the licensee must provide justification for operation until such corrective action is complete."

On January 19, 1982, FRC representatives met with NRC Division of Licensing personnel at NRC offices to discuss the potential for FRC to assist the staff in the technical review of licensees' statements regarding justification for interim plant operation submitted in response to outstanding qualification deficiencies in the NRC EEQ SERs. The results of the meeting were as follows: (1) FRC was requested to proceed immediately with the technical review of licensees' justification for interim operation, (2) the format was established, and (3) the criteria for the review were established. These criteria are presented in Section 2 of this appendix.

On January 21, 1982, the NRC provided the following modification to Final Assignment 13 concerning this subject:

"The FRC review will consist of:

- o Review the licensee's justification of interim operation and provide FRC independent analysis which shows whether or not licensee provided technically sound rationale as a basis for justification for continued plant operation.

- o On January 27, 1982, FRC shall provide a list of those power reactors that have provided technically sound justification for continued operation. FRC shall also provide a list of those power reactors which have not provided technically sound justification for continued operation. In addition to the lists, FRC may provide any additional information which in FRC's judgment is necessary to support the conclusions regarding justification for continued operation."

On January 25, 1982, the NRC was provided with the completed review of the licensees' statements presented as a basis for justification for interim operation in response to the NRC EEQ SER.* On February 5, 1982, at the NRC's request, the NRC was provided with actual examples of licensees' responses to the NRC EEQ SER that provide adequate rationale as a basis for justification for interim operation.**

2. GENERAL DISCUSSION

In general, licensee-submitted justifications for interim operation are based on systems considerations, equipment operability evaluations, or failure-modes-and-effects analyses.

Systems considerations often involve the availability of backup equipment capable of performing the particular safety function of concern. The backup equipment is either environmentally qualified, unqualified but not exposed to a harsh environment at the same time as the primary equipment, or located so that it is unlikely that both the primary and backup equipment would be simultaneously exposed to a severe environment. In general, these systems discussions should consider (1) the possibility of a single-active failure

* C. J. Crane

Letter to R. A. Clark, NRC. Subject: Transmittal of FRC Review of Licensees' Responses to NRC EEQ SER Concerning Justification for Interim Operation
FRC, 25-Jan-82

** C. J. Crane

Letter to R. A. Clark, NRC. Subject: Transmittal of Actual Examples of Licensees' Responses to NRC EEQ SER Which Provide Adequate Rationale as a Basis for Justification of Interim Operation
FRC, 5-Feb-82

disabling the backup equipment, (2) any major differences in the characteristics of the primary and backup equipment (unless it is obvious that the equipment is essentially identical), (3) the possibility of electrical failure of the primary equipment causing an adverse effect on other safety-related equipment or power supplies, and (4) in the case of display instrumentation, the possibility of an operator being misled by the failed primary equipment. Where equipment has not been demonstrated to be qualified, some justifications discuss administrative procedures or revised operating procedures in effect. Depending upon the specific equipment involved, each of the above considerations need not be discussed in every instance, but, in general, a complete systems discussion would consider the above points.

Where equipment qualification evaluations were used, licensees generally (1) received additional information from manufacturers, (2) applied engineering judgment, (3) performed material analysis, and/or (4) used partial test data in support of the original qualification documentation. Where these evaluations were performed, the licensees determined that, although full qualification was not documented, there was sufficient evidence to suggest that the equipment would perform its intended safety function, thereby justifying interim operation until qualified equipment is installed.

Some licensees provided detailed failure-modes-and-effects analyses of electrical circuitry to demonstrate that, under all identified failure modes, the safety function of the equipment could still be accomplished.

Other justifications involved a combination of qualification information and systems information. For example, if a licensee has qualification information (such as a generic test report or other partial qualification documentation) that tends to confirm the ability of the equipment to remain operable for a specified period of time, justification for interim operation often was based upon a discussion of the required safety function being performed prior to the potential failure. This type of discussion often applies to equipment which performs a short-term trip or isolation function in the early stages of an accident.

3. PLANT-SPECIFIC REVIEW

As a result of the review, this plant was evaluated and the results documented on the "Summary of Review of Licensee's 90-Day Response" form reproduced below:

"EQUIPMENT ENVIRONMENTAL QUALIFICATION (EEQ)
Review of Licensees' Resolution of Outstanding Issues
From NRC Equipment Environmental Qualification
Safety Evaluation Reports

SUMMARY OF REVIEW OF LICENSEE 90-DAY RESPONSE

Utility: Virginia Electric and Power Company
Plant Name: Surry Unit 1
NRC Docket No. 50-280
NRC TAC No. 42-468
NRC Contract No. NRC-03-79-118
FRC Project No. C5257
FRC Assignment No. 13
FRC Task No. 482

References:

- a. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga, NRC.
Subject: Response to Safety Evaluation Report for
Environmental Qualification ... IE Bulletin 79-01B 90-Day Review;
Surry Units 1 and 2
Virginia Electric & Power Co., 24-Aug-81
Serial No. 329
- b. Office of Nuclear Reactor Regulation
Safety Evaluation Report for Surry Unit 1
Environmental Qualification of Safety-Related
Electrical Equipment
NRC, 21-May-81

The Licensee has submitted technical information in Reference a in response to the NRC SER [b] on environmental qualification. FRC has reviewed these documents [a, b]. As a result of this review, FRC concludes that the Licensee has stated that the equipment items are environmentally qualified; or has provided a technically sound rationale as a basis for justification for continued plant operation; with the following exceptions:

<u>Equipment Item</u>	<u>Equipment Description/ Function</u>	<u>SCEW Sheet No.</u>	<u>Status Code</u>	<u>Basis for Deficiency</u>
Terminal blocks and splices	Various safety-related circuits	Para. 7.1.11 [a]	2	Note 1
ASCO solenoid valve operators	Various systems inside and outside containment	Para. 7.2.2 [a]	2	Note 2
Pumps	Charging pump component cooling water pumps	Para. 7.2.7 [a], 6-61, 6-62	2	Note 3

In general, with the exception of the items noted above, the Licensee's response to the SER addressed and provided resolution of deficiencies identified in the SER and provided adequate rationale as a basis for justification for interim operation.

JUSTIFICATION FOR INTERIM OPERATION (JIO) STATUS CODE:

1. No justification for interim operation provided.
- *2. Justification for interim operation submitted but technically deficient.
3. Justification for interim operation submitted and requires further evaluation:
 - a. Systems response
 - b. Non-systems response.
4. Licensee states the item is or should be exempted from qualification:
 - *a. Basis for exemption technically deficient, both as an exemption request and as a justification for interim operation.
 - b. Basis for exemption requires further evaluation as a justification for interim operation:
 - (1) System response
 - (2) Non-systems response.

*Basis for deficiency is provided in Notes 1 through 3.

NOTE 1

The Licensee states:

'7.1.11 Terminal Blocks and Splices

Terminal blocks and splices of several manufacturers have been utilized in safety related circuits for Surry Units 1 and 2. Documentation to support qualification of all types of terminal blocks and splices has not been assembled.

7.1.11.1 Modification/Replacement Status

VEPCO has undertaken a program (special test 104) to verify model and serial numbers of all safety-related equipment on the master list. As a result of the special test effort, many of the terminal blocks and splices have been identified. Information we can gather generically on various manufacturers/types of terminal blocks indicate that most of all types of terminal blocks are qualifiable to meet the DOR guidelines.

Upon completion of our review of the information gathered in the field verification program, qualification packages for all types of installed terminal blocks and splices will be assembled. Where documentation deficiencies cannot be corrected in a cost effective manner, the terminal blocks or splices will be replaced by qualified terminal blocks or splices.

As part of the field verification program, all terminal blocks in safety related circuits located inside containment were replaced with qualified Raychem Splices (WCSF-N).

7.1.11.2 Modification/Replacement Schedule

The field inspection of installed terminal blocks and splices will be finalized to provide specific identification of the installed terminal blocks and splices. This inspection will be completed by the first quarter of 1982. Upon completion of this inspection, the data will be reviewed to identify any unqualified terminal blocks and splices. A schedule for replacement of any unqualified terminal blocks or splices will be developed by the end of the second quarter of 1982.

7.1.11.3 Justification for Continued Operation

The terminal blocks and splices that exist in the plant have been specified and installed in strict accordance with the established power industry practices. These terminal blocks and splices have a history of reliability and satisfactory performance under similar operating conditions.

On the basis of the above, it is reasonable to conclude that these terminal blocks and splices will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of the Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.'

FRC EVALUATION

FRC assumes that the remaining splices and terminal blocks that require field verification are located outside containment in HELB areas. FRC concludes that for unverified components (terminal blocks and splices) which are required to operate under DBE HELB conditions, the Licensee's contention that industry specifications and practices are adequate is not a suitable justification for interim operation unless it has been verified that those practices and specifications envelope the DBE conditions.

NOTE 2

The Licensee states:

'7.2.2 ASCO (Solenoid Operators)

7.2.2.1 Modification/Replacement Status

We are in the process of replacing all solenoids which lack complete qualification documentation with qualified components. We will replace them with ASCO NP-Series SOVs.

7.2.2.2 Modification/Replacement Schedule

Replacement SOVs have been placed on order. Based on current projections for material delivery and the present outage schedule, replacements are scheduled to start during the first quarter of 1982.

7.2.2.3 Justification For Continued Operation

The solenoid valves that exist in the plant have been specified, installed, and maintained thus far in strict accordance with established power industry practices. These valves have Class B insulation coils rated at 266 F (130C) for continuous operation. The existing solenoid valves are NEMA type 4 construction, which is a watertight and dust tight construction. Their enclosures are intended to protect enclosed components against splashing water, seepage of water, and several external environments. They are heat resistant. They are Underwriter's

Laboratory (UL) listed, and Factory Manual certified, which are based on type tests. Material analysis of the existing solenoid components (i.e., insulation, plastic parts such as bobbin, o-rings and seals) indicate that they have a radiation resistance of 10E6 rads or better.

On the basis of the above, it is reasonable to conclude that these solenoid valves will perform their intended safety function when exposed to harsh environments. Therefore, continued operation of Surry Units with this equipment, albeit incomplete qualification documentation, will have little or no impact on plant safety.'

FRC EVALUATION

Although the Licensee has provided a material analysis which he maintains is reasonable assurance of operability, FRC concludes that the justification for interim operation is not adequate to provide assurance for solenoids which are required to operate after the DBE at various time intervals. The Licensee's analysis should address the specific safety function and failure modes of the solenoid valves and the effect on system operation."

TE 3

The Licensee states:

'7.2.7 General Electric Corporation (Charging Pump Component Cooling Water Pumps)

PLANT ID NO.

WORKSHEET PAGE NO.

1-CC-P-2A

6-61

1-CC-P-2B

6-62

7.2.7.1 Modification/Replacement Status

We will replace the charging pump component cooling water pump motors with qualified replacement units.

7.2.7.2 Modification/Replacement Schedule

Based on current projections for purchase order placement, material delivery and our present outage schedule, replacement is scheduled to start during the last quarter of 1982.

7.2.7.3 Justification For Continued Operation

The charging pump component cooling water pumps provide seal and cooling water for the mechanical seals of the charging pumps during their operation. In the event of a cooling water pump failure, the manufacturer has determined that the water reservoir surrounding the charging pump mechanical seals should provide a sufficient buffer to extend the operation of the pumps for approximately one (1) hour. Further, since during the use of charging pumps in its safety injection mode, it is handling cold water from the refueling water storage tank, which will minimize the heat load for the charging cooling system.

On the basis of the above, it is concluded that the component cooling water pumps will perform their intended safety function, and will have no impact on plant safety.'

FRC EVALUATION

FRC concludes that no assurance of operability beyond 1 hour after failure of cooling water pumps has been provided by the Licensee. The Licensee should assess the availability of alternate systems to provide the essential safety function."

APPENDIX E - REQUEST FOR ADDITIONAL INFORMATION

This appendix contains the Request for Additional Information (RAI) that was developed during the course of the review and issued to the NRC for forwarding to the Licensee. The RAI was revised throughout the review to reflect the Licensee's response(s) to the initial RAI.

The reader is cautioned that the numbers in brackets refer to citations found in the list of references at the end of this appendix and not to the citations listed in Section 6, References, of the TER.

REQUEST FOR ADDITIONAL INFORMATION

EQUIPMENT ENVIRONMENTAL QUALIFICATION (EEQ)
REVIEW OF LICENSEES' RESOLUTION OF OUTSTANDING ISSUES
FROM NRC EQUIPMENT ENVIRONMENTAL QUALIFICATION SAFETY
EVALUATION REPORTS (SER) AND TMI ACTION PLAN INSTALLED EQUIPMENT

Virginia Electric and Power Company

Surry Unit 1

NRC Docket No. 50-280

November 30, 1981

NRC TAC No. 42468

Rev. 1, April 7, 1982

Rev. 2, June 4, 1982

BACKGROUND

Franklin Research Center (FRC) of Philadelphia, Pa. is providing assistance to the U.S. Nuclear Regulatory Commission (NRC) for the equipment environmental qualification (EEQ) review of operating reactors. FRC will perform an EEQ review of the Licensee's 90-day response to outstanding issues from the NRC Equipment Environmental Qualification Safety Evaluation Report (SER) and the installed TMI Action Plan equipment. The review will be limited to safety-related equipment potentially exposed to a harsh environment. The results will be presented in the form of a technical evaluation report for each plant.

This request for additional information (RAI) is the result of an evaluation of the information provided by letters dated February 1, 1981 [1] and December 1, 1980 [2].* FRC previously requested TMI Action Plan information by a telephone memorandum dated August 12, 1981 [3].

In response, VEPCO transmitted the following information on September 10, 1981 [4].

- a. Comsip-Delphi Engineering Analysis and Test Report 1035-1 on the containment hydrogen analyzers providing IEEE test results for Model KIII and KIV analyzers
- b. Environmental Zone Description Volumes 1-4 for Surry Power Station.

On February 8, 1982, VEPCO transmitted a response to the FRC request for information which stated that submitting their EEQ documentation to FRC would be in violation of their Technical Specifications. The Licensee extended an invitation to FRC to audit the EEQ files at VEPCO's corporate headquarters in Richmond, Virginia [8]. (1)**

By letter dated May 18, 1982, VEPCO submitted information regarding documentation referenced in their EEQ submittal; specifically, a list of

*Numbers in brackets refer to citations found in the list of references.

**Throughout the text, superscript numbers in parentheses indicate the revision in which the underlined material preceding the superscript was added.

references requested and the status of these references was provided. The Licensee stated that the QDR packages requested would be forwarded under separate cover by NUS Corporation.⁽²⁾

By letter dated May 21, 1982 [10], NUS Corporation transmitted a complete set of the qualification documentation review packages along with additional status information regarding certain references requested.⁽²⁾

On May 26, 1982, FRC received the equipment qualification master lists [11] for Surry Units 1 and 2.⁽²⁾

A. FRC REVIEW OF THE LICENSEE'S 90-DAY RESPONSE TO THE NRC EEQ SER

INFORMATION REQUESTED

DATE RECEIVED BY FRC***

1. In reference to the Licensee's 90-day response [5] to the NRC SER [6], a legible single copy of each of the following qualification documents is requested in order that the FRC evaluation may proceed:

(The numbers in parentheses after the letter correspond to the numbers in Section 8 of Reference 5.)

- a(2). Environmental Qualification of Reactor Coolant Temperature Detectors and Containment Pressure Transmitters, VEPCO submittal No. 855, November 1, 1979.
- b(3). Qualification of Resistance Temperature Detectors, VEPCO submittal No. 855A, for North Anna Power Station Units 1 and 2, November 1, 1979.
- c(5). Learn, J. R., Boston Insulated Wire and Cable Company, to Wright, R. D., Stone & Webster Engineering Corporation, 300 V Instrument Cables and 600 V Control Cables, January 17, 1972.

***This column will be completed by FRC as the requested information is received.

DATE RECEIVED BY FRC***

d(6). Limitorque Corporation, Nuclear Qualification Data for Safety Related Service, NQDS, November 1, 1979.

e(7). Anderson, T. M., Westinghouse Electric Corporation, to Stolz, J. F., Nuclear Regulatory Commission, NS-TMA-1950, September 29, 1978. Possible attachments include: Vota, J. L., Westinghouse Electric Corporation, to Proffitt, W. L., Virginia Electric Power Company, October 19, 1978, Eicheldinger, C., Westinghouse Electric Corporation, to Stolz, J. F., Nuclear Regulatory Commission, March 23, 1977, Westinghouse Sensor Qualification Program, IEEE 323-1971 Demonstration Program, Final Test for Barton/ITT Modified Pressure Transmitter (Proprietary Class 2).

Received 3/4/82 for
Tasks 497/498⁽¹⁾

f(9). Anderson, T. M., Westinghouse Electric Corporation, to Stolz, J. F., Nuclear Regulatory Commission, NS-TMA-2120, September 14, 1979, Revision A, September 30, 1979. Possible attachments include: Westinghouse Supplemental Qualification Testing of Barton Lot 1 Pressure and Differential Pressure Transmitters (Proprietary Class 2).

g(12). Chapman, L., Stone, J., Tests of Electric Cables After Simulated Post-Accident Reactor Containment Service, Cerro Wire and Cable Technical Report NP-04, March 1971.

Received 2/12/82 for
Task 495⁽¹⁾

DATE RECEIVED BY FRC***

- h(13). Alm, C. A., Marth J. R.,
Qualification of Firewall III Class
IE Electric Cables, Rockbestos
Company, Rockbestos Report
13-10407-E058-13-2, June 22, 1978,
Updated August 22, 1978.
- i(18). D. G. O'Brien Incorporated,
Environmental Test Report, DGO Report
No. C19QA061, February 28, 1972. 5/24/82 [10](2)
- k(23). Sheets M. W., Topical Report on
General Electric Vertical Induction
Motors, Inside Containment
Recirculation Spray Pump Motors -
Surry Power Station - Second Addendum
to Cover Heat Aging, Radiation.
Exposure, Vibration, and
Steam/Chemical Spray Exposure
Qualification Tests, NRC Docket Nos.
50-280 and 50-281, June 12, 1973 and
July 23, 1973. Received 2/11/82 for
Task 490(1)
- l(24). Sheets, M. W., Topical Report on
General Electric Vertical Induction
Motors, Inside Containment
Recirculation Spray Pumps for the
Surry and North Anna Stations of
Virginia Electric and Power Company,
Third Addition to Cover Rebuilding
Motors Using New Bearings, Docket
Nos. 50-280 and 50-281, Report No.
491HA689, July 23, 1979. 5/24/82 [10](2)
- m(37). Cerro Wire and Cable Company,
Qualification of Firewall III Class IE
Electrical Cables, May 1976.
Attachments include: Patterson, W. J.,
Cerro Wire and Cable Company, to
Maguire, T. A., Stone & Webster
Engineering Corporation, subject:
Identification of cable supplied under
this P.O. as Firewall III, June 9,
1976. Received 3/4/82 for
Tasks 497/498(1)

DATE RECEIVED BY FRC***

- n(38). Schwencer, A., Nuclear Regulatory Commission, to Proffitt, W. L., Virginia Electric and Power Company, subject: Environmental Qualification Testing of Continental Instrumentation Cable, July 25, 1979. 5/24/82 [10](2)
- o(40). Lasky, J. S., Okonite Company, to Bonner, J., Stone & Webster Engineering Corporation, October 15, 1980. 5/24/82 [10](2)
- p(42). Ling, T. H., Anaconda Wire and Cable Company, to Bonner, J., Stone & Webster Engineering Corporation, October 28, 1980. 5/24/82 [10](2)
- q(44). Bell, C. E., General Electric Company, to Bonner, J., Stone & Webster Engineering Corporation, subject: Qualification of Inside Recirculation Pump Motors to Withstand a pH of 7-11, October 28, 1980.
- r(45). Drab, J. B., Limitorque Corporation, to Reilly, P., Stone & Webster Engineering Corporation, subject: Qualification Information for Limitorque Actuators - Surry Power Station Units 1 & 2, October 8, 1980. Possible attachments include: Reilly, P., Stone & Webster Engineering Corporation, to Drab, J. B., Limitorque Corporation, two letters, September 11, 1980 and September 29, 1980, MacFarlane, I. S., Stone & Webster Engineering Corporation, Memo to Whom It May Concern, dated January 28, 1981, MacFarlane, I. S., Stone & Webster Engineering Corporation, to Drab, J. B., Limitorque Corporation, Telephone Memorandum dated December 12, 1980, MacFarlane, I. S., Stone & Webster Engineering Corporation, to McQuillan, P., Limitorque Corporation, Telephone Memorandum

- r(45). dated October 27, 1980, Zarandi,
(Cont.) VEPCO, to MacFarlane, I. S., Stone &
Webster Engineering Corporation,
November 7, 1980; MacFarlane, I. S.,
Stone & Webster Engineering
Corporation, to Padulla, D. and
Smith, R., VEPCO, Memo dated November
3, 1980, MacFarlane, I. S., Stone &
Webster Engineering Corporation, to
Padulla, D., VEPCO, Memo dated
November 4, 1980.
- s(47). Conax Corporation, Engineering
Department Certificate to Virginia
Electric and Power Company, subject:
Compliance of NAS-21 revised May 5,
1972 to equipment ordered under
purchase order SN-491, dated December
13, 1972.
- t(51). Drab, J. B., Limitorque Corporation,
to Barnhart, J. H., Stone & Webster
Engineering Corporation, subject:
Qualification Information for
Limitorque Actuators - Surry Power
Station Units 1 & 2, two letters,
November 13, 1980. Possible
attachments include: Barnhart, J. H.,
Stone & Webster Engineering
Corporation, to Limitorque
Corporation, November 3, 1980.
- u(52). Drab, J. B., Limitorque Corporation,
to MacFarlane, I. S., Stone & Webster
Engineering Corporation, subject:
Qualification Information for
Limitorque Actuators - Surry Power
Station Units 1 & 2, November 14,
1980. Possible attachments include:
MacFarlane, I. S., Stone & Webster
Engineering Corporation, to
Drab, J. B., Limitorque Corporation,
Memo - Subject: 79-01B Environmental
Qualification of Equipment, dated
November 12, 1980, MacFarlane, I. S.,
Stone & Webster Engineering

DATE RECEIVED BY FRC***

- u(52). Corporation, To Whom It May Concern,
(Cont.) Memo dated January 28, 1981;
MacFarlane, I. S., Stone & Webster
Engineering Corporation, to
Drab, J. B., Limitorque Corporation,
Telephone Memorandum dated
December 12, 1980.
- v(53). Kuster, J. M., Raychem Corporation,
to Barnhart, J. H., Stone & Webster
Engineering Corporation, subject:
Flamtrol Wire & Cable, North Anna
Nuclear Units 3 & 4, Stone & Webster
P.O. 3190, November 17, 1980.
Possible attachments include:
MacFarlane, I. S., Stone & Webster
Engineering Corporation, to
Kuster, J., Raychem Corporation,
Telephone Memorandum dated November
18, 1980.
- w(54). Lewicki, R. G., Reliance Electric
Company, to Barnhart, J. H., Stone &
Webster Engineering Corporation,
subject: VEPCO/Surry Power Station
Units 1 & 2, Motor Bearing Lubricant,
Reliance Part No. 4824-15-A,
November 14, 1980.
- x(55). Reliance Electric Company, Nuclear
Power Motor Systems, Type Test
Support Analysis, Random Wound Motors,
Summary Report NUC-9, July 1, 1978.
Includes Appendix: Seismic Report
78-R-33, Justification for Omission
of Routine "End Turn Stress Analysis"
for Random Wound Motors, July 10, 1978.
- y(56). Electric Power Research Institute,
Evaluation and Test of Improved
Fire-Resistant Fluid Lubricants
for Water Reactor Coolant Pump
Motors, Volume 1: Fluid Evaluation,
Bearing Model Tests, Motor Tests,
and Fire Test, Interim Report
NP-1447, July 1980.

Received for
Assignment 13(1)Received for
Assignment 13(1)

DATE RECEIVED BY FRC***

- z(58). Kuster, J., Raychem Corporation, to MacFarlane, I. S., Stone & Webster Engineering Corporation, subject: IE Bulletin 79-01B, Environmental Qualification of Equipment, Surry Power Station Units 1 & 2, Additional Qualification of Raychem Flamtrol Wire and Cable, Spec. No. NAS-3190, December 2, 1980.
- aa(60). McGowan, E. J., Raychem Corporation, Raychem-Flamtrol, Continuation of LOCA Simulation Test, Test Report EM #1403, December 9, 1977. Possible attachments include: Kuster, J., Raychem Corporation, to MacFarlane, I. S., Stone & Webster Engineering Corporation, January 27, 1981.
- bb(61). Cardello, P. S., Anaconda Ericsson Incorporated, to Bonner, J., Stone & Webster Engineering Corporation, subject: VEPCO Surry Qualification Data, three letters, October 8, 1980, October 21, 1980, and December 10, 1980.
- cc(64). Lasky, J. S., The Okonite Company, to Barnhart, J. H., Stone & Webster Engineering Corporation, subject: Environmental Qualification of Equipment, Surry Power Station Units 1 & 2, December 17, 1980.
- dd(68). Lasky, J. S., The Okonite Company, to Barnhart, J. H., Stone & Webster Engineering Corporation, Reference: J. O. No. 12846.44, December 22, 1980. Possible attachments include: Barnhart, J. H., Stone & Webster Engineering Corporation, to Lasky, J. S., Okonite Company, December 17, 1980; MacFarlane, I. S., Stone & Webster Engineering Corporation, To Whom It May Concern, Memo dated February 3, 1981.

DATE RECEIVED BY FRC***

- ee(69). Tolerico, F. A., Westinghouse Electric Corporation, to Barnhart, J. H., Stone & Webster Engineering Corporation, subject: Surry Power Station 1 & 2, Environmental Qualification of Hydrogen Recombiner, December 8, 1980.
- ff(72). Cookinham, J. H., Westinghouse Electric Corporation, to Brown, S. C., Virginia Electric and Power Company, subject: North Anna Power Station, NUREG-0588 Equipment Qualification, October 30, 1980. Possible attachments include: Newcomb, R. C., Virginia Electric and Power Company, to MacFarlane, I. S., Stone & Webster Engineering Corporation, Memo dated December 31, 1980.
- gg(73). Drab, J. B., Limitorque Corporation, to Reilly, P., Stone & Webster Engineering Corporation, subject: Qualification Information, North Anna Power Station Unit 2, September 19, 1980. Possible attachments include: MacFarlane, I. S., Stone & Webster Engineering Corporation, To Whom It May Concern, Memo dated January 28, 1981, MacFarlane, I. S., Stone & Webster Engineering Corporation, to Drab, J. B., Limitorque Corporation, Telephone Memorandum dated December 12, 1980.
- hh(76). Conax Corporation, Design Qualification Test Report for a Conax Low Voltage Control Service Classification Conductor Feedthrough Assembly P/N 7641-21001, Test Report No. IPS-353.2, June 18, 1979.
(Proprietary)

5/24/82 [10](2)5/24/82 [10](2)

DATE RECEIVED BY FRC***

- ii(77). Federick, W. C., Conax Corporation, to Reilly, P., Stone & Webster Engineering Corporation, subject: Environmental Qualification, Electrical Penetrations, North Anna Units 1 & 2, January 8, 1981.
- jj(79). Kushner, J. R., Rockbestos Company, to Barnhart, J. H., Stone & Webster Engineering Corporation, subject: S & W letter of 12/12/80, Items 1.a.(1) and 1.a.(2), February 24, 1981.
- kk(80). Ling, T. H., Anaconda Ericsson, to MacFarlane, I. S., Stone & Webster Engineering Corporation, subject: 600-Volt Power Cable, February 23, 1981. 5/24/82 [10](2)
- ll(82). Pirrong, J. S., Boston Insulated Wire & Cable Co., to Petty, K., Stone & Webster Engineering Corporation, subject: North Anna Cables, P.O. NA-265/1265, April 30, 1981.
- mm(83). Drab, J., Limitorque Corporation, to Barnhart, J. H., Stone & Webster Engineering Corporation, Telex, May 18, 1981.
- nn(84). Drab, J. B., Limitorque Corporation, to Barnhart, J. H., Stone & Webster Engineering Corporation, subject: Qualification Information for Surry Power Station - Units 1 & 2, May 19, 1981.
- oo(85). Technical Report 123-1247 dated April 1973. 5/24/82 [10](2)
- pp(86). Technical Report 123-2045 Rev. A dated March 25, 1975. 5/24/82 [10](2)
- qq(87). Report No. 23-1268 Revs. dated February 26, 1975. Received 3/11/82 for Task 505(1)

DATE RECEIVED BY FRC***

rr(88). Report No. 123-1269 Rev. dated February 26, 1975.	<u>5/24/82 [10](2)</u>
ss(89). Amphenol Design Verification Testing (DVT) Report No. 123-1275.	<u>Received 2/8/82 for Task 485⁽¹⁾</u>
tt(90). Qualification Report of General Electric Vertical Induction Motors for Class 1E Outside Recirculation Spray Pumps.	<u>5/24/82 [10](2)</u>
uu(91). Siemens-Allis Inc. (Medium Motor Division) Equipment Qualification Random Wound Motors for Class IE Safety Related Service.	<u>Received 3/4/82 for Task 486⁽¹⁾</u>
vv(93). Letter dated August 1, 1969 from Robert H. Dubuc of Cerro Wire & Cable Company to Mr. Roger Clark of S & W.	
ww(94). Cerro Wire & Cable Company Specification No. RSS-3-701 Issue 4, November 1, 1968 on Pyro-TROL III, 600 Volt Control Cables.	<u>5/24/82 [10](2)</u>
xx(96). NUS-VEPCO QDR Package 5437-96-01.	<u>5/24/82 [10](2)</u>
yy(98). NUS-VEPCO QDR Package 5437-SOV-02 changed to <u>5437-64-01.</u> (2)	<u>5/24/82 [10](2)</u>
zz(100). NUS-VEPCO QDR Package 5437-122-01.	<u>5/24/82 [10](2)</u>
aaa(102). NUS-VEPCO QDR Package 5437-121-01.	<u>5/24/82 [10](2)</u>
bbb(104). NUS-VEPCO QDR Package 5437-124-01.	<u>5/24/82 [10](2)</u>
ccc(106). NUS-VEPCO QDR Package 5437-119-01.	<u>5/24/82 [10](2)</u>
ddd(108). NUS-VEPCO QDR Package 5437-125-01.	<u>5/24/82 [10](2)</u>
eee(110). NUS-VEPCO QDR Package 5437-118-01.	<u>5/24/82 [10](2)</u>
fff(112). NUS-VEPCO QDR Package 5437-123-01.	<u>5/24/82 [10](2)</u>

DATE RECEIVED BY FRC***

ggg(114).	NUS-VEPCO QDR Package 5437-123-02 <u>changed to 5437-134-01.</u> (2)	<u>5/24/82 [10]</u> (2)
hhh(116).	NUS-VEPCO QDR Package 5437-125A-01.	
iii(118).	NUS-VEPCO QDR Package 5437-117-01.	<u>5/24/82 [10]</u> (2)
jjj(120).	NUS-VEPCO QDR Package 5437-127-01.	<u>5/24/82 [10]</u> (2)
kkk(122).	NUS-VEPCO QDR Package 5437-104-01.	<u>5/24/82 [10]</u> (2)
lll(124).	NUS-VEPCO QDR Package 5437-MOV-2-01 <u>changed to 5437-66-01.</u> (2)	<u>5/24/82 [10]</u> (2)
nnn(126).	NUS-VEPCO QDR Package 5437-MOV-2-02 <u>changed to 5437-97-01.</u> (2)	<u>5/24/82 [10]</u> (2)
ooo(127).	NUS-VEPCO QDR Package 5437-133-01.	<u>5/24/82 [10]</u> (2)
ppp(128).	Automatic Dampers (Safety Related) Qualification Report for Electric Actuators by RCS.	<u>5/24/82 [10]</u> (2)
qqq(134).	NUS-VEPCO QDR Package 5437-124-02 <u>changed to 5437-135-01.</u> (2)	<u>5/24/82 [10]</u> (2)
rrr(135).	NUS-VEPCO QDR Package 5437-128-01.	<u>5/24/82 [10]</u> (2)
sss(136).	NUS-VEPCO QDR Package 5437-103-15.	
ttt(137).	NUS-VEPCO QDR Package 5437-132-01.	<u>5/24/82 [10]</u> (2)
uuu(138).	NUS-VEPCO QDR Package 5437-120-01.	
vvv(139).	NUS-VEPCO QDR Package 5437-130-01.	<u>5/24/82 [10]</u> (2)
www(140).	NUS-VEPCO QDR Package 5437-103-02 <u>changed to 5437-136-01.</u> (2)	<u>5/24/82 [10]</u> (2)
yyy(141).	NUS-VEPCO QDR Package 5437-105-01.	<u>5/24/82 [10]</u> (2)
xxx(142).	NUS-VEPCO QDR Package 5437-69-01.	<u>5/24/82 [10]</u> (2)

B. FRC REVIEW OF INSTALLED TMI ACTION PLAN ITEMS

INFORMATION REQUESTED

DATE RECEIVED BY FRC***

1. References 2, 4, and 5⁽¹⁾ do not provide adequate detail with respect to identification of TMI Action Plan equipment installed after 1/1/81. Identification of all TMI Action Plan equipment installed after 1/1/81 is requested.
2. The qualification documents, e.g., the actual test reports and associated correspondence cited as evidence of qualification listed on the SCEW sheets, for all identified TMI Action Plan equipment are requested. [The identification of those reports considered to be proprietary is requested so that proper control of documents can be maintained.]
3. Where the Licensee has a standard Owners' Group position with respect to a NUREG-0737 [7]⁽¹⁾ technical area or has requested extensions of implementation dates, this information is requested in order to incorporate it into the review.

C. INSTRUCTIONS FOR TRANSMITTING INFORMATION REQUESTED

1. The schedule for completion of the FRC assignment requires that the Licensee provide the requested information within 3 weeks of the date of the RAI.
2. The Licensee may transmit the requested information as follows:
 - o complete package directly to the NRC project manager
 - or
 - o copy of cover letter to NRC project manager and complete package to FRC.

REFERENCES

1. Surry Unit 1 - IE Bulletin 79-01B,
TMI Review - Supplement 3, Revision 3 Change Package
Virginia Electric & Power Co.,
01-Feb-81
2. VEPCO Surry Unit 1 - IE Bulletin 79-01B
Revision 2 - Supplement 3 TMI Review
Virginia Electric & Power Co.,
01-Dec-80
3. Telephone Memorandum dated 8/12/81
C. J. Crane, J. Murphy (FRC) with D. Nabors (NRC-P.M.),
R. Newcomb and J. E. Wromiewicz (VEPCO).
Subject: RFI for Surry Units 1 and 2
4. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga (NRC)
Subject IE Bulletin 79-01B Supplement 3
TMI Review, Surry Power Station
Unit Nos. 1 and 2
September 10, 1981
5. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga (NRC)
Subject: Response to Safety Evaluation Report for
Environmental Qualification ... IE Bulletin 79-01B 90-Day Review;
Surry Units 1 and 2, Virginia Electric & Power Co.,
24-Aug-81
Serial No. 329
6. Office of Nuclear Reactor Regulation
Safety Evaluation Report for Surry Unit 1
Environmental Qualification of Safety-Related
Electrical Equipment
USNRC, 21-May-81
7. NUREG-0737, "Clarification of TMI Action Plan Requirements"
NRC, November 1980
8. R. H. Leasburg
Letter to S. A. Varga, NRC.
Subject: Request for Additional Information on Environment
Qualification of Safety-Related Electrical Equipment, Surry Power
Station Units 1 and 2
Virginia Electric & Power Co., 08-Feb-82
Serial No. 043(1)

9. R. H. Leasburg
Letter to H. R. Denton and S. A. Varga, NRC. Subject: Request for
Additional Information, Environmental Qualification of Safety Related
Electrical Equipment; Surry 1 and 2
Virginia Electric & Power Co., 18-May-82
Serial No. 282(2)

10. R. C. Wilson
Letter to C. J. Crane, FRC. Subject: Surry 1 and 2; Environmental
Qualification of Safety Related Electrical Equipment; Submittal of
Additional Information
NUS Corp., 21-May-82(2)

11. Surry Power Station Units 1 and 2; Electrical Qualification Master
Lists
Virginia Electric & Power Co., 14-Apr-82(2)